

6 浄水場毎日検査

(1)水道用水毎日検査

高蔵寺浄水場	204	豊田浄水場	207
尾張東部浄水場	204	幸田浄水場	207
上野浄水場	205	豊橋浄水場	208
知多浄水場	205	豊橋南部浄水場	208
犬山浄水場	206	豊川浄水場	209
尾張西部浄水場	206		

(2)工業用水毎日検査

尾張東部浄水場(東郷)	210
上野浄水場	210
知多浄水場	210
尾張西部浄水場	211
安城浄水場	211
豊橋南部浄水場	211
蒲郡浄水場(工水)	212

(1)水道用水毎日検査

高蔵寺浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.7	27.6	27.3	31.4	32.2	29.0	26.2	19.2	12.0	10.7	10.8	20.0	32.2	
	最小	8.1	15.7	18.6	25.3	22.7	18.7	14.0	6.8	1.5	-0.4	1.6	5.9	-0.4	
	平均	16.5	22.2	23.9	29.3	28.9	25.3	19.0	13.1	6.8	5.0	5.8	12.6	17.4	
原水水温 (°C)	最大	14.9	18.3	20.7	24.5	23.3	22.7	19.6	14.1	9.0	7.0	6.5	11.1	24.5	
	最小	9.3	12.7	17.8	19.0	21.1	19.0	13.8	9.0	5.5	3.8	3.8	6.9	3.8	
	平均	11.3	15.6	19.1	22.3	22.1	20.8	16.7	11.2	7.3	5.6	5.1	8.9	13.8	
濁度 (度)	原水	最大	49	6.8	4.3	348	155	7.8	58	31	2.0	8.1	2.6	57	348
		最小	1.6	3.4	2.0	1.9	4.5	2.2	2.0	1.8	1.1	0.9	1.6	2.1	0.9
		平均	8.6	4.5	3.0	32	18	3.8	6.8	3.8	1.6	2.1	2.0	9.5	8.0
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	25	5.0	5.0	113	24	9.0	26	19	3.0	8.0	3.0	20	113
		最小	3.0	4.0	3.0	3.0	3.0	4.0	4.0	4.0	2.0	2.0	3.0	3.0	2.0
		平均	6.7	4.4	3.6	12	6.8	5.5	6.9	4.8	2.8	3.5	3.0	6.4	5.5
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.3	7.3	7.3	7.2	7.2	7.3	7.3	7.4	7.3	7.3	7.4	7.4	
		最小	7.0	7.2	7.1	6.8	7.0	7.1	7.2	7.2	7.2	7.1	7.2	7.0	6.8
		平均	7.2	7.2	7.2	7.1	7.1	7.2	7.2	7.3	7.3	7.2	7.3	7.2	7.2
	浄水	最大	7.4	7.4	7.3	7.2	7.2	7.3	7.3	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.2	7.3	7.1	7.1	7.0	7.1	7.1	7.2	7.2	7.2	7.2	7.2	7.0
		平均	7.3	7.3	7.2	7.1	7.1	7.1	7.2	7.3	7.3	7.3	7.3	7.3	7.2
アルカ度 (mg/l)	原水	最大	20.0	16.5	18.5	20.0	16.5	18.5	20.0	19.5	21.0	20.5	21.0	21.5	21.5
		最小	8.0	13.5	15.5	9.5	9.0	13.5	10.5	10.0	16.5	10.5	16.5	8.5	8.0
		平均	13.9	15.5	17.0	15.7	14.3	16.7	16.0	16.9	19.1	17.0	18.4	13.9	16.2
	浄水	最大	19.0	16.0	17.5	18.5	15.5	17.0	19.0	18.5	20.5	19.5	20.5	21.0	21.0
		最小	9.5	13.5	15.0	10.5	10.0	13.5	11.5	10.0	16.0	11.0	16.0	10.0	9.5
		平均	14.1	15.0	16.0	15.4	13.6	15.5	15.5	16.3	18.4	16.6	17.9	14.0	15.7
KMnO ₄ 消費量 (mg/l)	原水	最大	12	4.3	5.1	74	26	6.8	14	9.0	3.4	5.4	3.5	11	74
		最小	2.8	2.8	2.5	2.8	3.9	2.9	2.8	2.0	2.2	2.0	2.0	2.6	2.0
		平均	5.0	3.5	3.4	9.6	6.8	4.2	4.9	3.2	2.7	3.2	2.6	4.2	4.5
	浄水	最大	1.9	1.5	1.7	1.9	1.7	1.5	1.7	1.5	1.2	1.5	1.2	1.5	1.9
		最小	0.6	0.7	0.6	0.8	0.8	0.8	0.8	0.3	0.6	0.8	0.8	0.8	0.3
		平均	1.2	1.0	1.0	1.3	1.2	1.3	1.2	0.7	1.0	1.1	1.0	1.0	1.1
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.6	
		最小	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.4	
		平均	0.4	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4	

尾張東部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	19.9	26.7	27.3	31.7	32.1	32.6	26.5	19.0	12.8	10.3	10.6	20.1	32.6	
	最小	8.2	16.4	18.6	25.8	24.4	19.6	14.5	6.3	2.1	0.2	2.1	7.2	0.2	
	平均	15.9	21.7	23.3	29.1	29.0	25.4	18.8	12.8	7.1	5.2	5.9	12.6	17.2	
原水水温 (°C)	最大	13.5	18.0	21.0	24.0	23.0	23.0	20.0	15.0	10.0	7.5	6.0	10.0	24.0	
	最小	10.0	13.5	18.0	19.5	21.5	19.5	14.0	9.5	5.5	4.0	4.0	6.5	4.0	
	平均	11.5	15.9	19.2	21.9	22.3	21.0	17.4	11.8	7.5	5.5	4.9	8.4	13.9	
濁度 (度)	原水	最大	45	7.2	4.1	600	132	15	33	59	2.5	6.6	2.5	40	600
		最小	1.3	3.0	1.0	1.6	4.2	2.6	2.1	1.9	1.1	0.9	1.6	2.5	0.9
		平均	7.1	4.3	2.5	45	17	4.5	5.4	5.0	1.7	2.0	2.0	9.0	8.8
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	15	8.5	4.8	240	33	9.7	15	22	3.8	6.1	3.2	18	240
		最小	2.6	2.6	1.7	2.5	3.2	3.7	2.2	3.0	2.1	1.8	2.3	2.9	1.7
		平均	4.9	3.7	3.2	16	6.4	5.5	5.6	4.4	2.6	3.0	2.7	5.8	5.3
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.7	7.6	7.8	7.5	7.6	7.6	7.6	7.6	7.5	7.6	7.5	7.8
		最小	7.1	7.4	7.3	6.9	7.1	7.2	7.2	7.1	7.4	7.2	7.3	7.1	6.9
		平均	7.3	7.5	7.4	7.3	7.3	7.4	7.4	7.4	7.5	7.4	7.4	7.3	7.4
	浄水	最大	7.3	7.3	7.2	7.2	7.2	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3
		最小	7.1	7.1	7.0	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.2	7.1	7.0
		平均	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2
アルカ度 (mg/l)	原水	最大	21.0	17.5	18.5	19.0	17.5	19.0	19.5	19.0	21.0	20.5	20.5	21.0	21.0
		最小	8.0	13.0	15.5	10.5	9.0	14.0	10.5	9.0	16.5	10.5	16.5	9.0	8.0
		平均	13.8	15.3	16.7	15.0	14.4	16.7	16.3	16.7	19.1	17.0	18.3	14.1	16.1
	浄水	最大	19.5	15.5	16.5	18.0	15.5	17.0	17.5	18.5	18.5	18.5	18.5	19.0	19.5
		最小	8.5	11.5	13.5	9.0	9.5	13.0	10.5	11.0	14.5	10.5	14.0	7.1	7.1
		平均	12.6	13.5	15.0	14.1	13.2	14.9	14.9	15.1	16.8	15.1	16.1	12.6	14.5
KMnO ₄ 消費量 (mg/l)	原水	最大	12	5.0	4.8	34	17	5.9	9.6	16	3.9	6.2	4.1	11	34
		最小	2.5	2.7	2.3	2.2	2.2	2.2	3.1	2.6	1.8	2.2	2.0	2.3	1.8
		平均	4.6	3.8	3.4	7.7	5.8	4.0	4.7	3.8	2.7	3.3	2.8	4.5	4.3
	浄水	最大	1.7	1.6	1.7	1.8	1.7	1.9	1.9	1.6	1.4	1.6	1.6	1.6	1.9
		最小	0.6	0.6	0.4	0.6	0.5	0.6	0.8	0.6	0.4	0.6	0.6	0.6	0.4
		平均	1.1	1.1	1.0	1.1	1.1	1.2	1.2	1.0	0.9	1.1	1.1	1.0	1.1
残留塩素 (mg/l)	浄水	最大	0.7	0.7	0.7	0.8	0.8	0.8	0.7	0.8	0.6	0.6	0.6	0.8	
		最小	0.6	0.6	0.6	0.7	0.7	0.7	0.6	0.6	0.5	0.5	0.5	0.5	
		平均	0.6	0.6	0.7	0.7	0.7	0.7	0.7	0.6	0.6	0.5	0.5	0.5	

上野浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	20.5	26.5	26.5	31.5	32.5	28.0	25.0	18.5	12.5	11.0	10.0	18.0	32.5	
	最小	8.0	16.0	18.0	25.5	24.5	20.0	14.0	7.0	2.5	-0.5	1.5	6.5	-0.5	
	平均	16.0	21.5	23.2	29.4	29.2	25.1	18.6	12.7	6.7	4.9	5.3	11.7	17.0	
原水水温 (°C)	最大	15.5	19.5	22.0	26.0	25.5	24.5	21.0	15.5	10.5	6.0	6.0	11.0	26.0	
	最小	9.5	14.5	19.5	22.0	24.0	21.0	15.5	10.5	6.0	4.5	4.0	6.5	4.0	
	平均	12.4	17.1	20.7	24.1	24.7	22.8	18.7	12.8	7.8	5.3	5.0	8.7	15.0	
濁度 (度)	原水	最大	9.8	5.7	4.3	9.5	6.6	8.6	7.6	9.3	2.9	3.1	1.9	7.4	9.5
		最小	4.1	2.3	1.7	1.5	4.7	3.5	2.7	1.9	1.3	1.2	1.4	1.6	1.2
		平均	5.9	4.1	3.0	10	15	5.4	4.4	3.7	2.0	1.7	1.6	4.5	5.1
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	5.9	6.7	6.1	5.3	30	8.2	7.5	8.7	3.9	2.7	2.4	3.7	5.3
		最小	<0.5	3.0	3.8	5.0	6.1	5.1	4.7	3.2	1.9	1.7	1.5	1.4	<0.5
		平均	2.8	4.8	5.0	9.8	10	6.3	5.7	4.9	2.6	2.2	1.8	2.5	4.9
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.7	7.5	7.4	7.4	7.5	7.5	7.5	7.7	7.6	7.6	7.6	7.6	7.7
		最小	7.3	7.3	7.3	7.1	7.1	7.2	7.3	7.3	7.3	7.5	7.4	7.4	7.2
		平均	7.5	7.4	7.3	7.2	7.2	7.4	7.4	7.5	7.6	7.5	7.5	7.4	7.4
	浄水	最大	7.5	7.5	7.3	7.3	7.2	7.2	7.4	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.3	7.2	7.2	7.0	7.0	7.1	7.2	7.3	7.4	7.3	7.4	7.4	7.0
		平均	7.4	7.4	7.2	7.1	7.1	7.1	7.3	7.4	7.4	7.4	7.4	7.4	7.3
アルカ度 (mg/l)	原水	最大	18.0	16.0	17.5	18.0	16.0	17.5	18.0	17.5	20.0	19.5	18.0	19.5	20.0
		最小	12.5	13.0	15.5	14.5	13.0	15.0	14.5	14.0	17.0	15.5	15.5	13.5	12.5
		平均	15.1	14.6	16.5	16.1	14.3	16.2	16.5	15.8	18.4	17.7	16.7	15.9	16.2
	浄水	最大	17.5	16.0	17.0	17.0	15.0	16.0	17.5	17.0	18.5	18.5	17.5	18.5	18.5
		最小	12.5	13.5	15.0	14.0	12.0	14.0	14.5	14.0	16.5	14.5	14.5	13.5	12.0
		平均	15.2	14.5	16.1	15.2	13.4	15.0	16.3	15.7	17.5	17.0	16.0	15.8	15.6
KMnO ₄ 消費量 (mg/l)	原水	最大	5.3	4.6	3.5	19	14	5.7	5.6	5.2	4.4	3.8	3.2	4.4	19
		最小	3.2	2.9	2.7	2.7	3.3	3.2	3.5	3.2	2.5	2.5	2.4	2.5	2.4
		平均	3.9	3.6	3.1	5.2	5.9	4.6	4.3	4.0	3.4	3.0	2.7	3.5	3.9
	浄水	最大	1.1	1.3	1.1	1.3	1.1	1.4	1.6	1.3	1.3	1.3	1.1	1.1	1.6
		最小	0.6	0.8	0.6	0.6	0.3	0.8	0.8	0.8	0.6	0.6	0.6	0.6	0.3
		平均	0.9	1.0	1.0	1.0	0.8	1.1	1.1	1.0	0.9	0.9	0.9	0.9	1.0
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.6	0.8	0.7	0.6	0.6	0.6	0.5	0.5	0.4	0.4	0.8
		最小	0.4	0.4	0.5	0.6	0.6	0.6	0.5	0.5	0.5	0.4	0.4	0.4	0.4
		平均	0.4	0.5	0.6	0.7	0.6	0.6	0.6	0.5	0.5	0.4	0.4	0.4	0.5

知多浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.0	28.0	28.0	33.0	34.0	29.0	25.0	18.5	11.0	9.0	10.0	21.0	34.0	
	最小	7.0	16.0	19.0	26.0	28.0	21.0	13.0	7.0	3.0	0.0	1.0	0.0	0.0	
	平均	16.2	22.1	24.0	30.4	29.2	25.3	18.5	12.4	6.2	3.9	4.4	9.7	16.9	
原水水温 (°C)	最大	17.0	25.0	26.5	29.5	29.5	26.5	23.0	16.5	12.0	9.0	9.6	15.0	29.5	
	最小	12.0	17.0	22.0	25.0	24.9	20.8	16.0	10.0	7.5	5.5	6.0	8.0	5.5	
	平均	14.4	20.7	23.7	27.2	26.6	24.0	19.4	13.9	9.3	7.3	7.5	11.1	17.1	
濁度 (度)	原水	最大	50	10	11	36	62	8.4	51	18	5.0	5.4	5.4	60	62
		最小	3.5	3.5	4.6	3.7	4.4	3.0	3.7	2.8	1.9	1.6	1.6	4.8	1.6
		平均	7.9	6.7	8.5	9.3	13.4	5.7	9.1	5.1	2.9	2.7	3.3	9.7	7.0
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	41	9.8	9.9	32	80	9.7	46	13	6.2	6.5	5.2	27	80
		最小	4.1	4.3	7.7	6.7	5.4	<0.5	4.2	3.1	3.0	2.2	2.6	4.1	<0.5
		平均	5.8	7.0	9.0	8.3	13	6.7	6.8	4.8	3.9	4.2	4.0	7.3	6.8
	浄水	最大	<0.5	<0.5	0.6	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.6	8.6	7.8	7.9	8.0	8.2	7.4	7.7	7.7	7.7	7.7	7.7	8.6
		最小	7.0	7.1	7.1	6.7	6.8	7.0	7.0	7.2	7.4	7.3	7.3	7.1	6.7
		平均	7.3	7.6	7.3	7.2	7.2	7.4	7.2	7.4	7.6	7.5	7.5	7.2	7.4
	浄水	最大	7.4	7.3	7.3	7.2	7.2	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.4
		最小	7.2	7.1	7.1	7.1	7.0	7.0	7.0	7.1	7.2	7.2	7.2	7.1	7.0
		平均	7.3	7.2	7.2	7.1	7.1	7.1	7.1	7.2	7.3	7.3	7.3	7.2	7.2
アルカ度 (mg/l)	原水	最大	33.0	35.0	36.5	35.5	32.5	35.0	34.0	36.0	37.5	36.0	37.5	37.5	37.5
		最小	12.5	24.0	25.0	17.0	16.0	22.0	15.0	16.5	25.5	22.5	30.5	12.5	12.5
		平均	24.3	30.4	32.4	28.5	26.0	29.4	26.9	30.8	33.4	29.3	34.4	22.4	29.0
	浄水	最大	31.0	34.0	35.0	36.0	30.5	31.0	33.0	33.0	34.0	34.0	35.5	35.0	36.0
		最小	14.5	23.0	25.5	19.5	17.0	20.5	16.0	17.0	23.0	20.0	28.0	13.0	13.0
		平均	24.1	28.3	30.7	28.0	25.4	27.5	26.9	29.2	30.9	27.3	32.4	22.4	27.8
KMnO ₄ 消費量 (mg/l)	原水	最大	10	7.6	8.8	11	14	7.5	12	5.0	5.4	5.1	5.4	14	14
		最小	2.2	3.2	4.7	3.8	2.5	2.8	2.8	2.2	2.2	2.2	2.5	1.9	1.9
		平均	3.7	4.7	6.2	5.9	5.4	4.3	4.7	2.9	3.1	3.3	3.5	4.1	4.3
	浄水	最大	1.3	1.9	2.2	1.6	1.9	1.6	1.3	1.3	2.5	1.9	1.9	1.9	2.5
		最小	0.3	0.6	0.9	0.6	0.3	0.3	0.6	0.3	0.6	0.6	0.6	0.3	0.3
		平均	0.8	1.1	1.5	1.2	0.8	1.0	0.9	0.8	1.1	1.2	1.2	0.9	1.0
残留塩素 (mg/l)	浄水	最大	0.5	0.7	0.9	0.8	0.8	0.8	0.7	0.7	0.7	0.6	0.6	0.6	0.9
		最小	0.4	0.4	0.7	0.7	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.4
		平均	0.5	0.5	0.7	0.7	0.7	0.7	0.6	0.6	0.6	0.5	0.5	0.6	0.6

大山浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.0	27.5	27.0	30.8	31.8	28.2	25.5	16.9	11.0	10.0	9.4	18.7	31.8	
	最小	8.3	15.3	18.6	23.7	22.5	18.7	13.9	5.9	1.6	-0.5	0.3	6.8	-0.5	
	平均	15.7	21.4	23.9	28.6	28.7	24.4	18.3	12.1	6.3	4.2	4.8	11.8	16.7	
原水水温 (°C)	最大	12.3	18.2	21.8	24.3	23.2	22.3	19.2	13.1	8.7	6.0	5.7	9.9	24.3	
	最小	8.8	11.9	18.2	19.7	21.0	19.1	13.5	8.3	4.7	3.3	3.2	6.0	3.2	
	平均	10.6	15.3	19.7	22.2	22.0	20.6	16.5	10.7	6.3	4.6	4.2	7.9	13.4	
濁度 (度)	原水	最大	48	5.5	17	189	78	4.9	52	11	6.7	6.2	2.8	44	189
		最小	1.8	2.4	2.0	2.3	3.4	1.8	1.8	1.2	1.0	1.0	1.4	2.0	1.0
		平均	7.2	3.1	3.9	20	12	3.0	7.8	2.4	1.7	2.2	1.7	9.2	6.2
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	49	6.6	14	118	45	7.4	35	6.4	5.3	5.7	2.9	14	118
		最小	3.4	3.5	3.2	5.1	5.1	3.6	4.0	2.9	2.4	2.0	2.0	3.2	2.0
		平均	7.0	4.5	5.0	14	8.8	5.3	8.0	3.7	2.7	3.1	2.4	5.6	5.8
	浄水	最大	<0.5	<0.5	<0.5	0.6	0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	0.6
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.3	7.3	7.2	7.1	7.1	7.3	7.3	7.5	7.4	7.4	7.4	7.4	7.5
		最小	6.9	7.0	7.0	6.7	7.0	7.0	7.1	7.2	7.3	7.2	7.2	7.2	6.9
		平均	7.1	7.2	7.1	6.9	7.0	7.2	7.2	7.3	7.3	7.3	7.3	7.2	7.2
	浄水	最大	7.4	7.4	7.4	7.3	7.1	7.2	7.3	7.3	7.4	7.4	7.4	7.4	7.4
		最小	7.3	7.3	7.2	7.1	7.0	7.0	7.2	7.2	7.3	7.3	7.3	7.2	7.0
		平均	7.3	7.3	7.3	7.2	7.1	7.1	7.3	7.3	7.3	7.3	7.3	7.3	7.3
アルカ度 (mg/l)	原水	最大	20.0	18.0	18.5	19.0	17.0	19.0	19.0	19.5	22.5	20.0	19.5	19.0	22.5
		最小	8.0	14.0	11.5	11.0	11.5	15.5	11.0	11.5	18.0	11.0	16.0	7.5	7.5
		平均	14.1	16.0	16.8	16.0	15.1	17.3	16.1	17.3	20.3	16.3	17.7	12.6	16.3
	浄水	最大	20.0	17.5	19.5	19.0	17.0	18.5	19.5	19.0	22.0	20.0	19.5	19.0	22.0
		最小	9.0	15.0	11.5	12.0	11.5	15.5	11.5	12.0	17.5	11.0	15.5	8.0	8.0
		平均	14.7	16.2	17.0	16.4	15.0	16.9	16.3	17.2	19.8	16.2	17.6	12.9	16.4
KMnO ₄ 消費量 (mg/l)	原水	最大	15	5.1	9.1	30	16	6.0	22	5.4	5.9	5.4	3.8	14	30
		最小	2.5	3.2	3.2	3.8	4.1	3.5	3.5	3.1	2.8	2.8	2.8	2.8	2.5
		平均	4.6	3.9	4.6	7.6	6.2	4.6	5.9	3.8	3.7	4.0	3.2	4.4	4.7
	浄水	最大	1.9	1.9	1.9	2.6	2.2	2.2	1.9	1.6	1.9	2.2	1.6	1.6	2.6
		最小	0.9	0.9	0.9	0.9	0.9	1.3	0.9	0.6	0.9	0.9	0.9	0.6	0.6
		平均	1.3	1.4	1.3	1.6	1.5	1.5	1.3	1.2	1.4	1.3	1.2	1.0	1.3
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.7	0.7	0.7	0.7	0.7	0.5	0.5	0.5	0.5	0.7	
		最小	0.4	0.4	0.5	0.5	0.6	0.6	0.5	0.5	0.5	0.4	0.4	0.4	
		平均	0.4	0.5	0.6	0.6	0.7	0.6	0.6	0.5	0.5	0.5	0.5	0.5	

尾張西部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	20.8	27.4	29.2	32.7	32.8	29.5	27.2	19.2	10.5	10.7	11.8	20.1	32.8	
	最小	8.7	15.8	17.9	24.9	24.7	20.2	14.5	6.0	2.0	-0.6	-0.9	5.7	-0.9	
	平均	15.8	21.4	22.8	28.5	28.3	24.9	18.5	12.6	6.8	4.6	5.7	11.4	16.8	
原水水温 (°C)	最大	13.9	22.1	24.4	27.1	26.1	24.5	20.8	14.0	10.2	6.9	8.3	11.8	27.1	
	最小	10.4	13.6	19.6	21.3	22.5	20.4	14.3	8.6	5.6	3.7	3.8	7.0	3.7	
	平均	12.1	17.7	22.1	24.5	24.1	22.5	17.8	11.9	7.5	5.6	6.0	9.1	15.1	
濁度 (度)	原水	最大	32	5.9	6.8	125	68	6.5	34	18	3.2	6.4	3.7	30	125
		最小	1.6	2.0	3.0	5.2	3.2	2.4	1.7	1.3	1.3	0.9	1.1	1.7	0.9
		平均	5.6	3.0	4.6	17.8	14.4	3.5	7.3	3.2	1.9	2.2	1.7	7.4	6.0
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	12	6.4	7.9	75	41	8.2	21	8.0	4.3	5.5	4.7	11	75
		最小	2.8	2.8	4.2	5.8	5.0	3.6	3.6	2.4	2.6	2.5	2.4	1.9	1.9
		平均	4.8	4.0	5.2	13.4	10.0	5.4	6.7	4.0	3.4	3.6	3.0	4.9	5.7
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.6	7.6	7.3	7.2	7.3	7.5	7.4	7.7	7.8	7.9	7.7	7.5	7.9
		最小	7.0	7.1	7.0	6.9	6.9	7.1	7.0	7.0	7.4	7.1	7.3	6.9	6.9
		平均	7.3	7.4	7.1	7.1	7.2	7.3	7.2	7.4	7.6	7.5	7.5	7.2	7.3
	浄水	最大	7.4	7.3	7.3	7.4	7.5	7.3	7.4	7.4	7.3	7.3	7.3	7.5	7.5
		最小	7.3	7.3	7.3	7.3	7.2	7.2	7.3	7.2	7.2	7.2	7.2	7.2	7.2
		平均	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3
アルカ度 (mg/l)	原水	最大	21.5	19.5	20.5	21.0	18.5	20.0	21.0	21.0	24.0	22.5	22.0	23.0	24.0
		最小	9.0	14.0	17.0	12.0	11.0	16.0	12.0	13.0	18.0	13.0	18.5	9.0	9.0
		平均	14.7	17.0	19.0	16.3	15.3	18.3	17.2	18.3	21.3	19.0	20.4	15.0	17.6
	浄水	最大	19.5	19.0	21.0	21.0	18.0	19.0	19.5	19.5	21.0	21.0	21.0	21.5	21.5
		最小	11.0	13.5	17.0	14.0	12.0	16.0	13.5	13.0	17.0	13.0	17.0	10.0	10.0
		平均	14.4	16.0	19.2	17.5	16.1	17.7	17.0	17.4	19.1	17.6	18.8	15.1	17.2
KMnO ₄ 消費量 (mg/l)	原水	最大	8.1	5.1	4.9	19	16	6.3	18	6.3	4.9	5.1	6.0	12	19
		最小	1.6	2.3	2.8	4.1	3.5	2.8	3.3	3.0	2.8	2.5	2.8	2.5	1.6
		平均	4.1	3.6	4.2	7.4	6.3	4.4	5.4	3.7	3.7	4.0	3.7	4.6	4.6
	浄水	最大	2.5	2.7	2.2	2.4	2.4	2.2	2.2	1.9	2.2	2.4	2.4	2.5	2.7
		最小	0.5	0.3	0.5	0.6	1.1	0.9	0.6	0.9	0.8	0.8	0.9	0.3	0.3
		平均	1.1	1.1	1.4	1.7	1.6	1.5	1.4	1.2	1.5	1.6	1.6	1.4	1.4
残留塩素 (mg/l)	浄水	最大	0.6	0.6	0.8	0.8	0.8	0.7	0.6	0.5	0.5	0.5	0.6	0.8	
		最小	0.4	0.4	0.6	0.7	0.6	0.6	0.5	0.4	0.4	0.4	0.4	0.4	
		平均	0.5	0.5	0.7	0.8	0.7	0.7	0.6	0.5	0.5	0.4	0.5	0.5	

豊田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.1	28.3	26.6	31.8	32.6	28.1	26.0	18.1	11.5	12.1	10.1	19.2	32.6	
	最小	7.5	16.5	19.0	25.5	22.5	19.3	13.1	6.4	1.2	-1.3	0.2	5.6	-1.3	
	平均	16.0	21.6	23.4	29.5	28.6	24.6	18.1	12.2	5.6	4.2	5.0	11.7	16.7	
原水水温 (°C)	最大	12.5	17.5	20.0	23.8	24.3	22.0	19.1	14.1	12.9	6.3	5.2	9.2	24.3	
	最小	7.5	12.5	16.1	20.0	20.5	18.6	13.0	9.0	4.5	2.6	3.3	5.0	2.6	
	平均	10.5	15.0	18.2	22.2	22.1	20.6	16.9	11.3	6.6	4.5	4.1	7.5	13.3	
濁度 (度)	原水	最大	39	3.6	9.2	110	66	5.3	98	7.2	2.8	13	2.4	49	110
		最小	1.4	1.7	1.9	1.9	1.8	1.4	1.5	1.1	0.9	0.8	1.4	1.8	0.8
		平均	5.0	2.4	3.0	7.8	10	2.2	8.2	2.3	1.3	1.9	1.8	8.1	4.5
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	17	4.3	11	50	50	6.5	88	7.0	3.8	13	3.6	37	88
		最小	2.4	2.4	1.9	4.5	4.0	3.7	3.7	2.7	1.7	2.0	2.4	3.4	1.7
		平均	4.8	3.2	4.8	8.0	9.0	4.7	8.4	3.8	2.5	3.3	3.0	7.8	5.3
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.4	7.5	7.4	7.3	7.3	7.4	7.4	7.6	7.6	7.6	7.5	7.6	
		最小	7.0	7.2	7.0	7.0	7.0	7.1	7.0	7.3	7.4	7.4	7.4	7.1	
		平均	7.3	7.3	7.3	7.2	7.2	7.2	7.3	7.4	7.5	7.5	7.5	7.3	7.3
	浄水	最大	7.4	7.4	7.5	7.5	7.5	7.5	7.4	7.5	7.5	7.5	7.5	7.4	7.5
		最小	7.3	7.3	7.2	7.3	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.2
		平均	7.3	7.3	7.3	7.3	7.4	7.4	7.3	7.4	7.4	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	18.0	20.0	21.0	20.5	20.5	20.0	20.5	22.5	22.0	21.0	20.5	20.0	22.5
		最小	13.0	15.0	18.5	12.0	13.5	17.5	12.0	15.5	19.5	18.0	17.0	13.0	12.0
		平均	15.5	17.8	19.8	19.1	16.5	18.5	18.5	20.6	20.6	19.9	18.8	15.3	18.4
	浄水	最大	17.0	18.5	21.0	20.5	20.0	19.0	20.0	21.0	20.5	19.0	18.5	18.0	21.0
		最小	13.5	13.5	16.5	15.5	12.5	17.0	14.5	15.5	18.0	17.5	15.5	13.5	12.5
		平均	14.9	16.6	18.7	18.7	16.2	17.9	17.7	19.2	18.7	18.2	17.4	15.0	17.4
KMnO ₄ 消費量 (mg/l)	原水	最大	15.6	5.5	9.8	40.0	24.7	6.1	77.8	6.2	4.0	9.9	3.7	24.4	77.8
		最小	2.3	2.7	2.2	4.6	3.4	2.8	2.8	2.2	1.2	1.5	1.7	2.2	1.2
		平均	4.9	3.9	4.5	8.0	8.1	4.0	8.2	3.6	2.7	3.0	2.7	5.8	5.0
	浄水	最大	1.7	1.2	1.7	2.0	2.2	1.5	1.9	1.6	2.1	1.2	1.5	1.6	2.2
		最小	0.1	0.1	0.3	0.6	0.5	0.1	0.5	0.3	0.3	0.1	0.3	0.5	0.1
		平均	0.8	0.7	0.8	1.3	1.0	0.9	1.0	0.9	0.8	0.6	0.6	1.0	0.9
残留塩素 (mg/l)	浄水	最大	0.6	0.6	0.6	0.7	0.8	0.7	0.7	0.6	0.6	0.6	0.6	0.6	0.8
		最小	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5
		平均	0.6	0.6	0.6	0.7	0.7	0.7	0.6	0.6	0.6	0.6	0.6	0.6	0.6

幸田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	20.8	27.5	27.8	32.3	34.0	30.6	27.4	19.5	14.1	11.4	11.3	19.4	34.0	
	最小	7.9	17.0	19.3	25.6	25.4	19.6	14.5	6.6	3.4	1.0	2.9	6.6	1.0	
	平均	16.8	22.7	24.1	30.4	30.1	25.9	19.5	13.3	7.5	5.7	6.2	12.8	17.9	
原水水温 (°C)	最大	16.0	22.0	23.0	27.5	28.0	27.0	21.5	15.5	11.5	8.0	7.5	13.5	28.0	
	最小	9.5	16.0	19.0	20.0	24.0	20.5	16.0	9.5	5.5	3.0	4.0	7.5	3.0	
	平均	13.3	18.9	21.3	26.0	26.1	23.5	18.9	12.8	7.5	5.4	5.3	10.3	15.8	
濁度 (度)	原水	最大	45	6.7	30	27	161	12	78	8.5	6.9	11	2.7	16	161
		最小	1.4	3.0	1.9	2.7	1.6	1.6	1.5	1.1	0.4	0.6	0.7	0.8	0.4
		平均	8.4	4.3	5.7	7.1	12	3.4	7.6	2.5	1.1	1.7	1.0	4.5	4.9
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	46	11	24	37	105	17	41	11	11	14	5.2	18	105
		最小	4.2	6.6	6.3	7.5	6.2	5.5	5.3	4.3	2.9	2.9	2.8	3.1	2.8
		平均	11	8.3	9.9	12	14	7.9	11	6.1	4.1	4.7	3.4	7.1	8.4
	浄水	最大	<0.5	<0.5	0.6	0.5	<0.5	0.5	0.7	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.5	7.5	7.5	7.5	7.4	7.6	7.5	7.5	7.5	7.5	7.4	7.6
		最小	7.2	7.3	7.2	7.3	7.1	7.2	7.2	7.4	7.3	7.3	7.4	7.2	7.1
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.3	7.4
	浄水	最大	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.4	7.4	7.4	7.4	7.3	7.3	7.4	7.3	7.4	7.3	7.4	7.3	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	21.0	21.5	22.5	22.0	22.5	22.0	22.0	19.5	20.5	20.5	20.5	21.0	22.5
		最小	12.0	17.0	13.5	15.5	11.5	15.5	11.0	15.5	17.0	15.0	17.5	11.0	11.0
		平均	17.1	19.2	19.6	20.2	18.9	19.9	18.6	18.4	19.6	19.1	19.7	16.1	18.9
	浄水	最大	19.5	20.5	21.5	21.5	21.0	20.5	20.5	18.5	19.5	19.0	20.0	20.0	21.5
		最小	12.5	16.5	14.0	16.5	12.0	17.0	11.0	14.0	16.5	15.0	16.5	11.5	11.0
		平均	16.3	18.5	18.9	19.6	18.1	19.4	17.7	17.3	18.5	18.1	18.8	15.7	18.1
KMnO ₄ 消費量 (mg/l)	原水	最大	20	10	27	23	22	16	23	8.3	8.4	9.3	4.0	14	27
		最小	2.8	3.8	3.7	5.9	4.9	4.4	4.7	3.5	2.1	2.7	2.4	2.7	2.1
		平均	8.0	6.6	8.3	9.7	9.3	6.8	8.2	4.7	3.5	3.8	2.9	5.7	6.5
	浄水	最大	2.2	2.2	2.3	2.3	2.1	2.2	2.2	1.8	1.9	1.9	1.3	2.4	2.4
		最小	0.9	0.9	1.2	0.9	0.5	1.0	1.3	0.8	0.8	0.6	0.6	0.6	0.5
		平均	1.4	1.5	1.6	1.5	1.5	1.5	1.7	1.2	1.2	1.1	1.0	1.3	1.4
残留塩素 (mg/l)	浄水	最大	0.7	0.7	0.9	1.0	1.1	0.9	0.9	0.8	0.6	0.5	0.6	0.6	1.1
		最小	0.5	0.5	0.6	0.8	0.8	0.7	0.8	0.5	0.5	0.4	0.5	0.5	0.4
		平均	0.6	0.6	0.8	0.9	0.9	0.8	0.8	0.6	0.5	0.5	0.5	0.5	0.7

豊橋浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.0	27.0	28.0	33.0	33.0	30.0	25.0	19.0	12.0	12.0	11.0	19.5	33.0	
	最小	11.0	18.0	20.0	25.0	27.0	21.0	15.0	8.0	4.0	0.5	2.0	5.5	0.5	
	平均	17.1	22.9	24.5	30.7	30.4	26.0	20.3	14.2	8.0	5.9	6.2	13.1	18.3	
原水水温 (°C)	最大	16.0	23.0	23.5	28.0	28.5	26.5	22.0	15.5	10.0	8.0	8.0	14.5	28.5	
	最小	10.0	16.5	18.5	22.0	23.5	21.5	14.5	9.0	5.0	2.5	3.5	8.0	2.5	
	平均	13.5	19.6	21.5	25.7	26.1	23.7	18.7	12.3	6.6	5.0	5.2	10.8	15.7	
濁度 (度)	原水	最大	7.7	3.9	3.5	8.5	21	5.3	28	4.2	11	16	1.3	38	38
		最小	1.1	1.2	1.3	1.7	1.9	1.5	1.5	0.7	0.4	0.7	1.2	1.2	0.4
		平均	2.6	2.2	3.9	3.1	4.1	2.6	5.6	1.9	1.3	1.8	1.0	3.8	2.8
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	15	10	29	15	28	15	50	8.0	13	16	2.7	32	50
		最小	2.6	2.8	4.3	5.0	4.8	4.3	4.4	2.7	1.8	1.7	1.9	3.0	1.7
		平均	5.1	5.1	6.3	7.6	7.9	6.8	10	4.0	3.6	4.0	2.3	6.5	5.8
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.7	7.5	7.4	7.4	7.4	7.7	7.7	8.0	7.8	7.6	7.5	8.0
		最小	7.1	7.3	7.0	7.2	7.2	7.2	7.2	7.3	7.4	7.4	7.2	7.4	7.2
		平均	7.4	7.4	7.3	7.3	7.3	7.3	7.4	7.5	7.7	7.5	7.5	7.3	7.4
	浄水	最大	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	24.0	25.5	30.0	26.5	29.0	27.5	29.0	26.0	27.0	25.5	26.0	25.0	30.0
		最小	11.0	22.0	11.5	16.0	14.0	19.0	16.0	18.0	19.0	13.5	22.0	12.0	11.0
		平均	18.8	23.7	25.1	23.9	23.2	25.6	23.1	23.1	24.9	22.3	24.0	18.3	23.0
	浄水	最大	22.0	23.0	25.5	24.0	25.5	24.5	24.0	23.0	24.0	23.5	24.0	23.0	25.5
		最小	11.0	19.5	11.5	14.0	11.5	17.0	15.0	16.0	18.0	15.0	21.0	10.0	10.0
		平均	17.8	21.4	22.3	21.4	20.2	22.4	20.1	20.7	21.9	20.6	22.2	17.0	20.7
KMnO ₄ 消費量 (mg/l)	原水	最大	10	9.1	17	12	16	13	21	6.5	8.5	8.3	2.8	10	21
		最小	2.5	2.2	3.5	3.8	3.7	3.8	3.4	2.8	1.8	1.7	1.9	2.5	1.7
		平均	4.5	4.4	5.4	5.9	5.7	5.6	6.2	3.6	3.5	3.3	2.4	4.8	4.6
	浄水	最大	1.6	1.6	1.6	1.6	1.2	1.9	1.9	1.5	1.6	1.3	0.9	1.6	1.9
		最小	0.9	0.6	0.9	0.6	0.6	0.9	0.9	0.6	0.9	0.2	0.6	0.9	0.2
		平均	1.1	1.0	1.2	1.1	0.9	1.2	1.2	1.0	1.2	0.7	0.8	1.0	1.0
残留塩素 (mg/l)	浄水	最大	0.5	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.6	
		最小	0.4	0.5	0.5	0.5	0.6	0.5	0.5	0.4	0.4	0.4	0.4	0.4	
		平均	0.5	0.5	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	

豊橋南部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	20.6	25.9	26.3	31.6	32.8	28.8	26.7	18.4	11.6	13.0	9.7	18.4	32.8	
	最小	7.8	16.1	18.9	25.5	25.0	19.1	14.1	7.5	4.4	0.2	1.3	5.4	0.2	
	平均	16.0	21.6	23.2	29.2	29.3	25.4	19.6	13.5	7.5	5.7	5.6	12.2	17.4	
原水水温 (°C)	最大	13.5	17.5	20.7	23.7	25.5	25.0	22.8	18.0	13.1	8.5	7.0	11.6	25.5	
	最小	9.6	13.0	17.2	20.6	23.6	22.5	17.5	12.7	8.5	5.5	5.5	7.6	5.5	
	平均	12.0	15.4	19.4	22.2	24.8	24.0	20.9	15.6	10.3	7.4	6.0	9.9	15.7	
濁度 (度)	原水	最大	4.3	1.9	5.5	7.1	4.1	8.9	17	2.6	2.3	3.1	1.7	10.2	17
		最小	0.9	1.1	1.5	1.4	0.8	0.8	0.7	1.1	0.7	1.1	1.0	1.3	0.7
		平均	1.5	1.4	2.7	3.0	1.4	1.5	2.8	1.6	1.4	1.5	1.3	2.3	1.9
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	7.5	5.1	6.4	10	9.3	9.7	14	6.6	5.5	14	3.6	9.4	14
		最小	3.4	3.8	3.1	2.3	4.5	4.3	4.4	3.5	3.8	3.2	2.9	3.3	2.3
		平均	4.7	4.4	3.9	4.6	5.4	5.6	6.1	4.7	4.7	4.3	3.4	4.4	4.7
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.7	7.5	8.2	7.9	7.7	7.4	7.6	7.7	7.7	7.7	7.6	7.6	8.2
		最小	7.3	7.2	7.4	7.6	7.3	7.2	7.2	7.4	7.4	7.3	7.4	7.4	7.2
		平均	7.5	7.4	7.8	7.7	7.5	7.3	7.4	7.6	7.6	7.6	7.5	7.5	7.5
	浄水	最大	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.4	7.4	7.5	7.4	7.5	7.5
		最小	7.4	7.4	7.4	7.3	7.4	7.4	7.3	7.3	7.4	7.3	7.4	7.3	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	21.5	19.0	30.5	27.0	25.0	20.5	22.0	21.0	23.0	22.0	22.0	19.5	30.5
		最小	14.0	15.0	17.0	18.0	17.0	16.0	16.5	17.0	18.0	11.0	18.5	14.0	11.0
		平均	18.4	17.1	23.7	22.5	18.8	18.3	19.1	19.5	19.7	18.7	19.8	17.3	19.4
	浄水	最大	20.0	18.0	25.0	23.0	21.0	19.0	19.0	19.5	20.0	20.5	21.0	18.0	25.0
		最小	14.0	14.0	15.5	15.5	13.5	15.0	15.0	16.0	16.5	15.0	17.5	14.0	13.5
		平均	17.1	16.1	19.9	19.5	16.8	16.7	17.2	17.5	17.7	17.6	18.7	16.0	17.6
KMnO ₄ 消費量 (mg/l)	原水	最大	9.1	7.4	8.4	11	7.0	10	8.8	6.3	6.1	12	6.0	7.9	12
		最小	4.1	4.4	3.0	4.2	3.4	4.8	4.5	3.5	3.4	4.1	4.1	3.2	3.0
		平均	5.1	5.4	4.7	5.5	5.1	5.9	5.9	4.6	4.9	5.0	4.8	5.1	5.2
	浄水	最大	1.3	1.6	1.3	1.2	1.2	1.5	1.5	1.2	1.3	1.3	1.6	2.2	2.2
		最小	0.6	0.3	0.3	0.3	0.3	0.3	0.6	0.3	0.3	0.6	0.6	0.6	0.3
		平均	1.0	0.9	0.6	0.9	0.6	0.9	1.2	0.8	0.9	0.9	1.1	1.2	0.9
残留塩素 (mg/l)	浄水	最大	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.6	
		最小	0.5	0.5	0.5	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.4	0.4	
		平均	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	

豊川浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.5	29.2	28.3	33.3	34.2	31.7	27.3	19.1	11.9	11.9	11.3	21.1	34.2	
	最小	7.9	16.2	18.6	24.8	25.5	19.5	14.4	7.0	2.7	-0.3	1.6	6.2	-0.3	
	平均	17.4	23.5	24.5	30.7	30.5	26.3	19.5	13.5	7.3	5.4	6.4	13.9	18.2	
原水水温 (°C)	最大	17.0	20.0	22.5	26.1	26.5	25.3	22.1	17.5	12.2	8.6	8.9	14.5	26.5	
	最小	11.5	17.5	19.0	22.5	21.3	22.5	16.8	12.0	8.0	6.0	6.1	8.9	6.0	
	平均	14.9	18.9	20.5	24.8	25.2	23.6	19.9	14.4	9.5	7.4	7.1	11.9	16.5	
濁度 (度)	原水	最大	7.6	4.9	5.8	4.3	3.1	2.5	9.7	4.4	2.8	2.1	3.4	4.8	9.7
		最小	1.2	1.1	1.0	1.4	1.3	1.1	1.0	1.3	1.2	1.2	1.0	1.3	1.0
		平均	2.9	1.8	1.9	2.7	2.1	1.7	2.9	2.4	1.9	1.6	1.4	2.4	2.1
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	9.3	8.5	9.4	11	9.6	9.5	14	9.2	6.0	5.9	4.0	8.9	14
		最小	3.7	5.1	3.3	4.7	5.8	6.0	4.9	4.2	4.8	3.6	1.5	3.3	1.5
		平均	6.0	6.1	4.9	7.1	7.4	7.2	7.9	5.8	5.4	4.9	3.6	5.8	6.0
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.4	7.9	7.8	7.6	7.3	7.3	7.5	7.5	7.5	7.7	7.5	7.9
		最小	7.2	7.1	7.2	7.3	7.1	7.1	7.1	7.1	7.1	7.3	7.3	7.4	7.2
		平均	7.4	7.3	7.5	7.5	7.3	7.2	7.2	7.3	7.4	7.4	7.6	7.4	7.4
	浄水	最大	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.2	7.3	7.3	7.3	6.9	7.4	7.3	7.3	7.3	7.4	7.3	7.3	6.9
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
アルカリ度 (mg/l)	原水	最大	22.5	17.0	36.0	32.0	27.5	18.0	21.5	21.5	25.0	20.0	21.5	19.0	36.0
		最小	15.0	13.0	13.0	20.0	14.5	14.0	15.0	14.5	16.5	15.5	17.5	13.0	13.0
		平均	17.5	14.5	26.5	25.3	17.2	16.0	17.8	19.0	19.8	18.1	19.6	15.8	18.9
	浄水	最大	23.0	16.0	32.5	30.5	27.0	18.5	21.5	21.5	21.0	20.0	21.5	18.0	32.5
		最小	14.5	12.5	14.0	19.5	15.0	15.5	16.0	15.5	18.0	15.5	17.0	13.0	12.5
		平均	17.2	14.5	25.1	24.5	17.7	16.8	18.4	18.9	19.5	18.0	18.9	15.9	18.8
KMnO ₄ 消費量 (mg/l)	原水	最大	6.7	6.5	6.1	7.4	8.8	8.6	7.2	6.0	5.3	5.6	4.4	7.8	8.8
		最小	3.0	3.3	2.1	3.2	3.2	4.3	2.1	3.0	3.9	3.2	3.2	3.6	2.1
		平均	4.4	5.4	3.4	4.8	5.3	6.1	5.2	4.3	4.5	4.4	3.8	5.0	4.7
	浄水	最大	1.5	2.2	1.8	1.8	1.8	1.5	1.5	1.8	1.5	1.7	1.5	1.8	2.2
		最小	0.3	0.3	0.3	0.3	0.2	0.6	0.6	0.6	0.6	0.8	0.5	0.6	0.2
		平均	1.0	1.1	0.9	0.8	1.0	1.1	1.2	1.2	1.2	1.2	1.0	1.2	1.1
残留塩素 (mg/l)	最大	0.5	0.6	0.6	0.7	0.7	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.7	
	最小	0.4	0.5	0.5	0.5	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.4	
	平均	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	

(2)工業用水毎日検査

尾張東部浄水場(東郷)

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.0	27.0	28.0	32.0	34.0	29.0	29.0	23.0	15.0	10.0	11.0	21.0	34.0	
	最小	6.0	17.0	17.0	22.0	23.5	16.0	11.0	4.0	0.0	0.0	0.0	4.0	0.0	
	平均	15.4	21.7	22.7	28.5	28.7	24.4	17.4	13.0	7.1	4.9	6.5	12.2	16.9	
原水水温 (°C)	最大	14.7	18.8	21.5	25.0	25.1	23.8	20.5	16.0	10.1	6.7	6.0	10.1	25.1	
	最小	9.3	13.8	19.1	21.4	23.5	20.6	15.0	10.0	5.6	4.7	4.2	6.4	4.2	
	平均	11.9	16.5	20.1	23.2	24.1	22.4	18.4	12.7	7.7	5.2	4.8	8.4	14.6	
濁度 (度)	原水	最大	8.0	4.0	7.0	8.2	5.2	10	11	14	2.0	2.0	2.0	7.0	8.2
		最小	2.0	1.0	2.0	1.0	3.0	3.0	3.0	2.0	1.0	1.0	1.0	1.0	1.0
		平均	3.0	3.0	2.0	11.0	11.0	6.0	6.0	4.0	1.0	1.0	1.0	3.0	4.3
	配水	最大	5.0	3.0	2.0	9.0	6.0	6.0	8.0	9.0	2.0	2.0	2.0	6.0	9.0
		最小	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		平均	2.0	1.0	1.0	2.0	3.0	3.0	3.0	2.0	1.0	1.0	1.0	3.0	1.9
pH値	原水	最大	8.0	7.5	7.6	7.5	7.5	7.7	7.7	7.8	7.7	7.6	7.6	7.6	8.0
		最小	7.2	7.3	7.2	7.0	7.1	7.3	7.2	7.3	7.5	7.4	7.4	7.3	7.0
		平均	7.4	7.4	7.4	7.3	7.3	7.5	7.4	7.5	7.6	7.5	7.6	7.4	7.4
	配水	最大	7.4	7.4	7.4	7.4	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.2	7.3	7.2	7.0	7.0	7.2	7.1	6.9	7.3	7.3	7.4	7.3	6.9
		平均	7.3	7.3	7.3	7.2	7.2	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.3
アルカ度 (mg/l)	原水	最大	19.0	16.5	18.5	18.5	16.0	18.0	18.5	18.0	20.0	19.5	18.5	19.5	20.0
		最小	13.0	14.0	16.0	15.0	13.0	15.5	14.5	13.5	17.0	15.0	15.5	13.0	13.0
		平均	15.9	15.4	17.2	16.6	14.7	16.7	17.0	16.2	18.6	17.8	16.8	15.5	16.5
	配水	最大	17.5	15.5	18.0	18.0	15.0	17.0	18.0	17.0	19.0	19.0	17.5	18.0	19.0
		最小	12.5	13.0	15.5	13.0	12.0	14.5	13.5	13.0	16.0	14.5	15.0	13.0	12.0
		平均	15.1	14.7	16.6	15.8	13.5	15.9	16.4	15.4	17.8	17.3	16.2	15.2	15.8

上野浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	20.5	26.5	26.5	31.5	32.5	28.0	25.0	18.5	12.5	11.0	10.0	18.0	32.5	
	最小	8.0	16.0	18.0	25.5	24.5	20.0	14.0	7.0	2.5	-0.5	1.5	6.5	-0.5	
	平均	16.0	21.5	23.2	29.4	29.2	25.1	18.6	12.7	6.7	4.9	5.3	11.7	17.0	
原水水温 (°C)	最大	15.5	19.5	22.0	26.0	25.5	24.5	21.0	15.5	10.5	6.0	6.0	11.0	26.0	
	最小	9.5	14.5	19.5	22.0	24.0	21.0	15.5	10.5	6.0	4.5	4.0	6.5	4.0	
	平均	12.4	17.1	20.7	24.1	24.7	22.8	18.7	12.8	7.8	5.3	5.0	8.7	15.0	
濁度 (度)	原水	最大	9.8	5.7	4.3	9.5	6.6	8.6	7.6	9.3	2.9	3.1	1.9	7.4	9.5
		最小	4.1	2.3	1.7	1.5	4.7	3.5	2.7	1.9	1.3	1.2	1.4	1.6	1.2
		平均	5.9	4.1	3.0	10.4	14.6	5.4	4.4	3.7	2.0	1.7	1.6	4.5	5.1
	配水	最大	4.8	3.4	1.8	3.6	5.0	3.4	4.7	6.4	1.9	1.6	1.2	3.7	6.4
		最小	1.2	0.7	0.7	0.8	0.6	1.3	1.3	1.2	0.9	0.7	0.8	0.8	0.6
		平均	2.8	1.9	1.0	1.8	2.2	2.2	2.5	1.3	1.1	1.0	2.2	1.9	
pH値	原水	最大	7.7	7.5	7.4	7.4	7.5	7.5	7.5	7.7	7.6	7.6	7.6	7.6	7.7
		最小	7.3	7.3	7.3	7.1	7.1	7.2	7.3	7.3	7.5	7.4	7.4	7.2	7.1
		平均	7.5	7.4	7.3	7.2	7.2	7.4	7.4	7.5	7.6	7.5	7.5	7.4	7.4
	配水	最大	7.3	7.2	7.2	7.2	7.2	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3
		最小	7.1	7.1	7.1	6.9	6.8	7.1	7.1	7.1	7.2	7.2	7.2	7.2	6.8
		平均	7.2	7.2	7.2	7.1	7.0	7.2	7.2	7.2	7.2	7.3	7.3	7.2	7.2
アルカ度 (mg/l)	原水	最大	18.0	16.0	17.5	18.0	16.0	17.5	18.0	17.5	20.0	19.5	18.0	19.5	20.0
		最小	12.5	13.0	15.5	14.5	13.0	15.0	14.5	14.0	17.0	15.5	15.5	13.5	12.5
		平均	15.1	14.6	16.5	16.1	14.3	16.2	16.5	15.8	18.4	17.7	16.7	15.9	16.2
	配水	最大	16.5	15.0	16.5	17.0	14.5	16.5	17.0	16.0	18.0	18.0	16.5	17.5	18.0
		最小	11.5	12.5	15.0	11.0	9.5	14.0	13.5	13.0	15.5	14.0	13.5	12.0	9.5
		平均	14.0	13.7	15.9	14.7	11.9	15.3	15.6	14.6	16.5	15.8	14.8	14.4	14.8

知多浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.0	28.0	28.0	33.0	34.0	34.0	25.0	18.5	11.0	9.0	10.0	21.0	34.0	
	最小	7.0	16.0	19.0	26.0	25.0	25.0	13.0	7.0	3.0	0.0	1.0	0.0	0.0	
	平均	15.7	22.1	24.0	30.4	30.2	30.2	18.5	12.4	6.2	3.9	4.4	10.3	17.4	
原水水温 (°C)	最大	16.0	21.5	23.5	27.5	27.5	27.5	23.0	16.8	12.5	7.3	7.0	12.0	27.5	
	最小	10.0	15.5	20.5	23.0	25.0	25.0	16.0	11.0	6.0	5.0	5.0	7.0	5.0	
	平均	12.5	18.1	21.8	25.7	26.5	26.5	19.7	13.9	8.7	6.0	5.6	9.2	16.2	
濁度 (度)	原水	最大	6.5	7.8	4.1	17	16	7.1	6.7	6.0	3.4	5.8	2.6	4.5	17
		最小	4.1	1.8	2.4	2.3	4.9	4.0	3.1	3.2	1.9	1.6	1.7	1.8	1.6
		平均	5.3	3.9	2.8	4.0	7.1	5.3	4.7	4.5	2.7	2.2	2.1	3.2	4.0
	配水	最大	4.4	5.4	4.0	7.4	8.1	9.2	5.9	4.6	1.6	3.3	2.5	4.4	9.2
		最小	0.4	0.3	1.3	0.7	0.8	2.4	1.1	0.4	0.4	0.2	0.7	1.4	0.2
		平均	2.0	3.3	3.2	3.0	4.1	5.2	4.2	2.0	0.9	0.9	1.7	2.9	2.8
pH値	原水	最大	7.7	7.4	7.2	7.1	7.2	7.7	7.4	8.1	8.1	7.7	7.5	7.5	8.1
		最小	7.3	6.9	7.1	7.0	6.9	7.1	7.1	7.4	7.5	7.4	7.4	7.3	6.9
		平均	7.5	7.2	7.2	7.0	7.1	7.3	7.3	7.7	7.8	7.6	7.5	7.4	7.4
	配水	最大	7.5	7.4	7.4	7.1	7.2	7.4	7.4	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.2	7.1	7.1	6.9	6.8	7.1	7.1	7.3	7.2	7.2	7.3	7.3	6.8
		平均	7.3	7.3	7.2	7.0	7.0	7.3	7.3	7.4	7.4	7.4	7.5	7.4	7.3
アルカ度 (mg/l)	原水	最大	18.5	17.0	18.5	18.0	17.5	23.5	19.5	18.0	20.0	20.5	19.0	19.5	23.5
		最小	15.5	14.5	16.0	16.0	14.5	15.5	16.0	15.0	17.0	17.5	16.5	15.5	14.5
		平均	17.4	15.8	17.0	17.2	16.0	17.1	17.5	16.5	18.6	19.4	17.3	17.6	17.3
	配水	最大	18.0	18.0	30.0	21.5	19.0	18.0	27.0	17.0	19.0	19.5	21.0	19.5	30.0
		最小	14.5	13.5	16.0	16.0	13.5	15.5	16.5	14.5	15.0	16.0	16.0	15.0	13.5
		平均	16.2	15.9	17.9	17.4	16.0	16.8	18.2	15.7	16.9	18.0	17.4	17.6	17.0

尾張西部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	20.8	27.4	29.2	32.7	32.8	29.5	27.2	19.2	10.5	10.7	11.8	20.1	32.8	
	最小	8.7	15.8	17.9	24.9	24.7	20.2	14.5	6.0	2.0	-0.6	-0.9	5.7	-0.9	
	平均	15.8	21.4	22.8	28.5	28.3	24.9	18.5	12.6	6.8	4.6	5.7	11.4	16.8	
原水水温 (°C)	最大	14.1	21.5	24.3	27.8	26.1	24.4	20.5	14.3	10.0	6.6	7.6	11.7	27.8	
	最小	10.0	14.3	20.2	20.5	22.8	20.0	14.2	9.5	5.7	4.5	4.0	7.4	4.0	
	平均	12.4	17.5	21.9	24.8	24.1	22.3	17.8	11.9	7.4	5.5	5.5	9.0	15.0	
濁度 (度)	原水	最大	30	4.0	5.6	188	52	6.2	25	20	3.2	4.4	1.3	25	188
		最小	1.5	1.1	1.7	3.0	2.0	1.9	1.3	1.4	1.0	0.8	0.7	0.9	0.7
		平均	5.5	2.5	3.2	17.4	13.2	2.6	5.1	3.3	1.6	1.5	0.9	5.6	5.2
	配水	最大	0.7	0.5	0.6	0.7	0.7	0.4	0.3	0.2	0.3	0.4	0.4	0.8	0.8
		最小	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.1
		平均	0.5	0.3	0.3	0.3	0.3	0.2	0.2	0.2	0.2	0.2	0.2	0.5	0.3
pH値	原水	最大	7.5	7.6	7.2	7.1	7.3	7.4	7.3	7.5	7.8	7.8	7.5	7.4	7.8
		最小	6.8	7.1	6.9	6.8	6.9	7.0	7.0	7.1	7.4	7.1	7.4	6.9	6.8
		平均	7.1	7.3	7.1	7.0	7.1	7.2	7.2	7.3	7.6	7.4	7.4	7.1	7.6
	配水	最大	7.3	7.3	7.3	7.2	7.2	7.3	7.3	7.3	7.4	7.4	7.3	7.3	7.4
		最小	7.0	7.1	7.0	7.0	7.0	7.1	7.1	7.1	7.2	7.0	0.2	7.0	0.2
		平均	7.2	7.2	7.1	7.1	7.1	7.2	7.2	7.2	7.3	7.2	7.0	7.1	7.2
アルカリ度 (mg/l)	原水	最大	25.0	21.0	22.5	21.0	19.0	22.0	21.5	24.5	26.0	23.5	25.0	25.0	26.0
		最小	10.5	15.5	19.0	13.0	9.5	17.5	12.5	14.0	20.0	14.5	19.0	11.0	9.5
		平均	16.4	18.1	20.5	17.3	15.7	19.6	18.6	20.8	23.0	20.2	21.8	17.2	19.1
	配水	最大	21.0	17.0	20.5	20.5	18.0	21.0	21.0	21.5	20.5	20.5	20.0	20.0	21.5
		最小	10.5	13.0	14.5	13.0	11.0	15.0	11.0	12.0	17.0	12.0	16.0	10.0	10.0
		平均	15.0	15.4	18.7	16.6	14.5	17.0	16.6	17.4	18.8	17.2	18.1	14.4	16.6

安城浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.2	28.8	29.0	33.1	34.4	29.6	27.6	20.3	14.5	11.4	12.0	20.9	34.4	
	最小	8.6	16.4	19.1	25.8	25.2	20.0	14.6	6.8	3.8	0.7	3.2	6.7	0.7	
	平均	17.2	23.0	24.6	30.8	30.3	26.2	19.3	13.9	7.8	5.7	6.7	13.3	18.2	
原水水温 (°C)	最大	15.3	21.0	22.8	27.5	27.8	25.0	20.7	14.2	10.0	6.7	6.8	12.4	27.8	
	最小	10.1	14.7	19.1	21.6	22.8	20.5	14.8	9.5	5.5	3.1	3.8	7.0	3.1	
	平均	12.6	17.9	21.1	25.7	24.5	22.8	18.1	12.0	7.0	4.9	4.8	9.5	15.1	
濁度 (度)	原水	最大	30	7.0	8.0	176	153	7.0	77	17	38	29	3.0	30	176
		最小	2.0	3.0	2.0	3.0	2.0	2.0	1.0	3.0	1.0	1.0	1.0	2.0	1.0
		平均	7.0	5.0	4.0	14	18	4.0	10	6.0	3.0	4.0	2.0	9.0	7.2
	配水	最大	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		最小	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		平均	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
pH値	原水	最大	7.6	7.4	7.4	7.3	7.4	7.6	7.4	7.7	7.5	7.6	7.5	7.4	7.7
		最小	7.1	7.2	7.0	6.8	7.0	7.2	7.1	7.2	7.3	7.3	7.3	7.1	6.8
		平均	7.3	7.3	7.3	7.1	7.2	7.4	7.3	7.4	7.4	7.4	7.4	7.3	7.3
	配水	最大	7.1	7.1	7.1	6.8	7.0	7.0	7.0	7.2	7.2	7.3	7.2	7.2	7.3
		最小	6.8	6.9	6.8	6.6	6.7	6.8	6.8	6.9	7.0	7.0	7.0	6.9	6.6
		平均	7.0	7.0	7.0	6.7	6.8	6.9	6.9	7.0	7.1	7.2	7.1	7.1	7.0
アルカリ度 (mg/l)	原水	最大	26.0	23.0	24.0	23.0	25.5	23.0	24.0	23.5	25.0	24.0	24.0	26.0	26.0
		最小	15.0	18.5	21.5	15.5	14.0	20.0	15.5	18.0	19.0	20.5	22.0	16.0	14.0
		平均	19.9	20.8	22.5	21.8	19.7	21.9	21.5	21.6	23.5	23.1	22.8	19.9	21.6
	配水	最大	21.5	18.0	19.0	18.0	20.0	19.5	19.0	20.0	21.5	20.5	19.5	20.0	21.5
		最小	12.0	14.0	17.5	13.0	11.5	15.0	14.0	15.0	18.0	17.0	18.0	15.0	11.5
		平均	16.4	16.8	18.5	16.2	15.1	17.3	17.0	17.7	19.3	19.0	18.8	17.0	17.4

豊橋南部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	20.6	25.9	26.3	31.6	32.8	28.8	26.7	18.4	11.6	13.0	9.7	18.4	32.8	
	最小	7.8	16.1	18.9	25.5	25.0	19.1	14.1	7.5	4.4	0.2	1.3	5.4	0.2	
	平均	16.0	21.6	23.2	29.2	29.3	25.4	19.6	13.5	7.5	5.7	5.6	12.2	17.4	
原水水温 (°C)	最大	13.5	17.5	20.7	23.7	25.5	25.0	22.8	18.0	13.1	8.5	7.0	11.6	25.5	
	最小	9.6	13.0	17.2	20.6	23.6	22.5	17.5	12.7	8.5	5.5	5.5	7.6	5.5	
	平均	12.0	15.4	19.4	22.2	24.8	24.0	20.9	15.6	10.3	7.4	6.0	9.9	15.7	
濁度 (度)	原水	最大	4.3	1.9	5.5	7.1	4.1	8.9	17	2.6	2.3	3.1	1.7	10	17
		最小	0.9	1.1	1.5	1.4	0.8	0.8	0.7	1.1	0.7	1.1	1.0	1.3	0.7
		平均	1.5	1.4	2.7	3.0	1.4	1.5	2.8	1.6	1.4	1.5	1.3	2.3	1.9
	配水	最大	0.2	0.3	0.2	0.3	0.2	0.3	0.2	0.2	0.3	0.4	0.1	0.3	0.4
		最小	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.1	0.1	0.0	0.0	0.0	0.0
		平均	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.1	0.1	0.1
pH値	原水	最大	7.7	7.5	8.2	7.9	7.7	7.4	7.6	7.7	7.7	7.7	7.6	7.6	8.2
		最小	7.3	7.2	7.4	7.6	7.3	7.2	7.2	7.4	7.4	7.3	7.4	7.4	7.2
		平均	7.5	7.4	7.8	7.7	7.5	7.3	7.4	7.6	7.6	7.6	7.5	7.5	7.5
	配水	最大	7.2	7.1	7.2	7.2	7.2	7.2	7.2	7.1	7.2	7.2	7.2	7.2	7.2
		最小	7.0	6.9	7.0	6.9	6.9	6.9	6.9	7.0	7.0	6.9	7.0	6.9	6.9
		平均	7.1	7.0	7.1	7.1	7.0	7.0	7.1	7.1	7.1	7.1	7.0	7.0	7.1
アルカリ度 (mg/l)	原水	最大	21.5	19.0	30.5	27.0	25.0	20.5	22.0	21.0	23.0	22.0	22.0	19.5	30.5
		最小	14.0	15.0	17.0	18.0	17.0	16.0	16.5	17.0	18.0	11.0	18.5	14.0	11.0
		平均	18.4	17.1	23.7	22.5	18.8	18.3	19.1	19.5	19.7	18.7	19.8	17.3	19.4
	配水	最大	17.5	15.0	22.5	21.0	18.0	16.0	16.0	16.0	16.5	17.5	17.5	15.0	22.5
		最小	11.0	10.5	12.0	13.0	11.5	12.0	11.5	12.0	14.0	11.0	14.0	11.0	10.5
		平均	14.1	13.0	16.8	16.6	13.6	13.8	14.2	14.4	14.9	14.5	15.1	13.0	14.5

蒲郡浄水場(工水)

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	20.0	25.5	26.0	31.0	32.0	28.5	26.5	20.0	14.0	13.0	12.0	19.5	32.0	
	最小	10.0	18.0	19.5	26.0	26.0	21.0	14.5	9.0	5.0	2.0	4.0	9.0	2.0	
	平均	16.2	21.6	23.1	28.9	28.9	25.2	19.6	14.4	9.2	7.1	7.5	13.2	17.9	
原水水温 (°C)	最大	15.1	18.4	20.0	24.3	24.6	24.3	22.0	17.5	13.0	10.4	8.8	13.0	24.6	
	最小	11.0	15.2	17.2	20.5	23.1	20.6	17.0	12.6	9.1	6.6	6.4	8.5	6.4	
	平均	13.2	16.3	18.8	22.7	23.9	22.4	19.5	14.9	10.7	8.4	7.5	10.9	15.8	
濁度 (度)	原水	最大	3.3	3.7	4.5	7.8	5.6	2.7	7.4	1.5	3.4	0.9	5.9	3.0	7.8
		最小	0.4	0.4	0.6	0.6	0.8	0.4	0.4	0.3	0.3	0.3	0.2	0.5	0.2
		平均	1.3	1.1	1.5	1.7	1.8	1.1	1.3	0.6	0.6	0.5	0.8	1.5	1.2
	配水	最大	0.2	0.4	0.5	0.2	0.6	0.3	0.4	0.3	0.2	0.3	0.2	0.6	0.6
		最小	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
		平均	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.3	0.1
pH値	原水	最大	7.5	7.4	7.6	7.5	7.5	7.4	7.4	7.4	7.4	7.4	7.5	7.4	7.6
		最小	7.3	7.2	7.2	7.3	7.2	7.1	7.3	7.2	7.3	7.3	7.4	7.2	7.1
		平均	7.3	7.3	7.4	7.4	7.3	7.3	7.4	7.3	7.4	7.4	7.4	7.3	7.4
	配水	最大	7.3	7.3	7.4	7.4	7.3	7.3	7.4	7.3	7.3	7.3	7.3	7.4	7.4
		最小	7.1	7.1	7.2	7.1	7.1	7.0	7.1	7.1	7.1	7.1	7.2	7.2	7.0
		平均	7.2	7.3	7.3	7.3	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.3	7.2
アルカリ度 (mg/l)	原水	最大	26.0	23.0	37.0	33.0	30.0	25.0	29.0	28.0	27.0	27.0	24.0	37.0	
		最小	19.0	18.0	17.0	24.0	18.0	18.0	21.0	21.0	22.0	19.0	21.0	17.0	17.0
		平均	21.8	20.5	27.9	28.0	20.9	19.8	23.2	23.6	23.6	22.5	22.6	19.7	22.8
	配水	最大	23.0	20.0	31.0	30.0	27.0	21.0	23.0	23.0	22.0	22.0	21.0	20.0	31.0
		最小	17.0	17.0	15.0	21.0	16.0	15.0	19.0	19.0	18.0	17.0	18.0	16.0	15.0
		平均	19.7	18.7	24.3	25.1	19.0	17.5	20.7	21.1	20.4	19.3	19.9	17.6	20.3