

## 6 浄水場毎日検査

### (1)水道用水毎日検査

高蔵寺浄水場	202	豊田浄水場	205
尾張東部浄水場	202	幸田浄水場	205
上野浄水場	203	豊橋浄水場	206
知多浄水場	203	豊橋南部浄水場	206
犬山浄水場	204	豊川浄水場	207
尾張西部浄水場	204		

### (2)工業用水毎日検査

尾張東部浄水場(東郷)	208
上野浄水場	208
知多浄水場	208
尾張西部浄水場	209
安城浄水場	209
豊橋南部浄水場	209
蒲郡浄水場(工水)	210

# (1)水道用水毎日検査

## 高蔵寺浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.8	27.9	29.7	35.9	35.5	29.5	26.5	20.4	17.7	8.3	14.3	17.1	35.9	
	最小	8.2	16.4	18.3	23.7	27.2	18.0	15.8	11.4	1.0	0.8	3.2	6.7	0.8	
	平均	18.3	21.6	24.6	30.8	31.6	24.6	20.8	15.9	9.1	6.0	8.4	11.6	18.6	
原水水温 (°C)	最大	14.5	18.3	21.0	25.3	26.8	23.5	19.2	15.0	11.8	7.1	8.0	10.7	26.8	
	最小	10.4	13.5	17.8	18.3	21.8	18.1	15.2	11.3	7.0	5.0	5.2	7.9	5.0	
	平均	12.7	15.8	19.7	22.4	24.7	20.1	17.3	13.7	9.3	5.9	6.5	9.4	14.8	
濁度 (度)	原水	最大	83	30	317	235	905	391	92	2.9	5.2	2.6	3.8	4.1	905
		最小	3.0	4.0	2.6	5.9	2.4	3.3	1.8	1.9	1.5	1.1	1.9	2.1	1.1
		平均	11	8.5	15	33	72	33	9.6	2.4	2.5	1.7	2.5	2.9	16
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	35	17	41	80	291	149	33	5.0	7.0	3.0	4.0	5.0	291
		最小	3.0	4.0	4.0	5.0	4.0	4.0	2.0	3.0	2.0	2.0	2.0	3.0	2.0
		平均	6.9	6.5	6.2	14	28	15	5.5	3.6	3.6	2.3	3.1	3.4	8.2
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.3	7.3	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.4	7.3	7.4	
		最小	6.9	7.0	6.7	6.7	6.7	7.0	7.1	7.3	7.2	7.2	7.2	7.2	6.7
		平均	7.2	7.2	7.2	7.1	7.1	7.2	7.3	7.3	7.3	7.3	7.3	7.2	7.2
	浄水	最大	7.4	7.4	7.3	7.2	7.1	7.3	7.4	7.4	7.4	7.3	7.3	7.3	7.4
		最小	7.2	7.2	7.1	7.0	7.0	7.0	7.2	7.3	7.2	7.2	7.2	7.2	7.0
		平均	7.3	7.3	7.2	7.1	7.0	7.1	7.3	7.4	7.3	7.3	7.3	7.2	7.2
アルカ度 (mg/l)	原水	最大	17.5	17.0	18.5	17.5	19.0	16.0	21.5	23.5	22.5	22.0	21.5	20.5	23.5
		最小	8.0	10.0	8.5	7.5	9.0	10.0	11.5	19.5	18.0	18.0	18.0	17.0	7.5
		平均	13.2	13.3	17.1	13.6	15.6	13.2	17.2	21.3	20.2	20.3	20.0	18.8	17.0
	浄水	最大	17.0	17.0	17.5	16.0	17.5	14.5	20.5	22.5	21.5	21.0	20.5	20.0	22.5
		最小	9.5	10.5	14.0	9.0	9.5	10.5	12.0	19.0	17.5	17.5	17.0	16.5	9.0
		平均	13.4	13.2	16.6	13.1	14.5	12.6	16.4	20.8	19.5	19.5	19.4	18.4	16.5
KMnO <sub>4</sub> 消費量 (mg/l)	原水	最大	26	10	17	39	133	51	13	4.3	5.7	3.4	4.5	3.6	133
		最小	2.6	3.6	2.9	3.6	3.2	2.9	2.5	3.0	2.8	2.3	2.3	2.3	2.3
		平均	5.7	5.2	4.2	8.6	13	8.0	4.0	3.6	3.4	2.9	3.2	3.0	5.4
	浄水	最大	1.6	1.4	1.4	1.2	1.5	1.5	1.4	1.7	1.7	1.5	1.6	1.4	1.7
		最小	0.6	0.8	0.6	0.8	0.6	0.8	0.9	0.9	0.9	0.8	0.9	0.8	0.6
		平均	1.1	1.0	1.0	1.0	1.1	1.1	1.1	1.3	1.2	1.1	1.3	1.1	1.1
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.4	0.5	0.5	0.6
		最小	0.4	0.4	0.4	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
		平均	0.5	0.4	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.4	0.4

## 尾張東部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	26.3	28.5	29.3	35.8	34.7	29.4	26.0	19.6	17.3	7.8	13.3	16.4	35.8	
	最小	8.8	13.0	18.9	23.5	24.0	17.4	15.0	9.8	0.8	0.4	2.2	7.0	0.4	
	平均	17.9	20.9	24.1	30.3	30.8	23.8	20.1	14.7	8.4	5.4	7.5	10.8	17.9	
原水水温 (°C)	最大	14.5	18.5	21.0	25.0	26.0	23.5	19.0	15.0	11.5	7.0	7.0	10.0	26.0	
	最小	10.0	13.5	18.0	19.0	22.0	19.0	15.0	11.5	7.0	5.5	5.0	7.0	5.0	
	平均	12.4	15.4	19.6	22.0	24.3	20.4	17.3	13.8	9.4	5.9	6.0	8.7	14.6	
濁度 (度)	原水	最大	96	24	77	160	848	427	110	3.3	5.3	2.9	3.4	3.4	848
		最小	3.0	3.8	1.9	4.8	1.8	2.7	1.9	1.8	1.6	1.1	1.9	2.0	1.1
		平均	11	8.8	6.4	35	85	36	8.8	2.4	2.8	1.9	2.5	2.5	17
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	34	14	26	63	350	193	60	4.1	6.4	2.9	4.0	3.9	350
		最小	2.9	3.1	3.0	3.7	3.3	3.8	2.7	2.3	2.1	1.7	2.2	2.4	1.7
		平均	6.8	6.2	5.3	15	37	17	6.1	3.3	3.5	2.3	2.8	3.0	9.0
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.7	7.8	7.5	7.5	7.5	7.6	7.5	7.6	7.5	7.5	7.4	7.8
		最小	7.0	7.2	7.2	7.0	6.8	6.9	7.3	7.3	7.3	7.3	7.3	7.2	6.8
		平均	7.3	7.4	7.5	7.3	7.3	7.4	7.5	7.4	7.4	7.4	7.4	7.3	7.4
	浄水	最大	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.2	7.2	7.2	7.3
		最小	7.1	7.1	7.1	7.1	7.1	7.2	7.2	7.1	7.1	7.1	7.1	7.1	7.1
		平均	7.2	7.2	7.2	7.2	7.2	7.3	7.2	7.2	7.2	7.2	7.2	7.1	7.2
アルカ度 (mg/l)	原水	最大	27.5	17.0	18.5	17.5	19.0	16.0	20.5	23.5	22.5	22.0	21.5	20.5	23.5
		最小	7.5	9.5	12.5	7.5	8.0	9.5	11.0	18.5	18.5	18.0	17.5	17.0	7.5
		平均	13.5	13.4	17.3	13.4	15.2	13.1	16.8	20.7	20.5	20.3	20.2	18.9	16.9
	浄水	最大	15.5	15.0	16.5	15.5	17.0	15.0	18.5	21.0	20.5	20.0	19.5	18.5	21.0
		最小	9.0	9.5	12.0	8.5	9.0	9.5	12.0	16.5	16.0	16.0	15.0	15.0	8.5
		平均	12.1	12.0	15.2	12.5	14.2	12.4	15.1	18.6	18.3	18.2	17.9	16.8	15.3
KMnO <sub>4</sub> 消費量 (mg/l)	原水	最大	27	10	14	26	198	31	11	4.8	5.4	3.2	3.7	4.0	198
		最小	2.0	3.2	2.6	2.8	2.6	2.7	2.0	2.8	2.3	1.8	2.1	2.3	1.8
		平均	5.2	5.1	4.4	8.0	18	6.9	3.3	3.5	3.5	2.7	2.8	2.9	5.5
	浄水	最大	1.2	1.4	1.6	1.5	1.5	1.5	1.9	2.0	1.5	1.5	1.4	1.6	2.0
		最小	0.5	0.3	0.6	0.6	0.6	0.8	0.3	0.6	0.8	0.6	0.6	0.8	0.3
		平均	0.8	0.9	1.1	0.9	1.0	1.0	0.9	1.3	1.1	1.0	0.9	1.1	1.0
残留塩素 (mg/l)	浄水	最大	0.6	0.6	0.7	0.7	0.8	0.7	0.7	0.6	0.6	0.5	0.5	0.8	
		最小	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.5	0.5	0.4	0.4	0.5	
		平均	0.5	0.5	0.6	0.7	0.7	0.6	0.6	0.6	0.6	0.5	0.5	0.5	

上野浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.5	29.0	29.0	35.0	33.5	29.5	25.5	19.5	17.5	8.0	13.0	15.5	35.0	
	最小	10.0	16.0	18.5	24.0	26.0	18.0	14.5	10.0	3.0	2.5	3.5	7.5	2.5	
	平均	17.9	21.3	24.3	30.4	30.7	24.4	20.2	14.9	8.9	6.0	7.7	10.9	18.1	
原水水温 (°C)	最大	16.5	19.0	22.5	27.0	28.0	25.5	21.5	16.5	12.5	7.5	8.0	11.0	28.0	
	最小	11.5	16.0	19.0	23.0	25.0	20.5	16.5	12.5	7.0	5.4	5.5	8.0	5.4	
	平均	13.6	17.2	20.9	24.4	26.7	22.8	19.2	14.6	10.1	6.3	6.4	9.4	16.0	
濁度 (度)	原水	最大	27	8.8	6.9	52	255	79	25	7.0	4.3	2.8	3.0	3.8	255
		最小	3.9	3.4	2.3	4.6	4.2	5.0	5.2	2.8	2.1	1.8	2.0	2.3	1.8
		平均	6.5	5.1	4.0	16	42	21	9.3	4.2	2.9	2.2	2.5	3.1	10
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	9.5	4.5	3.8	9.7	29	12	5.7	4.7	3.3	2.2	1.7	2.3	29
		最小	0.6	2.3	2.0	2.6	2.7	2.4	2.0	2.3	2.0	1.2	1.2	1.3	0.6
		平均	2.7	3.3	2.9	5.1	9.7	5.4	3.6	3.2	2.6	1.8	1.4	1.7	3.6
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.4	7.4	7.4	7.4	7.3	7.6	7.6	7.9	7.6	7.6	7.6	7.9
		最小	7.2	7.2	7.3	7.1	7.1	7.0	7.2	7.4	7.5	7.4	7.4	7.4	7.0
		平均	7.3	7.3	7.4	7.2	7.3	7.2	7.4	7.5	7.6	7.5	7.5	7.5	7.4
	浄水	最大	7.5	7.5	7.3	7.2	7.1	7.2	7.4	7.5	7.5	7.5	7.5	7.4	7.5
		最小	7.4	7.3	7.1	7.0	7.0	7.1	7.2	7.3	7.3	7.3	7.3	7.4	7.0
		平均	7.4	7.3	7.2	7.1	7.0	7.1	7.3	7.4	7.4	7.4	7.4	7.4	7.3
アルカ度 (mg/l)	原水	最大	15.0	14.5	18.0	17.0	18.0	14.0	16.5	20.0	20.5	19.0	19.5	19.0	20.5
		最小	12.5	12.0	15.5	12.0	12.5	12.0	13.0	17.0	18.5	17.5	17.5	17.0	12.0
		平均	13.8	13.0	17.0	14.4	16.2	12.9	14.8	18.2	19.4	18.3	18.6	18.3	16.2
	浄水	最大	15.0	15.0	17.0	15.5	16.5	13.5	16.0	20.0	19.5	18.5	19.0	18.5	20.0
		最小	13.0	12.0	15.0	11.5	12.0	11.5	13.0	16.0	18.0	17.0	17.5	17.0	11.5
		平均	13.9	13.1	16.3	13.4	14.5	12.5	14.2	17.8	18.6	17.9	18.2	17.8	15.7
KMnO <sub>4</sub> 消費量 (mg/l)	原水	最大	9.3	5.3	4.5	8.0	39	12	6.2	5.1	5.3	4.1	3.2	3.2	39
		最小	3.5	3.3	3.2	3.5	3.3	3.5	3.5	2.7	2.8	2.6	2.4	2.5	2.4
		平均	4.4	4.3	3.9	5.2	9.3	6.2	4.4	3.7	3.8	3.2	2.7	2.8	4.5
	浄水	最大	1.3	1.4	1.4	1.1	1.3	1.6	1.6	1.3	1.3	1.3	1.1	1.1	1.6
		最小	0.8	0.5	0.8	0.6	0.8	0.6	0.8	0.6	0.8	0.8	0.8	0.6	0.5
		平均	1.1	1.0	1.1	0.9	1.0	1.1	1.1	0.9	1.0	1.0	1.0	0.8	1.0
残留塩素 (mg/l)	浄水	最大	0.4	0.5	0.5	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.6
		最小	0.4	0.4	0.5	0.4	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4
		平均	0.4	0.4	0.5	0.5	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.4	0.5

知多浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	26.0	29.0	30.0	35.0	35.0	31.0	26.0	20.0	17.0	7.0	14.0	16.0	35.0	
	最小	10.0	14.0	18.0	24.0	26.0	17.0	15.0	10.0	3.0	0.0	2.0	7.0	0.0	
	平均	18.4	21.2	24.7	30.8	31.9	24.6	20.4	14.5	8.4	4.9	7.4	11.4	18.2	
原水水温 (°C)	最大	19.5	23.0	26.0	31.5	32.0	27.0	22.0	18.0	14.0	8.5	11.0	13.0	32.0	
	最小	13.0	17.0	21.5	21.0	24.0	20.5	18.0	13.5	8.5	7.0	7.0	2.4	2.4	
	平均	16.1	19.5	24.3	26.1	29.0	22.8	19.9	16.0	11.0	7.7	8.6	11.5	17.7	
濁度 (度)	原水	最大	49	13	11	350	55	127	119	8.6	6.9	4.7	7.3	10	350
		最小	3.1	2.8	3.8	5.4	6.8	4.0	2.5	3.5	2.4	2.0	2.7	2.9	2.0
		平均	8.3	6.4	6.9	52	15	27	10	5.0	4.5	3.5	4.4	6.2	12
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	29	12	10	150	25	59	33	7.2	5.9	4.5	6.0	8.0	150
		最小	1.8	3.2	4.1	5.7	5.2	3.3	3.1	3.6	2.7	2.5	2.5	3.5	1.8
		平均	6.5	5.9	7.6	27	10	13	5.5	4.9	4.2	3.3	3.8	5.3	8.1
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.7	8.1	7.9	8.6	8.5	7.5	8.2	7.7	7.5	7.7	7.8	7.5	8.6
		最小	6.9	7.0	6.8	6.8	6.9	6.9	7.1	7.2	7.3	7.3	7.2	7.2	6.8
		平均	7.2	7.2	7.4	7.5	7.6	7.1	7.5	7.4	7.4	7.4	7.4	7.3	7.4
	浄水	最大	7.3	7.3	7.3	7.4	7.4	7.2	7.3	7.3	7.4	7.3	7.4	7.2	7.4
		最小	7.0	7.0	7.1	7.1	7.0	7.1	7.1	7.1	7.2	7.2	7.1	7.1	7.0
		平均	7.1	7.1	7.2	7.2	7.2	7.1	7.2	7.2	7.2	7.2	7.2	7.1	7.2
アルカ度 (mg/l)	原水	最大	27.5	31.0	35.5	38.5	41.5	32.0	36.5	39.0	40.5	40.0	40.0	36.0	41.5
		最小	14.0	14.0	23.0	13.0	17.0	17.0	15.5	28.0	31.0	33.0	29.0	26.5	13.0
		平均	23.2	23.5	31.1	26.3	32.7	24.1	30.3	34.4	34.8	36.7	34.9	31.9	30.3
	浄水	最大	30.5	30.5	34.5	36.5	40.0	30.5	35.0	36.0	39.5	38.5	38.0	34.0	40.0
		最小	15.0	19.0	26.0	15.5	18.0	17.5	18.5	26.0	28.5	30.0	27.5	25.0	15.0
		平均	23.1	23.9	30.3	26.4	31.4	23.9	28.2	32.1	32.4	34.4	32.7	30.1	29.1
KMnO <sub>4</sub> 消費量 (mg/l)	原水	最大	11	6.3	7.8	21	8.5	13	10	5.4	4.4	4.7	4.7	21	
		最小	2.5	2.2	3.5	0.3	3.7	2.5	2.2	2.2	2.5	2.2	2.5	2.2	0.3
		平均	4.1	3.9	5.1	7.3	5.9	4.9	3.1	3.5	3.2	3.2	3.4	3.6	4.3
	浄水	最大	1.9	2.2	2.2	1.6	1.6	1.6	1.3	1.9	1.9	1.6	1.3	1.9	2.2
		最小	0.6	0.3	0.6	0.3	0.3	0.3	0.6	0.6	0.6	0.6	0.0	0.3	0.0
		平均	1.1	0.9	1.2	0.8	0.9	0.8	0.8	1.0	1.1	1.1	1.0	1.1	1.0
残留塩素 (mg/l)	浄水	最大	0.7	0.7	0.8	0.8	0.8	0.8	0.7	0.7	0.7	0.6	0.6	0.7	0.8
		最小	0.5	0.6	0.7	0.6	0.7	0.6	0.6	0.7	0.6	0.5	0.5	0.5	0.5
		平均	0.6	0.6	0.7	0.7	0.8	0.7	0.7	0.7	0.7	0.6	0.6	0.6	0.7

犬山浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.8	27.5	29.0	34.9	34.0	28.9	27.5	19.7	16.4	7.6	13.0	15.8	34.9	
	最小	7.9	15.9	18.2	23.8	26.1	17.9	14.7	9.0	0.4	-0.2	4.1	6.0	-0.2	
	平均	17.5	21.0	24.1	30.3	30.9	24.1	20.0	14.8	8.5	5.2	7.7	10.9	17.9	
原水水温 (°C)	最大	14.4	18.2	21.4	25.0	26.4	23.3	19.0	14.7	11.2	6.3	7.4	9.6	26.4	
	最小	9.7	13.5	17.4	18.2	22.0	17.5	14.7	10.9	6.1	4.3	4.7	7.3	4.3	
	平均	11.8	15.3	19.7	21.6	24.5	19.8	16.8	13.3	8.7	5.2	5.8	8.3	14.2	
濁度 (度)	原水	最大	86	19	622	596	550	427	86	2.2	3.5	2.1	2.9	9.8	622
		最小	2.3	2.3	1.6	8.7	3.5	4.8	1.4	1.4	1.3	1.0	1.8	1.4	1.0
		平均	9.9	5.3	32	67	57	35	10	1.7	2.0	1.5	2.1	2.3	19
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	82	12	124	258	268	204	60	4.3	5.9	2.7	3.0	7.2	268
		最小	3.1	3.2	3.0	6.2	4.6	4.0	2.7	2.5	2.2	1.6	2.0	2.4	1.6
		平均	8.0	5.0	12	30	28	18	7.0	3.1	3.3	2.1	2.4	2.9	10.2
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.4	7.4	7.3	7.2	7.2	7.3	7.4	7.4	7.4	7.4	7.4	7.3	7.4
		最小	7.0	7.2	6.6	6.2	6.8	6.8	7.1	7.3	7.3	7.3	7.3	7.2	6.2
		平均	7.2	7.2	7.2	7.0	7.1	7.2	7.4	7.3	7.3	7.4	7.3	7.2	7.2
	浄水	最大	7.3	7.4	7.4	7.3	7.2	7.4	7.3	7.3	7.4	7.4	7.3	7.3	7.4
		最小	7.2	7.2	7.3	7.1	7.0	7.1	7.2	7.3	7.2	7.2	7.1	7.1	7.2
		平均	7.2	7.3	7.3	7.2	7.1	7.3	7.3	7.3	7.3	7.3	7.2	7.3	7.3
アルカ度 (mg/l)	原水	最大	15.5	15.5	17.5	16.0	18.0	14.0	17.0	19.0	18.5	17.5	18.0	17.0	19.0
		最小	6.5	9.0	6.5	5.0	8.0	8.0	7.5	15.5	15.0	15.5	16.0	15.0	5.0
		平均	12.3	12.2	15.6	12.0	14.4	10.8	13.7	17.4	17.0	16.7	16.7	16.1	14.6
	浄水	最大	15.5	15.5	17.5	16.0	18.0	14.0	16.5	19.0	18.5	17.5	17.5	17.0	19.0
		最小	8.0	9.0	9.5	8.5	8.5	9.0	9.0	15.5	15.5	15.0	15.5	14.5	8.0
		平均	12.7	12.4	15.9	12.2	14.3	11.1	13.8	17.3	17.0	16.4	16.4	15.7	14.6
KMnO <sub>4</sub> 消費量 (mg/l)	原水	最大	26	9.1	53	43	36	38	27	4.5	5.1	4.1	4.4	5.6	53
		最小	2.8	2.8	3.1	3.7	3.8	3.8	3.2	3.2	2.9	2.8	2.8	3.1	2.8
		平均	5.0	4.3	6.5	9.7	8.4	7.1	4.7	3.9	4.1	3.5	3.4	3.5	5.3
	浄水	最大	1.6	1.6	1.9	1.6	1.9	1.6	1.9	2.2	2.2	1.6	1.9	1.9	2.2
		最小	0.6	0.6	0.9	0.3	0.6	0.6	1.0	0.9	0.9	0.9	0.9	0.6	0.3
		平均	1.1	1.1	1.4	0.7	1.1	1.2	1.3	1.6	1.6	1.4	1.3	1.3	1.3
残留塩素 (mg/l)	浄水	最大	0.6	0.5	0.6	0.6	0.7	0.6	0.6	0.5	0.6	0.5	0.5	0.5	0.7
		最小	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4
		平均	0.5	0.5	0.5	0.5	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.5

尾張西部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	24.5	26.3	28.8	35.6	34.0	29.9	25.9	19.4	14.8	7.5	12.7	15.9	35.6	
	最小	7.8	16.0	19.6	23.2	24.7	18.6	15.0	7.9	-0.1	-0.8	1.8	4.0	-0.8	
	平均	17.9	20.6	24.5	30.1	30.8	24.4	20.1	14.6	8.0	5.0	7.5	10.3	17.8	
原水水温 (°C)	最大	17.3	21.1	25.5	28.3	30.4	25.8	20.0	16.6	13.0	7.6	9.4	12.2	30.4	
	最小	11.0	14.1	18.4	18.8	23.6	19.0	16.1	12.7	6.3	5.8	5.8	8.0	5.8	
	平均	13.2	16.7	22.2	23.8	27.3	21.1	18.1	14.8	9.8	6.6	7.4	10.1	15.9	
濁度 (度)	原水	最大	47	18	288	130	328	132	89	3.7	3.4	3.4	3.2	3.4	328
		最小	1.9	2.0	2.1	8.3	6.2	4.7	1.3	1.5	1.1	1.0	1.3	1.2	1.0
		平均	6.8	5.8	14	42	40	28	9.4	2.1	2.0	1.5	1.8	1.8	13
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	25	9.4	95	68	153	88	36	4.8	5.1	4.5	3.5	3.7	153
		最小	2.9	3.6	3.7	5.4	5.0	4.9	3.0	2.5	2.6	1.8	2.0	2.0	1.8
		平均	5.3	5.3	7.9	18	21	15	6.4	3.2	3.6	2.7	2.6	2.7	7.7
	浄水	最大	<0.5	<0.5	<0.5	0.5	0.5	<0.5	<0.5	0.5	<0.5	<0.5	<0.5	<0.5	0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.7	7.6	7.7	7.2	7.3	7.2	7.6	7.6	7.5	7.6	7.5	7.3	7.7
		最小	6.9	7.0	6.7	6.6	6.7	6.8	7.0	7.2	7.2	7.4	7.0	7.1	6.6
		平均	7.3	7.2	7.2	6.9	7.0	7.1	7.3	7.4	7.3	7.5	7.3	7.2	7.2
	浄水	最大	7.5	7.5	7.4	7.5	7.5	7.4	7.5	7.4	7.4	7.4	7.4	7.4	7.5
		最小	7.3	7.3	7.3	7.0	7.2	7.0	7.2	7.3	7.3	7.2	7.3	7.3	7.0
		平均	7.4	7.4	7.4	7.3	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	27.5	19.5	22.5	19.5	22.0	18.5	22.0	25.0	25.5	24.0	24.0	23.0	25.5
		最小	9.5	12.5	9.0	8.5	11.5	11.0	11.5	20.5	20.5	21.0	21.0	19.5	8.5
		平均	15.1	15.4	20.0	15.0	17.8	14.6	18.1	22.6	22.5	22.4	22.7	21.2	19.0
	浄水	最大	17.5	18.5	22.0	20.0	22.0	17.0	20.5	24.0	24.0	23.0	23.0	22.0	24.0
		最小	11.0	12.5	16.5	10.5	13.5	12.5	13.0	19.5	19.0	18.5	20.0	18.0	10.5
		平均	14.9	15.4	20.0	15.9	18.4	15.0	17.3	21.5	21.2	21.1	21.4	20.1	18.5
KMnO <sub>4</sub> 消費量 (mg/l)	原水	最大	16	8.2	27	24	22	30	12	6.1	6.4	5.1	5.4	4.9	30
		最小	2.5	3.5	2.8	3.5	3.5	3.6	3.2	3.5	3.2	3.0	2.8	2.3	2.3
		平均	4.9	5.0	5.3	8.5	7.5	7.2	4.5	4.9	4.6	4.1	4.3	3.5	5.4
	浄水	最大	2.7	2.7	2.2	1.7	2.2	2.1	2.4	2.9	2.2	2.2	2.5	2.2	2.9
		最小	0.9	1.3	1.1	0.8	0.9	0.5	0.5	1.1	1.0	0.6	0.6	0.5	0.5
		平均	1.8	1.7	1.8	1.2	1.5	1.3	1.1	1.9	1.7	1.3	1.5	1.3	1.5
残留塩素 (mg/l)	浄水	最大	0.5	0.6	0.8	0.8	0.8	0.7	0.6	0.6	0.6	0.5	0.6	0.5	0.8
		最小	0.4	0.4	0.6	0.5	0.6	0.5	0.5	0.5	0.5	0.4	0.4	0.5	0.4
		平均	0.5	0.5	0.7	0.7	0.7	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.6

豊田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.3	29.0	29.5	33.6	34.0	30.4	25.5	20.5	17.0	7.2	13.8	16.5	34.0	
	最小	8.5	15.4	17.0	24.0	26.0	17.8	14.9	9.5	0.1	0.2	1.8	6.4	0.1	
	平均	17.5	20.5	23.1	30.1	30.6	24.0	20.0	14.2	8.0	4.9	7.3	10.5	17.6	
原水水温 (°C)	最大	14.5	16.8	20.0	24.0	25.0	22.7	18.5	14.3	11.5	6.0	6.8	8.4	25.0	
	最小	9.0	13.4	16.0	15.0	22.2	17.4	14.0	10.5	1.5	4.5	4.2	6.0	1.5	
	平均	11.8	14.9	18.3	21.5	23.5	19.9	16.3	12.7	8.8	5.2	5.1	7.0	13.8	
濁度 (度)	原水	最大	14	23	20	110	31	76	55	4.3	7.8	2.9	2.5	3.9	110
		最小	1.5	2.2	2.1	1.7	1.9	2.0	2.7	2.0	1.5	1.4	1.4	1.3	1.3
		平均	4.2	5.1	3.7	8.0	4.0	13	10	3.0	2.5	1.8	1.8	1.8	4.9
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	11	17	12	56	25	37	46	4.8	5.8	3.7	4.3	5.7	56
		最小	2.9	3.2	3.6	3.8	4.8	4.5	4.1	3.2	3.0	2.2	2.7	1.4	1.4
		平均	4.9	5.5	5.2	7.3	7.0	10	7.8	4.2	3.7	3.0	3.3	3.0	5.4
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.5	7.5	7.4	7.3	7.3	7.4	7.3	7.5	7.4	7.4	7.4	7.5
		最小	7.2	7.2	7.3	7.1	7.1	7.0	7.2	7.2	7.2	7.3	7.2	7.2	7.3
		平均	7.3	7.3	7.3	7.3	7.2	7.2	7.3	7.2	7.3	7.3	7.3	7.3	7.3
	浄水	最大	7.4	7.5	7.4	7.4	7.4	7.4	7.4	7.4	7.5	7.4	7.4	7.4	7.5
		最小	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3
		平均	7.4	7.4	7.4	7.3	7.3	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	17.5	18.0	20.0	19.5	21.0	17.5	18.0	20.0	20.5	20.0	19.5	20.0	21.0
		最小	13.5	13.0	16.0	11.0	15.0	10.0	12.5	16.5	18.5	18.0	18.5	18.0	10.0
		平均	15.3	15.3	18.0	16.5	18.5	15.1	16.3	18.7	19.2	19.0	19.0	18.9	17.5
	浄水	最大	16.0	16.5	18.5	17.5	20.0	16.5	17.0	19.0	19.5	19.5	18.5	19.0	20.0
		最小	13.0	13.0	15.0	12.0	13.0	10.5	12.0	16.5	16.5	17.0	17.0	16.0	10.5
		平均	14.3	14.4	16.8	15.4	17.5	14.5	15.5	17.8	18.5	18.0	17.8	17.5	16.5
KMnO <sub>4</sub> 消費量 (mg/l)	原水	最大	12	11	11	31	24	23	16	4.4	5.6	3.8	3.8	5.0	31
		最小	2.6	3.1	3.9	2.5	3.2	4.1	2.2	2.5	2.2	1.4	1.6	1.9	1.4
		平均	4.5	5.1	5.4	5.8	5.8	7.1	4.6	3.4	3.2	2.6	2.7	3.1	4.4
	浄水	最大	1.4	1.9	1.9	2.0	2.3	2.0	2.2	1.6	1.6	1.6	1.2	1.2	2.3
		最小	0.4	0.5	0.8	0.4	0.3	0.6	0.4	0.6	0.3	0.3	0.5	0.5	0.3
		平均	0.8	1.2	1.3	1.0	1.0	1.3	0.9	1.0	0.8	0.7	0.8	0.8	1.0
残留塩素 (mg/l)	浄水	最大	0.7	0.6	0.6	0.7	0.8	0.8	0.7	0.6	0.6	0.6	0.6	0.6	0.8
		最小	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5
		平均	0.6	0.6	0.6	0.6	0.7	0.7	0.6	0.6	0.5	0.6	0.6	0.5	0.6

幸田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	24.2	29.5	29.1	34.7	35.4	29.6	27.4	21.6	18.9	10.5	14.5	18.2	35.4	
	最小	9.8	17.4	18.5	25.1	26.6	18.2	16.1	11.0	2.4	1.7	3.4	8.1	1.7	
	平均	18.8	21.8	25.0	30.7	31.3	25.2	21.0	15.7	9.7	6.7	8.6	11.8	18.9	
原水水温 (°C)	最大	17.5	20.0	24.5	28.0	28.0	26.0	21.5	16.5	14.0	6.5	10.0	11.5	28.0	
	最小	11.5	15.5	18.5	21.5	24.5	20.0	15.0	10.0	5.5	5.0	5.0	8.5	5.0	
	平均	14.5	17.7	21.0	25.3	26.7	22.4	18.2	13.6	9.5	5.7	6.9	10.1	16.0	
濁度 (度)	原水	最大	41	28	32	42	29	42	83	6.9	6.9	7.0	4.4	15	83
		最小	1.4	4.0	3.5	1.9	1.8	2.9	1.1	0.7	0.7	0.6	0.8	0.9	0.6
		平均	8.3	9.2	9.0	8.0	7.4	9.3	5.6	1.8	1.9	1.3	1.7	2.5	5.5
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	43	30	31	37	38	45	59	11	9.2	6.2	6.8	18	59
		最小	4.0	6.2	6.6	5.3	5.8	6.3	3.6	3.4	2.8	1.3	2.8	3.3	1.3
		平均	9.9	11	12	11.2	11.1	12.0	7.4	4.6	4.5	3.1	4.0	5.3	8.0
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.2	7.3	7.3	7.1	7.2	7.1	7.1	7.3	7.4	7.4	7.4	7.3	7.1
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.5	7.4	7.5	7.5	7.4	7.4
	浄水	最大	7.5	7.5	7.5	7.5	7.4	7.5	7.4	7.5	7.5	7.4	7.4	7.5	7.5
		最小	7.3	7.3	7.4	7.4	7.3	7.3	7.4	7.1	7.3	7.4	7.4	7.4	7.1
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.3	7.4	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	27.5	19.0	19.0	19.5	21.0	19.0	18.5	21.0	21.0	21.0	21.5	21.5	21.5
		最小	10.0	13.0	15.0	12.5	11.5	10.5	9.5	17.5	18.0	19.0	19.0	15.5	9.5
		平均	17.2	16.1	17.8	17.5	18.3	15.8	16.5	19.5	20.3	20.3	20.3	20.4	18.3
	浄水	最大	18.5	18.0	19.0	18.5	19.0	17.5	17.5	19.5	20.0	19.5	20.0	20.0	20.0
		最小	12.0	12.5	13.0	11.5	11.0	9.5	11.0	15.5	17.0	17.5	18.5	16.5	9.5
		平均	16.4	15.1	16.6	16.3	16.8	14.9	15.5	17.7	18.9	19.0	19.0	19.1	17.1
KMnO <sub>4</sub> 消費量 (mg/l)	原水	最大	23	16	16	22	23	23	25	8.2	8.1	6.9	4.8	13	25
		最小	3.2	5.7	5.8	4.9	5.4	5.4	3.1	2.6	2.5	2.0	2.0	2.7	2.0
		平均	7.3	8.2	8.9	8.9	8.9	9.5	5.1	3.8	4.1	2.8	3.1	4.1	6.2
	浄水	最大	1.7	1.9	1.8	1.9	1.9	1.9	1.4	1.5	1.9	1.2	1.6	1.9	1.9
		最小	0.6	0.6	0.6	0.8	0.6	0.6	0.8	0.6	0.8	0.5	0.6	0.6	0.5
		平均	1.1	1.2	1.2	1.2	1.3	1.4	1.1	1.0	1.2	0.9	1.0	1.0	1.1
残留塩素 (mg/l)	浄水	最大	0.6	0.6	0.7	0.8	0.9	0.9	0.7	0.7	0.6	0.5	0.5	0.9	
		最小	0.5	0.5	0.6	0.6	0.7	0.6	0.6	0.5	0.5	0.4	0.4	0.4	
		平均	0.5	0.5	0.6	0.7	0.8	0.7	0.6	0.6	0.6	0.5	0.4	0.5	0.6

豊橋浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	24.0	28.0	29.5	35.0	34.0	29.0	27.0	22.0	18.5	10.0	15.0	18.0	35.0	
	最小	11.0	15.5	19.0	24.5	26.0	19.0	16.0	11.0	3.5	3.5	3.5	7.0	3.5	
	平均	18.9	21.4	24.2	30.0	30.6	25.3	21.2	16.0	10.0	7.1	8.8	11.9	18.8	
原水水温 (°C)	最大	18.0	20.5	24.5	28.5	29.5	26.0	22.5	17.0	14.0	6.5	10.5	12.5	29.5	
	最小	12.5	14.5	18.5	20.5	24.0	19.0	15.0	10.5	5.5	4.5	4.5	8.5	4.5	
	平均	15.3	17.7	21.2	25.1	26.9	21.9	18.6	13.9	9.3	5.4	7.4	10.6	16.1	
濁度 (度)	原水	最大	15	22	10	9.2	12	25	250	3.2	2.0	0.8	3.1	3.0	250
		最小	1.6	1.6	1.3	1.1	1.4	2.3	1.5	0.7	0.5	0.4	0.7	1.0	0.4
		平均	3.4	3.8	2.4	3.0	3.0	4.7	12	1.3	0.9	0.6	1.3	1.5	3.2
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	13	24	22	13	18	25	220	6.4	4.5	1.8	4.7	8.5	220
		最小	3.5	3.6	4.4	3.8	4.4	4.0	2.9	2.3	1.7	1.3	1.8	2.5	1.3
		平均	5.4	6.1	6.6	6.2	7.0	7.0	12	3.4	3.0	1.6	2.7	3.8	5.4
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.5	7.4	7.4	7.4	7.4	7.7	7.7	7.6	7.7	7.6	7.7	7.7
		最小	7.2	7.2	7.2	7.1	7.1	7.2	7.2	7.4	7.3	7.4	7.4	7.3	7.1
		平均	7.4	7.4	7.3	7.3	7.3	7.3	7.5	7.5	7.5	7.5	7.5	7.4	7.4
	浄水	最大	7.5	7.4	7.4	7.4	7.4	7.4	7.5	7.4	7.4	7.4	7.4	7.4	7.5
		最小	7.3	7.4	7.4	7.4	7.3	7.3	7.4	7.4	7.3	7.3	7.4	7.4	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	24.5	24.0	24.0	25.5	27.0	24.0	30.0	27.0	28.0	27.5	27.5	27.0	30.0
		最小	10.0	12.0	16.0	11.0	13.0	12.0	17.5	23.0	23.5	25.0	22.5	19.5	10.0
		平均	19.0	18.6	22.1	20.6	23.4	19.1	22.5	25.6	25.6	26.1	26.0	24.6	22.8
	浄水	最大	22.0	21.0	22.0	22.0	23.0	21.5	23.5	26.0	25.0	25.5	26.0	26.0	26.0
		最小	11.0	12.0	16.0	11.0	12.0	12.5	17.0	20.0	21.0	22.5	22.0	19.0	11.0
		平均	17.7	17.3	22.0	18.4	20.4	18.0	20.4	23.2	23.3	23.8	24.2	22.7	21.0
KMnO <sub>4</sub> 消費量 (mg/l)	原水	最大	11	13	15	12	10	14	32	5.9	5.3	3.7	4.0	9.0	32
		最小	2.8	2.2	3.4	3.4	3.8	4.1	3.1	2.7	2.2	1.2	2.2	2.8	1.2
		平均	4.4	3.8	5.1	5.3	5.6	5.8	5.2	3.6	3.7	2.3	2.7	4.5	4.3
	浄水	最大	1.8	1.2	1.9	1.9	1.6	1.2	1.9	1.6	1.5	0.9	1.2	2.2	2.2
		最小	0.3	0.3	0.3	0.9	0.6	0.9	0.6	0.6	0.6	0.3	0.6	0.6	0.3
		平均	0.8	0.5	0.9	1.1	1.0	1.1	1.0	0.9	1.2	0.6	0.8	1.2	0.9
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.6
		最小	0.4	0.5	0.5	0.5	0.6	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.4
		平均	0.5	0.5	0.5	0.5	0.6	0.6	0.5	0.5	0.4	0.5	0.5	0.4	0.5

豊橋南部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.7	25.2	27.6	32.6	33.4	29.2	26.4	19.9	18.3	8.5	13.0	16.6	33.4	
	最小	8.9	15.7	18.3	24.7	25.2	18.8	16.3	11.1	3.7	4.3	3.7	7.2	3.7	
	平均	17.5	20.6	23.5	29.1	29.9	24.7	20.4	15.3	9.7	6.5	8.1	11.3	18.1	
原水水温 (°C)	最大	15.5	18.0	21.1	23.6	25.5	25.0	22.5	18.3	15.0	9.3	8.7	11.5	25.5	
	最小	11.8	14.5	17.5	21.0	23.7	22.0	18.5	14.5	9.5	6.9	6.5	8.7	6.5	
	平均	13.2	16.1	19.7	22.2	24.5	23.7	20.8	16.6	12.3	8.0	7.4	10.1	16.2	
濁度 (度)	原水	最大	8.3	1.8	3.6	9.0	3.4	28	8.7	1.7	3.2	3.2	2.0	1.9	28
		最小	1.1	0.7	1.0	1.0	0.6	0.6	1.3	0.8	1.3	1.4	1.1	0.8	0.6
		平均	2.1	1.2	1.6	2.5	1.5	2.4	2.4	1.2	1.9	1.9	1.4	1.3	1.8
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	11	5.8	9.3	14	7.2	24	6.8	4.6	4.4	4.0	3.8	4.4	24
		最小	3.3	3.3	3.9	4.0	3.7	3.6	3.7	3.5	3.4	3.2	3.0	2.9	2.9
		平均	4.6	4.1	5.2	5.9	4.8	5.4	4.6	3.9	4.0	3.6	3.3	3.3	4.4
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.3	7.4	7.3	7.5	7.4	8.0	7.7	7.8	7.7	7.6	7.5	8.0
		最小	7.1	7.1	7.2	7.1	7.1	7.0	7.2	7.4	7.5	7.6	7.4	7.4	7.0
		平均	7.3	7.2	7.3	7.2	7.3	7.2	7.5	7.5	7.6	7.6	7.5	7.5	7.4
	浄水	最大	7.5	7.5	7.5	7.5	7.5	7.4	7.4	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.3	7.3	7.4	7.3	7.4	7.4	7.3	7.4	7.4	7.3	7.4	7.4	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	27.5	19.0	20.5	26.5	23.0	18.5	20.0	20.5	19.0	19.0	20.0	26.5	
		最小	15.5	15.0	14.0	15.0	14.0	15.0	15.5	17.5	17.0	17.0	17.0	17.0	14.0
		平均	17.8	17.2	17.4	17.9	17.5	16.9	17.9	18.7	17.8	18.0	17.9	17.9	17.7
	浄水	最大	19.0	18.0	19.0	24.0	23.5	17.0	18.0	18.5	17.0	17.5	18.0	18.5	24.0
		最小	15.0	14.5	14.0	14.0	13.5	14.0	14.0	16.0	14.0	15.0	15.5	16.0	13.5
		平均	16.7	16.4	16.0	16.8	16.3	15.9	15.8	17.1	15.9	16.3	16.6	16.8	16.4
KMnO <sub>4</sub> 消費量 (mg/l)	原水	最大	7.4	7.7	9.9	11	8.7	7.1	8.2	5.6	6.5	7.0	6.1	6.1	11
		最小	4.1	3.4	4.0	4.0	4.4	3.5	3.7	4.1	4.6	4.6	4.6	4.0	3.4
		平均	5.1	4.6	5.6	5.7	5.9	5.0	4.9	4.9	5.4	5.2	5.1	5.0	5.2
	浄水	最大	1.9	1.6	1.6	1.6	1.5	1.4	1.6	1.2	1.3	1.3	1.5	1.5	1.9
		最小	0.6	0.3	0.3	0.6	0.6	0.5	0.5	0.6	0.6	0.6	0.9	0.9	0.3
		平均	1.2	1.1	1.0	1.0	1.2	1.0	0.9	1.0	1.1	1.0	1.1	1.3	1.1
残留塩素 (mg/l)	浄水	最大	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.6	0.5	0.6	
		最小	0.4	0.4	0.6	0.5	0.5	0.6	0.5	0.5	0.5	0.5	0.4	0.4	
		平均	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	

豊川浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	26.0	30.4	30.0	35.0	35.5	30.2	26.8	20.3	18.8	9.3	15.1	18.4	35.5	
	最小	10.6	16.1	18.6	24.5	26.8	18.8	15.6	10.8	3.0	4.5	3.8	8.3	3.0	
	平均	19.6	22.2	25.1	31.2	31.7	25.4	20.7	15.5	9.7	6.7	9.0	12.6	19.1	
原水水温 (°C)	最大	19.0	20.5	22.5	26.5	29.0	25.4	23.5	17.5	14.5	8.5	10.5	13.1	29.0	
	最小	15.0	18.2	20.0	22.8	23.7	21.5	17.4	11.0	8.8	7.2	7.0	10.0	7.0	
	平均	16.6	19.3	20.8	24.6	25.2	23.3	20.5	15.7	11.7	7.9	8.5	11.6	17.1	
濁度 (度)	原水	最大	5.7	3.4	2.1	3.6	7.0	2.6	7.7	1.9	2.5	1.8	1.9	2.9	7.7
		最小	0.8	1.3	1.0	0.9	1.1	1.0	0.8	0.8	0.9	1.0	1.1	1.1	0.8
		平均	2.3	2.3	1.5	1.7	2.2	1.6	2.3	1.4	1.5	1.4	1.4	1.8	1.8
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	8.8	7.5	9.2	8.7	9.8	7.2	12	5.8	5.7	5.2	4.7	4.9	12
		最小	4.2	4.4	4.9	4.5	4.8	4.7	3.8	4.3	4.2	3.9	3.7	3.1	3.1
		平均	5.4	5.8	6.7	6.8	7.5	6.0	6.0	5.0	4.9	4.2	4.2	4.1	5.6
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.3	7.4	7.4	7.5	7.4	7.4	7.4	7.5	7.4	7.4	7.5	7.5
		最小	7.1	7.0	7.1	7.0	7.0	7.0	7.0	7.1	7.2	7.2	7.3	7.2	7.0
		平均	7.3	7.1	7.2	7.2	7.2	7.2	7.2	7.3	7.4	7.3	7.4	7.4	7.3
	浄水	最大	7.5	7.5	7.6	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.6
		最小	7.3	7.3	7.3	7.3	7.3	7.3	7.4	7.3	7.4	7.3	7.3	7.3	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
アルカリ度 (mg/l)	原水	最大	19.0	16.5	17.5	26.5	27.0	18.0	20.0	20.5	20.0	19.0	17.0	19.0	27.0
		最小	15.5	12.5	14.0	14.0	11.5	13.0	14.5	17.0	16.5	16.0	15.0	15.0	11.5
		平均	17.2	15.2	15.9	17.5	15.9	16.1	17.6	19.3	17.9	17.3	16.0	17.2	16.9
	浄水	最大	19.0	17.5	18.0	26.5	26.5	18.5	20.0	20.5	19.5	18.5	17.5	18.5	26.5
		最小	16.0	15.0	15.0	14.5	12.0	14.5	16.0	18.5	16.0	16.0	15.0	16.0	12.0
		平均	17.6	16.4	16.6	17.9	16.6	16.7	18.3	19.4	17.5	17.2	16.2	17.2	17.3
KMnO <sub>4</sub> 消費量 (mg/l)	原水	最大	6.0	5.8	7.8	7.2	7.9	5.4	5.7	5.2	6.5	5.3	5.1	5.9	7.9
		最小	3.0	3.3	4.8	4.2	3.6	3.5	2.0	2.3	3.5	2.1	2.7	3.5	2.0
		平均	4.3	4.3	5.8	5.7	6.1	4.1	3.6	4.0	4.6	3.8	4.0	4.7	4.6
	浄水	最大	1.2	1.2	1.5	1.5	1.5	1.2	1.2	1.8	1.7	1.4	1.5	1.7	1.8
		最小	0.3	0.6	0.6	0.9	0.2	0.2	0.3	0.2	0.5	0.5	0.3	0.5	0.2
		平均	0.8	0.8	1.2	1.2	1.0	0.7	0.7	1.0	1.2	0.9	1.0	1.0	1.0
残留塩素 (mg/l)	浄水	最大	0.6	0.6	0.7	0.7	0.7	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.7
		最小	0.5	0.5	0.5	0.6	0.6	0.5	0.6	0.5	0.5	0.5	0.5	0.5	0.5
		平均	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.6

## (2)工業用水毎日検査

尾張東部浄水場(東郷)

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	24.0	27.0	28.0	35.0	35.0	32.0	29.0	22.0	19.0	9.0	16.0	18.0	35.0	
	最小	8.0	13.0	17.0	20.5	24.0	15.0	16.0	11.0	3.0	1.0	2.0	6.5	1.0	
	平均	17.5	19.4	23.0	29.3	30.6	23.3	22.3	16.1	10.6	6.8	9.7	12.6	18.4	
原水水温 (°C)	最大	16.1	18.5	21.7	26.3	27.4	25.1	20.7	16.1	12.0	7.9	8.0	10.7	27.4	
	最小	10.4	15.4	18.5	22.1	24.9	20.3	16.3	12.2	7.2	5.3	5.2	7.4	5.2	
	平均	12.9	16.6	20.3	23.9	26.2	22.8	18.9	14.3	9.9	6.1	6.0	8.9	15.6	
濁度 (度)	原水	最大	11	7.0	11	34	169	21	11	9.0	3.0	3.0	2.0	2.0	169
		最小	2.0	3.0	2.0	4.0	3.3	4.0	3.0	3.0	1.0	1.0	1.0	1.0	1.0
		平均	3.0	4.0	3.0	11	35	11	7.0	4.0	2.0	1.0	1.0	1.0	6.9
	配水	最大	5.0	3.0	4.0	7.0	7.2	9.0	4.0	2.0	2.0	2.0	2.0	2.0	9.0
		最小	1.0	1.0	1.0	2.0	1.5	2.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		平均	2.0	1.0	1.0	4.0	3.0	3.0	2.0	1.0	1.0	1.0	1.0	1.0	1.8
pH値	原水	最大	7.5	7.5	7.4	7.4	7.4	7.4	7.7	7.7	7.6	7.6	7.6	7.7	
		最小	7.1	7.1	7.1	7.1	7.0	7.0	7.2	7.4	7.4	7.5	7.5	7.4	7.0
		平均	7.3	7.3	7.3	7.2	7.2	7.2	7.5	7.6	7.5	7.6	7.5	7.5	7.4
	配水	最大	7.4	7.4	7.5	7.2	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.5	7.5
		最小	7.0	7.1	7.2	7.0	6.8	6.9	7.1	7.3	7.3	7.3	7.3	7.3	6.8
		平均	7.3	7.3	7.3	7.1	7.1	7.1	7.3	7.4	7.4	7.4	7.4	7.4	7.3
アルカリ度 (mg/l)	原水	最大	15.5	15.5	18.5	17.0	18.5	14.5	18.0	21.0	21.5	21.0	20.5	21.5	
		最小	12.5	12.0	15.5	12.5	13.0	11.0	13.0	17.5	19.5	19.0	19.5	18.0	11.0
		平均	14.1	13.2	17.3	14.5	16.5	13.1	15.5	19.3	20.4	19.9	20.0	19.1	16.9
	配水	最大	15.0	15.0	18.0	17.0	18.5	13.5	17.0	20.0	20.5	20.0	20.0	19.5	20.5
		最小	11.5	11.0	15.5	11.0	11.0	10.5	11.5	16.0	18.5	18.0	18.5	17.0	10.5
		平均	13.7	12.8	16.8	13.7	15.3	12.1	14.3	18.0	19.4	19.0	19.2	18.2	16.0

上野浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.5	29.0	29.0	35.0	33.5	29.5	25.5	19.5	17.5	8.0	13.0	15.5	35.0	
	最小	10.0	16.0	18.5	24.0	26.0	18.0	14.5	10.0	3.0	2.5	3.5	7.5	2.5	
	平均	17.9	21.3	24.3	30.4	30.7	24.4	20.2	14.9	8.9	6.0	7.7	10.9	18.1	
原水水温 (°C)	最大	16.5	19.0	22.5	27.0	28.0	25.5	21.5	16.5	12.5	7.5	8.0	11.0	28.0	
	最小	11.5	16.0	19.0	23.0	25.0	20.5	16.5	12.5	7.0	5.4	5.5	8.0	5.4	
	平均	13.6	17.2	20.9	24.4	26.7	22.8	19.2	14.6	10.1	6.3	6.4	9.4	16.0	
濁度 (度)	原水	最大	27	8.8	6.9	52	255	79	25	7.0	4.3	2.8	3.0	3.8	255
		最小	3.9	3.4	2.3	4.6	4.2	5.0	5.2	2.8	2.1	1.8	2.0	2.3	1.8
		平均	6.5	5.1	4.0	16	42	21	9.3	4.2	2.9	2.2	2.5	3.1	9.9
	配水	最大	3.2	3.7	1.7	4.8	8.4	3.6	5.8	3.1	2.9	2.1	3.1	2.5	8.4
		最小	0.6	0.7	0.8	0.7	0.9	0.6	0.8	1.9	1.8	1.1	1.7	1.7	0.6
		平均	2.2	2.1	1.2	1.8	2.4	1.1	2.8	2.4	2.2	1.8	2.1	2.0	2.0
pH値	原水	最大	7.5	7.4	7.4	7.4	7.4	7.3	7.6	7.6	7.9	7.6	7.6	7.9	
		最小	7.2	7.2	7.3	7.1	7.1	7.0	7.2	7.4	7.5	7.4	7.4	7.4	7.0
		平均	7.3	7.3	7.4	7.2	7.3	7.2	7.4	7.5	7.6	7.5	7.5	7.5	7.4
	配水	最大	7.3	7.2	7.2	7.2	7.3	7.1	7.3	7.3	7.4	7.4	7.4	7.4	7.4
		最小	7.0	7.0	7.2	6.8	6.8	6.9	6.9	7.1	7.3	7.3	7.3	7.3	6.8
		平均	7.2	7.2	7.2	7.0	7.1	7.0	7.1	7.2	7.3	7.4	7.4	7.3	7.2
アルカリ度 (mg/l)	原水	最大	15.0	14.5	18.0	17.0	18.0	14.0	16.5	20.0	20.5	19.0	19.5	19.0	20.5
		最小	12.5	12.0	15.5	12.0	12.5	12.0	13.0	17.0	18.5	17.5	17.5	17.0	12.0
		平均	13.8	13.0	17.0	14.4	16.2	12.9	14.8	18.2	19.4	18.3	18.6	18.3	16.2
	配水	最大	14.0	14.0	17.0	16.0	17.5	12.0	14.5	19.0	19.0	18.5	18.5	18.0	19.0
		最小	10.0	10.5	15.0	9.0	9.5	10.0	10.0	15.0	17.0	16.5	17.5	16.5	9.0
		平均	12.7	12.0	16.2	12.1	14.2	10.8	12.7	16.7	18.0	17.6	17.9	17.4	14.9

知多浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	26.0	29.0	30.0	35.0	35.0	31.0	26.0	20.0	17.0	7.0	14.0	16.0	35.0	
	最小	10.0	14.0	18.0	24.0	26.0	17.0	15.0	10.0	3.0	0.0	2.0	7.0	0.0	
	平均	18.4	21.2	24.7	30.8	31.9	24.6	20.4	14.5	8.4	5.2	7.4	11.4	18.2	
原水水温 (°C)	最大	17.5	20.5	24.0	28.0	29.0	27.0	22.5	17.5	13.0	8.0	8.0	11.0	29.0	
	最小	11.9	17.0	20.5	24.0	26.0	22.0	18.0	13.0	8.0	6.0	5.5	8.0	5.5	
	平均	14.2	18.4	21.9	25.7	28.1	24.6	20.4	15.7	10.5	6.8	6.7	9.7	16.9	
濁度 (度)	原水	最大	7.4	6.5	4.6	7.1	46	13	127	5.4	5.9	29	18	3.7	127
		最小	2.9	2.8	1.9	3.5	3.9	5.1	1.8	2.8	1.8	1.5	2.1	2.0	1.5
		平均	5.2	4.2	3.5	5.0	13	7.7	9.6	3.8	3.2	4.3	3.3	2.9	5.5
	配水	最大	7.3	6.4	4.5	6.5	9.6	8.5	8.9	4.8	2.3	3.3	3.3	2.8	9.6
		27.5	1.4	1.8	1.3	2.6	0.9	0.9	0.3	0.7	0.6	0.6	0.9	0.9	0.3
		平均	3.6	4.1	3.6	4.9	3.6	4.0	4.5	2.8	1.2	1.3	1.7	2.0	3.1
pH値	原水	最大	7.6	7.2	7.1	7.1	7.5	7.1	7.7	7.7	7.8	7.8	7.8	7.5	7.8
		最小	7.1	7.0	7.0	6.8	7.0	6.9	7.1	7.3	7.5	7.3	7.3	7.3	6.8
		平均	7.3	7.1	7.1	6.9	7.2	7.0	7.2	7.5	7.7	7.5	7.5	7.4	7.3
	配水	最大	7.5	7.2	7.3	7.2	7.3	7.2	7.4	7.5	7.5	7.5	7.4	7.4	7.5
		最小	7.1	7.0	7.0	6.7	6.8	6.9	7.1	7.3	7.0	7.2	7.1	7.2	6.7
		平均	7.3	7.1	7.1	7.0	7.1	7.0	7.2	7.4	7.4	7.4	7.4	7.3	7.2
アルカリ度 (mg/l)	原水	最大	17.0	15.5	19.0	17.5	19.0	17.0	18.0	20.0	22.0	22.0	21.5	21.0	22.0
		最小	14.5	13.5	14.5	12.5	15.5	13.0	13.5	15.0	19.0	18.5	18.5	18.0	12.5
		平均	15.5	14.3	16.7	15.8	17.3	14.5	14.8	17.9	19.9	19.9	20.1	19.6	17.2
	配水	最大	18.0	16.5	23.0	19.0	23.5	15.0	20.0	21.5	20.0	20.0	20.0	20.5	23.5
		最小	14.5	13.0	14.5	14.0	12.0	13.0	13.5	15.0	17.5	18.0	18.0	18.0	12.0
		平均	15.5	14.5	17.2	15.9	16.3	13.9	14.8	17.6	18.7	18.8	19.1	19.0	16.8

尾張西部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	24.5	26.3	28.8	35.6	34.0	29.9	25.9	19.4	14.8	7.5	12.7	15.9	35.6	
	最小	7.8	16.0	19.6	23.2	24.7	18.6	15.0	7.9	-0.1	-0.8	1.8	4.0	-0.8	
	平均	17.9	20.6	24.5	30.1	30.8	24.4	20.1	14.6	8.0	5.0	7.5	10.3	17.8	
原水水温 (°C)	最大	16.0	20.7	24.5	28.5	30.0	26.1	19.4	16.6	12.8	7.0	9.4	11.9	30.0	
	最小	11.0	14.6	12.5	18.5	24.2	19.0	15.6	12.0	7.1	5.3	5.9	8.8	5.3	
	平均	13.2	17.0	21.6	23.8	27.4	21.0	17.9	14.3	9.7	6.2	7.2	10.2	15.8	
濁度 (度)	原水	最大	48	19	330	164	186	125	80	5.3	6.9	9.2	2.3	2.0	330
		最小	2.0	2.0	1.3	9.0	2.2	3.7	0.9	1.4	1.0	0.9	0.8	0.6	0.6
		平均	7.2	5.8	14	45	30	24	7.7	2.2	2.2	1.6	1.4	1.3	11
	配水	最大	0.8	0.4	0.5	0.5	0.7	0.8	0.7	0.3	0.3	0.2	0.5	0.5	0.8
		最小	0.1	0.1	0.1	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1
		平均	0.3	0.2	0.2	0.3	0.3	0.5	0.3	0.2	0.2	0.1	0.2	0.2	0.3
pH値	原水	最大	7.5	7.6	7.6	7.2	7.2	7.3	7.7	7.6	7.6	7.6	7.2	7.7	
		最小	6.6	6.9	6.5	6.5	6.7	6.8	6.9	7.3	7.2	7.3	7.2	7.0	
		平均	7.1	7.2	7.2	6.8	7.0	7.1	7.3	7.4	7.4	7.4	7.3	7.2	7.2
	配水	最大	7.4	7.4	7.4	7.3	7.2	7.2	7.3	7.3	7.3	7.3	7.2	7.2	7.4
		最小	7.0	7.2	7.1	7.0	7.0	7.0	7.0	7.2	7.1	7.1	7.1	7.0	7.0
		平均	7.2	7.3	7.3	7.2	7.1	7.1	7.2	7.3	7.2	7.2	7.2	7.1	7.2
アルカ度 (mg/l)	原水	最大	20.5	22.0	26.0	21.0	24.5	19.5	24.5	27.0	28.0	25.5	26.0	26.0	28.0
		最小	9.5	14.0	15.0	8.5	12.5	12.0	12.5	21.0	21.5	21.0	22.5	20.0	8.5
		平均	17.0	17.0	21.6	16.0	18.8	16.0	20.1	25.2	24.3	23.6	24.3	22.9	20.6
	配水	最大	18.0	17.0	21.0	17.0	20.5	17.5	20.0	24.0	23.0	22.0	24.0	22.5	24.0
		最小	10.0	12.0	13.0	10.0	12.0	11.0	12.0	16.0	17.0	17.0	18.0	17.0	10.0
		平均	14.3	14.1	18.1	13.9	16.3	14.4	16.3	20.0	20.2	19.1	19.9	18.7	17.1

安城浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	24.4	31.2	30.8	36.3	37.1	29.6	27.5	21.1	18.2	9.7	15.4	18.0	37.1	
	最小	11.5	17.3	18.7	24.2	26.8	18.1	17.0	11.5	3.1	2.1	3.4	8.0	2.1	
	平均	19.2	22.3	25.5	31.3	32.0	25.1	21.7	16.2	9.8	6.9	9.2	12.5	19.3	
原水水温 (°C)	最大	16.8	19.7	23.8	28.2	28.7	25.2	20.3	16.0	13.0	6.8	9.6	12.3	28.7	
	最小	12.3	14.8	17.0	18.3	24.0	19.2	15.0	11.8	6.8	5.0	5.3	9.1	5.0	
	平均	14.1	16.7	20.7	24.6	27.0	21.8	17.8	13.9	9.8	6.0	7.0	10.5	15.8	
濁度 (度)	原水	最大	60	70	19	52	23	80	48	18	5.0	3.0	4.0	18	80
		最小	3.0	3.0	3.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	2.0	1.0
		平均	8.0	11	7.0	9.0	4.0	14	9.0	2.0	2.0	2.0	3.0	4.0	6.3
	配水	最大	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		最小	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		平均	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
pH値	原水	最大	7.4	7.4	7.5	7.4	7.3	7.3	7.5	8.1	8.4	7.7	7.7	7.5	8.4
		最小	7.1	7.1	7.1	7.1	6.9	6.8	7.1	7.3	7.3	7.4	7.3	7.2	6.8
		平均	7.3	7.3	7.3	7.3	7.2	7.2	7.3	7.5	7.5	7.5	7.5	7.4	7.4
	配水	最大	7.1	7.1	6.9	7.0	7.0	6.9	7.0	7.1	7.2	7.2	7.1	7.2	7.2
		最小	6.9	6.8	6.8	6.7	6.6	6.6	6.8	6.9	7.0	7.0	7.0	7.0	6.6
		平均	7.0	6.9	6.9	6.8	6.9	6.8	6.9	7.0	7.1	7.1	7.1	7.1	7.0
アルカ度 (mg/l)	原水	最大	26.0	21.5	24.5	23.0	24.5	21.0	23.0	26.5	27.5	27.0	27.0	26.5	27.5
		最小	15.0	15.5	19.0	14.0	18.0	11.0	14.0	21.0	23.0	24.0	25.0	25.0	11.0
		平均	20.6	18.2	22.1	20.1	22.1	17.4	19.6	24.7	25.2	25.4	25.7	25.6	22.2
	配水	最大	20.0	18.0	21.0	18.0	19.5	17.0	18.5	22.0	22.5	22.0	22.0	22.5	22.5
		最小	14.0	13.0	15.0	12.0	12.5	10.5	12.0	18.0	19.0	20.0	21.0	20.5	10.5
		平均	16.5	14.8	17.4	15.7	17.2	13.7	15.9	19.8	20.7	21.4	21.3	21.6	18.0

豊橋南部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.7	25.2	27.6	32.6	33.4	29.2	26.4	19.9	18.3	8.5	13.0	16.6	33.4	
	最小	8.9	15.7	18.3	24.7	25.2	18.8	16.3	11.1	3.7	4.3	3.7	7.2	3.7	
	平均	17.5	20.6	23.5	29.1	29.9	24.7	20.4	15.3	9.7	6.5	8.1	11.3	18.1	
原水水温 (°C)	最大	15.5	18.0	21.1	23.6	25.5	25.0	22.5	18.3	15.0	9.3	8.7	11.5	25.5	
	最小	11.8	14.5	17.5	21.0	23.7	22.0	18.5	14.5	9.5	6.9	6.5	8.7	6.5	
	平均	13.2	16.1	19.7	22.2	24.5	23.7	20.8	16.6	12.3	8.0	7.4	10.1	16.2	
濁度 (度)	原水	最大	8.3	1.8	3.6	9.0	3.4	28	8.7	1.7	3.2	3.2	2.0	1.9	28
		最小	1.1	0.7	1.0	1.0	0.6	0.6	1.3	0.8	1.3	1.4	1.1	0.8	0.6
		平均	2.1	1.2	1.6	2.5	1.5	2.4	2.4	1.2	1.9	1.9	1.4	1.3	1.8
	配水	最大	0.2	0.2	0.2	0.4	0.3	0.2	0.2	0.1	0.1	0.2	0.2	0.2	0.4
		27.5	0.0	0.1	0.1	0.1	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0
		平均	0.1	0.1	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
pH値	原水	最大	7.5	7.3	7.4	7.3	7.5	7.4	8.0	7.7	7.8	7.7	7.6	7.5	8.0
		最小	7.1	7.1	7.2	7.1	7.1	7.0	7.2	7.4	7.5	7.6	7.4	7.4	7.0
		平均	7.3	7.2	7.3	7.2	7.3	7.2	7.5	7.5	7.6	7.6	7.5	7.5	7.4
	配水	最大	7.1	7.1	7.1	7.1	7.1	7.2	7.1	7.1	7.2	7.2	7.2	7.2	7.2
		最小	7.0	6.9	6.9	6.9	6.9	6.8	6.9	7.0	7.0	7.1	7.1	7.1	6.8
		平均	7.0	7.0	7.0	7.0	7.0	7.0	7.0	7.1	7.1	7.2	7.2	7.1	7.1
アルカ度 (mg/l)	原水	最大	20.5	19.0	20.5	26.5	23.0	18.5	20.0	20.5	19.0	19.0	19.0	20.0	26.5
		最小	15.5	15.0	14.0	15.0	14.0	15.0	15.5	17.5	17.0	17.0	17.0	17.0	14.0
		平均	17.8	17.2	17.4	17.9	17.5	16.9	17.9	18.7	17.8	18.0	17.9	17.9	17.7
	配水	最大	17.0	15.5	15.5	19.0	19.0	14.0	15.0	15.5	16.0	16.0	16.0	16.0	19.0
		最小	12.0	12.0	11.0	10.5	11.0	11.0	10.0	12.5	13.5	12.5	13.0	14.0	10.0
		平均	14.0	13.5	13.3	13.9	13.3	12.7	13.0	14.1	14.2	14.5	14.8	14.8	13.8

蒲郡浄水場(工水)

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.0	27.0	27.5	33.0	32.5	28.0	26.5	20.5	18.0	10.0	14.0	17.0	33.0	
	最小	11.5	17.0	21.0	25.0	25.0	20.0	17.5	13.0	5.0	5.5	5.0	9.0	5.0	
	平均	18.1	21.1	24.0	29.2	30.0	24.9	21.2	16.4	10.9	8.1	9.6	12.4	18.8	
原水水温 (°C)	最大	19.5	18.0	20.0	25.0	25.5	24.0	21.8	17.2	14.5	10.7	10.2	12.0	25.5	
	最小	12.3	14.0	17.2	19.1	22.7	20.6	17.2	13.9	10.2	7.4	7.4	9.7	7.4	
	平均	14.3	16.1	18.9	22.4	23.8	22.2	19.5	15.6	12.1	8.7	8.5	10.8	16.1	
濁度 (度)	原水	最大	8.0	9.5	2.5	1.9	2.7	1.9	1.8	2.1	0.7	1.0	5.2	3.6	9.5
		最小	0.3	0.4	0.5	0.4	0.7	0.5	0.3	0.2	0.2	0.2	0.3	0.5	0.2
		平均	1.2	1.3	1.1	1.0	1.3	1.0	0.9	0.5	0.4	0.4	1.1	1.1	0.9
	配水	最大	0.2	0.2	0.4	0.5	0.8	0.7	0.5	0.1	0.2	0.3	0.4	0.2	0.8
		最小	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
		平均	0.1	0.1	0.2	0.2	0.3	0.3	0.2	0.1	0.1	0.1	0.2	0.1	0.2
pH値	原水	最大	7.4	7.3	7.3	7.4	7.4	7.3	7.4	7.5	7.4	7.5	7.4	7.5	7.5
		最小	7.2	7.1	7.1	7.0	7.1	6.9	7.1	7.3	7.3	7.3	7.3	7.3	6.9
		平均	7.3	7.2	7.2	7.2	7.2	7.2	7.3	7.4	7.4	7.4	7.4	7.4	7.3
	配水	最大	7.3	7.4	7.2	7.3	7.3	7.3	7.3	7.3	7.4	7.3	7.2	7.3	7.4
		最小	7.1	7.0	7.1	7.0	7.1	7.1	7.1	7.1	7.1	7.1	7.0	7.2	7.0
		平均	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.1	7.2	7.2
アルカリ度 (mg/l)	原水	最大	27.0	29.0	23.0	27.0	27.0	24.0	26.0	24.0	25.0	23.0	21.0	23.0	29.0
		最小	19.0	19.0	18.0	17.0	16.0	18.0	19.0	19.0	19.0	18.0	18.0	19.0	16.0
		平均	21.3	22.8	19.8	20.8	19.2	20.4	22.1	23.0	21.3	20.4	19.8	20.4	20.9
	配水	最大	22.0	24.0	21.0	25.0	25.0	22.0	22.5	23.0	21.0	20.0	19.0	20.0	25.0
		最小	18.0	17.0	17.0	15.0	14.0	16.0	18.0	18.0	15.0	16.0	17.0	17.0	14.0
		平均	19.1	20.1	17.7	18.6	17.3	19.1	20.3	20.6	18.5	17.7	17.8	18.2	18.8