

6 浄水場毎日検査

(1)水道用水毎日検査

上野浄水場	201	豊田浄水場	204
知多浄水場	201	幸田浄水場	204
高蔵寺浄水場	202	豊橋浄水場	205
尾張東部浄水場	202	豊橋南部浄水場	205
犬山浄水場	203	豊川浄水場	206
尾張西部浄水場	203		

(2)工業用水毎日検査

上野浄水場	207
知多浄水場	207
尾張東部浄水場(東郷)	207
尾張西部浄水場	208
安城浄水場	208
豊橋南部浄水場	208
蒲郡浄水場(工水)	209

(1)水道用水毎日検査

上野浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.0	25.6	27.8	31.9	33.8	28.5	27.2	19.2	13.4	9.0	9.3	17.8	33.8	
	最小	10.4	13.8	19.4	23.3	22.9	19.5	14.1	8.6	0.2	1.2	0.9	6.5	0.2	
	平均	16.2	20.6	24.7	28.9	28.6	25.5	20.9	14.1	8.5	4.7	5.2	11.5	17.5	
原水水温 (°C)	最大	15.0	18.1	23.4	25.2	25.6	23.0	21.7	16.4	11.7	6.7	6.8	11.4	25.6	
	最小	11.8	14.5	17.5	20.9	22.1	21.1	16.6	11.3	6.9	4.4	4.5	6.2	4.4	
	平均	13.7	16.1	19.8	22.6	23.7	21.7	20.0	14.2	9.4	5.3	5.4	8.6	15.0	
濁度 (度)	原水	最大	6.3	28.9	12.1	8.5	92.4	24.5	7.9	4.1	6.2	3.0	2.5	5.4	92.4
		最小	3.1	2.9	3.6	3.3	3.9	3.1	2.6	2.3	2.5	1.7	1.6	1.8	1.6
		平均	4.9	8.9	6.0	5.6	24.8	9.5	4.5	3.1	3.7	2.2	1.9	2.8	6.5
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	3.5	6.4	4	5	15.0	5.4	3.9	3.0	7.3	2.8	2.0	2.9	15.0
		最小	2.0	1.6	2.7	3.7	3.0	2.4	2.0	1.4	2.2	1.4	1.0	1.0	1.0
		平均	2.8	3.4	3.4	4.3	6.5	3.5	2.6	2.0	3.1	1.8	1.4	1.7	3.0
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.5	7.5	7.4	7.4	7.5	7.5	7.6	7.6	7.5	7.5	7.5	7.6
		最小	7.2	7.1	7.2	7.1	7.1	7.2	7.3	7.3	7.4	7.3	7.4	7.3	7.1
		平均	7.4	7.3	7.4	7.3	7.2	7.4	7.4	7.5	7.4	7.4	7.4	7.4	7.4
	浄水	最大	7.4	7.4	7.3	7.2	7.1	7.3	7.3	7.4	7.4	7.4	7.5	7.4	7.5
		最小	7.3	7.3	7.1	7.0	7.0	7.0	7.2	7.2	7.3	7.3	7.3	7.4	7.0
		平均	7.4	7.4	7.2	7.1	7.0	7.1	7.2	7.4	7.4	7.4	7.4	7.4	7.3
総アルカリ度 (mg/l)	原水	最大	15.5	15.0	15.5	16.5	16.5	17.0	20.0	21.0	20.0	19.5	20.0	21.5	21.5
		最小	14.0	13.0	13.0	13.0	13.5	14.0	17.0	20.0	17.5	17.0	19.0	17.0	13.0
		平均	14.7	14.0	14.5	14.7	14.7	15.0	18.4	20.6	18.5	18.3	19.6	19.8	16.9
	浄水	最大	15.0	15.5	14.5	15.5	14.0	16.0	18.0	20.0	19.0	18.0	19.0	20.5	20.5
		最小	13.5	12.5	12.5	12.5	12.0	12.0	15.5	18.5	16.0	16.0	17.5	16.5	12.0
		平均	14.5	13.9	13.7	13.5	13.0	13.6	17.0	19.4	17.3	17.1	18.4	18.8	15.9
KMnO ₄ 消費量 (mg/l)	原水	最大	4.9	8.8	5.0	5.9	12.0	5.9	4.7	4.4	4.9	3.6	3.1	4.1	12.0
		最小	3.0	3.3	3.6	3.9	4.1	3.1	3.0	2.7	3.0	2.2	2.2	2.0	2.0
		平均	4.1	4.7	4.1	4.8	6.0	4.2	3.7	3.2	3.9	2.7	2.7	2.8	3.9
	浄水	最大	1.1	1.1	1.2	1.2	1.4	1.2	1.2	1.3	1.4	1.1	1.1	1.2	1.4
		最小	0.6	0.6	0.6	0.8	0.8	0.8	0.8	0.6	0.6	0.6	0.3	0.6	0.3
		平均	1.0	0.9	0.9	1.0	1.0	0.9	0.9	1.0	1.0	0.8	0.9	0.9	0.9
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.5	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.6
		最小	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.5	0.4	0.4	0.4
		平均	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5

知多浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.0	26.0	29.0	34.0	35.0	28.5	29.0	19.0	12.0	15.5	12.0	17.0	35.0	
	最小	11.0	11.0	19.5	20.0	24.0	20.0	15.0	8.0	-1.0	0.0	1.0	4.5	-1.0	
	平均	16.3	20.8	25.0	29.8	29.3	25.7	21.7	13.5	7.5	4.6	4.9	11.0	17.5	
原水水温 (°C)	最大	18.1	20.8	25.5	31.0	31.3	26.4	25.4	18.3	13.2	8.3	9.6	18.6	31.3	
	最小	13.7	15.7	19.0	21.9	21.3	22.8	17.8	12.8	9.0	7.0	7.9	9.2	7.0	
	平均	16.3	18.1	23.1	26.4	26.2	23.8	22.4	16.5	11.3	7.7	8.5	12.1	17.7	
濁度 (度)	原水	最大	12.7	43.4	22.4	15.0	79.3	12.8	11.8	8.8	8.7	7.6	8.6	36.4	79.3
		最小	2.9	3.3	5.3	5.3	3.7	3.6	2.8	3.1	2.6	2.0	2.5	4.1	2.0
		平均	5.5	11.1	8.7	8.5	17.0	5.7	6.4	6.2	5.6	3.7	3.7	8.2	7.5
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	12.6	30.0	17.2	9.6	35.8	10.5	10.0	8.2	10.0	5.3	5.0	17.6	35.8
		最小	2.4	3.5	4.5	4.1	3.3	3.0	3.5	4.0	2.9	3.0	2.7	2.3	2.3
		平均	4.8	8.4	6.5	6.7	10.2	5.4	5.2	5.4	6.1	3.7	3.4	5.4	5.9
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.7	7.4	8.0	8.5	8.2	7.9	9.0	8.5	7.5	7.5	7.6	8.3	9.0
		最小	7.0	7.0	6.9	6.9	6.9	6.9	7.0	7.3	7.2	7.4	7.4	7.0	6.9
		平均	7.3	7.2	7.3	7.4	7.3	7.3	8.1	7.6	7.3	7.5	7.5	7.4	7.4
	浄水	最大	7.4	7.3	7.3	7.3	7.3	7.3	7.5	7.4	7.4	7.4	7.4	7.4	7.5
		最小	7.1	7.2	7.0	7.0	7.1	7.0	7.1	7.3	7.3	7.3	7.3	7.3	7.0
		平均	7.2	7.2	7.2	7.1	7.3	7.1	7.3	7.4	7.4	7.4	7.4	7.4	7.3
総アルカリ度 (mg/l)	原水	最大	34.0	29.0	33.0	35.0	38.5	31.5	41.5	42.0	36.0	38.0	39.0	38.0	42.0
		最小	15.0	13.0	15.5	21.0	15.0	18.5	30.0	30.0	23.5	33.5	34.5	13.5	13.0
		平均	25.7	21.9	26.3	28.2	27.5	26.4	36.5	38.4	31.7	35.4	37.1	29.5	30.4
	浄水	最大	30.0	29.0	31.5	33.0	37.5	31.5	37.5	40.5	35.0	36.0	37.5	36.0	40.5
		最小	16.0	15.0	17.0	23.5	17.0	20.0	27.0	30.0	23.5	30.5	33.5	15.5	15.0
		平均	24.9	22.4	25.6	27.6	26.9	26.1	32.9	36.5	31.0	33.4	35.0	28.8	29.3
KMnO ₄ 消費量 (mg/l)	原水	最大	6.9	12.0	6.3	7.9	9.1	6.3	6.6	6.6	6.0	4.7	5.3	7.2	12.0
		最小	2.5	2.5	2.5	1.6	2.8	2.5	2.5	3.1	2.2	2.5	2.5	2.2	1.6
		平均	3.4	4.1	4.3	4.9	5.5	3.8	4.4	4.7	3.9	3.5	3.5	4.2	4.2
	浄水	最大	1.9	2.5	1.9	5.7	1.9	1.9	2.2	2.2	1.9	2.2	2.2	2.2	5.7
		最小	0.6	0.6	0.6	0.9	0.2	0.3	0.3	0.6	0.6	0.6	0.9	0.3	0.2
		平均	1.2	1.0	1.2	1.4	1.1	0.9	1.0	1.4	1.2	1.4	1.3	1.1	1.2
残留塩素 (mg/l)	浄水	最大	0.6	0.5	0.6	0.7	0.7	0.7	0.6	0.7	0.6	0.5	0.5	0.5	0.7
		最小	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.4
		平均	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.5	0.4	0.4	0.5	0.5

高蔵寺浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.1	26.7	29.5	32.3	35.0	28.8	28.3	24.0	13.7	10.4	11.7	19.3	35.0	
	最小	11.6	13.7	18.8	23.5	23.1	19.3	14.7	8.8	-0.1	1.9	-0.7	6.7	-0.7	
	平均	17.0	21.0	24.8	29.3	28.8	25.6	22.0	15.7	8.8	5.0	5.6	12.7	18.0	
原水水温 (°C)	最大	14.8	17.0	20.3	24.6	26.0	22.1	21.3	15.2	11.1	7.0	6.9	11.1	26.0	
	最小	12.0	12.8	17.0	19.0	19.3	19.1	15.1	11.2	6.7	4.2	5.0	6.2	4.2	
	平均	13.3	15.0	18.9	21.7	22.0	20.3	19.4	13.5	8.8	5.2	5.9	8.7	14.4	
濁度 (度)	原水	最大	12.7	225.0	18.9	20.6	850.4	75.2	23.3	6.1	12.0	3.8	2.5	20.7	850.4
		最小	2.3	3.2	2.2	2.3	2.5	2.2	1.2	1.5	1.0	1.6	1.8	1.0	
		平均	4.7	19.1	5.5	8.6	68.4	11.5	4.0	2.3	3.1	2.0	2.1	5.4	11.4
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	9.0	105	14	16	523.0	28.0	14	6.0	6.0	4.0	3.0	14	523
		最小	3.0	3.0	3.0	3.0	4.0	4.0	2.0	2.0	2.0	1.0	2.0	2.0	1.0
		平均	4.1	11.1	4.4	6.2	38.7	7.8	4.5	3.0	3.5	2.1	2.2	3.7	7.6
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.3	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.4	7.3	7.4	7.3	7.4
		最小	7.1	6.7	7.1	7.0	6.9	7.0	7.0	7.1	7.0	7.1	7.1	6.9	6.7
		平均	7.2	7.1	7.2	7.1	7.2	7.3	7.2	7.3	7.2	7.2	7.2	7.2	7.2
	浄水	最大	7.3	7.4	7.4	7.3	7.2	7.3	7.3	7.3	7.3	7.4	7.3	7.4	7.4
		最小	7.1	7.2	7.1	7.1	7.0	7.1	7.2	7.2	7.2	7.2	7.2	7.2	7.0
		平均	7.3	7.3	7.3	7.2	7.2	7.2	7.2	7.2	7.3	7.3	7.3	7.3	7.3
総アルカリ度 (mg/l)	原水	最大	17.5	16.5	16.5	17.0	17.0	18.5	22.0	23.0	21.0	20.5	21.0	22.5	23.0
		最小	11.5	8.5	10.0	10.5	9.0	9.0	15.0	16.5	15.0	17.5	19.0	12.0	8.5
		平均	14.3	12.1	14.2	13.5	13.3	14.9	18.9	21.3	17.4	18.9	20.1	18.8	16.5
	浄水	最大	17.5	16.0	16.0	16.5	16.5	17.5	21.0	22.5	20.0	20.0	21.0	22.0	22.5
		最小	11.5	9.0	10.0	11.0	9.5	10.5	15.5	17.0	15.5	17.5	19.0	13.5	9.0
		平均	14.1	12.4	14.0	13.4	13.2	14.4	18.1	20.7	17.2	18.5	19.8	18.7	16.2
KMnO ₄ 消費量 (mg/l)	原水	最大	6.4	49.0	7.5	8.5	87.0	15.4	7.5	5.4	6.0	4.0	3.5	7.0	87.0
		最小	2.5	3.0	3.0	3.2	3.2	1.3	2.3	2.6	2.0	2.3	1.8	2.0	1.3
		平均	4.0	7.7	4.4	5.3	12.6	4.9	3.4	3.3	3.5	2.9	2.7	3.3	4.8
	浄水	最大	1.5	1.7	1.9	1.7	1.7	1.5	1.4	1.7	1.9	1.7	1.4	1.7	1.9
		最小	0.6	0.6	0.9	0.8	0.9	0.1	0.5	0.8	0.6	0.9	0.6	0.6	0.1
		平均	1.1	1.2	1.2	1.3	1.3	0.8	1.0	1.3	1.2	1.2	1.0	1.0	1.1
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.5	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.6
		最小	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
		平均	0.5	0.5	0.4	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5

尾張東部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.8	26.5	28.4	31.7	25.3	26.9	24.8	17.6	11.5	7.6	7.4	16.1	31.7	
	最小	11.4	14.1	19.5	23.3	19.8	19.7	12.5	6.7	0.7	0.6	0.2	4.4	0.2	
	平均	16.4	20.9	24.7	28.7	22.0	23.5	19.2	12.2	6.8	3.4	3.8	10.2	16.0	
原水水温 (°C)	最大	15.2	17.0	20.5	24.0	25.0	22.0	21.0	15.0	11.0	8.5	7.0	11.0	25.0	
	最小	12.0	13.2	16.5	19.0	19.5	19.0	15.5	10.5	7.0	4.0	4.5	6.0	4.0	
	平均	13.6	15.2	18.7	21.4	22.0	20.4	19.3	13.6	8.9	6.0	5.8	8.4	14.4	
濁度 (度)	原水	最大	11.2	147.2	25.3	26.5	593.4	91.6	25.1	5.4	12.3	5.0	2.9	18.5	593.4
		最小	3.0	3.6	2.5	2.6	2.8	2.6	1.5	1.6	1.6	1.0	1.7	1.8	1.0
		平均	5.3	19.2	5.9	7.8	66.2	11.8	4.4	2.2	3.2	2.1	2.2	5.0	11.3
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	8.3	90.4	10.3	10.9	191.1	27.5	10.1	6.0	5.8	5.0	2.7	7.1	191.1
		最小	2.7	3.5	3.4	3.2	2.5	2.2	1.8	2.1	1.8	1.8	1.7	2.0	1.7
		平均	4.5	11.2	4.9	5.7	25.5	5.9	3.6	2.9	3.4	2.3	2.2	3.4	6.3
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.6	7.6	7.7	7.6	7.6	7.7	7.7	7.6	7.5	7.5	7.6	7.6	7.7
		最小	7.1	7.0	7.2	7.1	7.1	7.2	7.2	7.1	7.2	7.4	7.3	7.2	7.0
		平均	7.4	7.3	7.5	7.4	7.3	7.5	7.5	7.5	7.4	7.4	7.5	7.4	7.4
	浄水	最大	7.3	7.3	7.3	7.4	7.3	7.3	7.2	7.3	7.3	7.3	7.3	7.3	7.4
		最小	7.1	7.1	7.1	7.0	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.0
		平均	7.1	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2	7.2
総アルカリ度 (mg/l)	原水	最大	17.5	16.5	16.5	17.0	17.5	18.0	22.0	23.0	20.5	20.0	21.0	22.5	23.0
		最小	11.5	8.0	9.5	10.0	10.0	10.0	15.5	17.0	15.0	17.0	18.5	12.5	8.0
		平均	14.6	12.5	14.6	13.9	13.6	15.1	19.1	21.5	17.2	18.6	19.8	18.6	16.6
	浄水	最大	16.0	15.5	14.5	15.0	15.5	15.5	19.5	21.0	19.0	18.0	19.0	20.0	21.0
		最小	11.0	9.0	10.0	10.5	9.5	10.0	14.0	16.0	14.0	15.0	16.0	12.0	9.0
		平均	13.3	12.0	13.0	12.5	12.8	13.5	16.8	19.2	15.6	16.4	17.4	16.9	15.0
KMnO ₄ 消費量 (mg/l)	原水	最大	5.9	31.8	8.3	9.9	66.0	19.5	7.6	4.8	6.3	3.9	3.9	6.6	66.0
		最小	1.0	2.6	2.8	2.6	3.4	2.2	1.9	2.0	2.2	1.8	2.0	2.0	1.0
		平均	3.6	6.7	4.2	5.0	11.3	5.1	3.8	2.9	3.6	2.6	2.7	3.3	4.6
	浄水	最大	4.2	1.6	1.2	1.6	1.2	1.5	2.3	1.7	1.9	1.7	1.4	1.6	4.2
		最小	0.3	0.1	0.3	0.1	0.3	0.1	0.1	0.1	0.6	0.3	0.2	0.5	0.1
		平均	1.1	0.8	0.8	0.8	0.8	0.8	1.0	0.8	1.1	0.8	0.8	0.9	0.9
残留塩素 (mg/l)	浄水	最大	0.7	0.6	0.6	0.6	0.7	0.7	0.6	0.6	0.6	0.6	0.5	0.7	
		最小	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.5	0.4	0.5	
		平均	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	

犬山浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.8	25.6	27.8	31.5	34.3	27.8	27.5	18.4	14.3	9.4	10.3	17.0	34.3	
	最小	10.7	13.3	19.1	23.6	23.3	18.9	12.9	8.3	0.3	1.5	1.4	5.6	0.3	
	平均	16.2	20.1	24.8	28.6	28.5	24.8	20.9	13.9	8.2	4.3	4.8	11.7	17.2	
原水水温 (°C)	最大	13.8	16.3	20.2	23.7	25.2	21.6	21.0	14.6	11.3	5.9	5.8	10.5	25.2	
	最小	11.1	12.1	16.6	19.0	19.1	19.4	14.6	10.2	6.3	4.2	4.5	5.7	4.2	
	平均	12.3	14.5	18.6	21.3	21.6	20.1	18.7	12.9	8.3	4.8	5.2	8.0	13.9	
濁度 (度)	原水	最大	17.7	94.6	12.1	17.9	820.0	56.7	12.2	3.2	7.1	2.4	3.4	11.9	820.0
		最小	1.7	1.9	1.3	1.7	2.2	2.0	1.2	1.1	1.3	1.0	1.3	1.6	1.0
		平均	4.1	12.9	3.6	5.5	63.3	8.4	2.9	1.8	2.6	1.5	1.6	4.4	9.4
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	7.4	73.1	5.8	8.4	300.0	22.5	6.3	5.4	7.6	2.1	3.4	6.2	300.0
		最小	1.9	1.9	2.0	2.2	2.4	2.4	2.0	2.3	1.4	1.2	1.4	1.4	1.2
		平均	2.9	7.2	2.9	3.8	26.8	5.0	3.2	3.2	2.9	1.6	1.8	2.8	5.3
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.4	7.3	7.3	7.2	7.3	7.4	7.4	7.5	7.5	7.4	7.4	7.4	7.5
		最小	7.2	7.0	7.1	7.0	6.8	7.0	7.1	7.2	7.2	7.3	7.2	7.1	6.8
		平均	7.3	7.2	7.2	7.1	7.1	7.2	7.3	7.4	7.4	7.3	7.3	7.3	7.3
	浄水	最大	7.4	7.4	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.3	7.3	7.2	7.2	7.1	7.1	7.2	7.3	7.3	7.3	7.3	7.3	7.1
		平均	7.3	7.3	7.3	7.2	7.2	7.2	7.3	7.3	7.3	7.4	7.4	7.3	7.3
総アルカリ度 (mg/l)	原水	最大	17.0	16.0	16.5	16.5	17.0	16.5	22.0	22.5	21.5	20.9	23.6	23.1	23.6
		最小	11.5	8.5	10.5	10.5	8.0	9.5	16.0	17.5	15.5	18.0	19.8	13.1	8.0
		平均	14.8	12.2	14.4	13.6	13.1	14.4	19.1	21.2	17.6	19.3	21.4	18.9	16.7
	浄水	最大	17.0	15.5	16.5	15.5	16.0	16.0	21.5	21.5	20.5	19.4	21.7	22.0	22.0
		最小	12.0	9.0	11.5	11.0	9.5	10.0	16.0	17.0	15.0	17.5	19.2	13.0	9.0
		平均	14.9	12.4	14.3	13.3	13.0	14.0	18.5	20.4	17.0	18.2	20.3	18.6	16.2
KMnO ₄ 消費量 (mg/l)	原水	最大	8.8	31.9	5.7	7.9	51.2	15.6	6.3	5.9	6.9	3.8	4.3	7.4	51.2
		最小	2.8	2.8	2.8	3.2	3.5	2.9	2.8	2.8	2.8	2.5	2.5	2.8	2.5
		平均	3.7	5.4	3.6	4.7	8.2	4.4	3.6	3.7	4.0	3.1	3.4	3.8	4.3
	浄水	最大	1.6	1.6	1.6	1.9	1.6	1.6	1.6	1.9	2.5	1.9	1.6	1.8	2.5
		最小	0.6	0.9	0.6	0.9	0.6	0.9	0.6	0.9	0.9	0.9	0.9	0.9	0.6
		平均	1.0	1.2	1.0	1.4	1.0	1.1	1.2	1.4	1.6	1.4	1.2	1.3	1.2
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.5	0.6	0.7	0.6	0.7	0.5	0.5	0.5	0.5	0.5	0.7
		最小	0.5	0.5	0.5	0.3	0.5	0.6	0.5	0.5	0.5	0.5	0.4	0.5	0.3
		平均	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5

尾張西部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.6	26.4	28.9	32.3	35.0	29.5	28.6	23.2	14.8	10.9	10.9	18.0	35.0	
	最小	13.2	13.3	19.4	19.8	22.9	19.2	13.4	6.0	0.1	-0.2	0.8	5.0	-0.2	
	平均	17.4	20.7	25.3	28.9	28.9	25.1	21.7	14.6	8.5	4.7	5.5	11.5	17.7	
原水水温 (°C)	最大	15.4	18.0	22.7	26.3	28.5	23.6	22.8	16.9	11.7	6.6	8.3	12.1	28.5	
	最小	9.9	12.9	17.6	19.9	18.6	20.1	16.6	11.1	6.5	4.3	5.4	7.1	4.3	
	平均	13.6	15.6	20.3	22.7	23.0	21.5	20.2	14.5	9.2	5.7	6.5	9.5	15.2	
濁度 (度)	原水	最大	11.4	146.3	10.8	16.7	280.0	46.8	5.6	6.2	7.2	6.4	2.2	14.9	280.0
		最小	2.1	2.0	2.3	3.4	3.7	2.0	1.6	1.3	1.3	1.1	1.3	1.6	1.1
		平均	4.2	13.7	5.3	7.1	39.2	8.9	3.1	2.5	2.9	2.0	1.7	4.1	7.9
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	6.5	56.2	6.8	6.9	114.0	23.2	5.7	4.4	8.0	3.8	3.3	8.1	114.0
		最小	1.9	2.5	2.4	2.7	3.0	3.0	2.1	1.7	2.2	1.5	2.0	1.5	1.5
		平均	3.4	6.9	3.7	4.1	17.3	5.4	3.3	2.6	3.5	2.2	2.5	3.3	4.9
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.5	7.5	7.3	7.4	7.6	7.7	7.5	7.6	7.6	7.9	7.5	7.9
		最小	7.1	6.9	6.9	6.8	6.7	6.9	7.1	7.3	7.3	7.4	7.5	7.1	6.7
		平均	7.3	7.2	7.2	7.1	7.1	7.2	7.3	7.4	7.4	7.5	7.7	7.4	7.3
	浄水	最大	7.5	7.5	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.5
		最小	7.2	7.3	7.2	7.1	7.3	7.1	7.3	7.3	7.3	7.3	7.3	7.1	7.1
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
総アルカリ度 (mg/l)	原水	最大	19.5	18.5	18.0	18.0	18.5	18.0	23.5	24.5	22.0	22.0	23.0	23.5	24.5
		最小	13.0	9.5	12.5	12.0	9.5	11.0	17.0	21.0	16.0	19.0	20.5	13.5	9.5
		平均	16.4	13.8	15.5	15.1	14.3	15.8	20.4	23.0	19.2	20.5	21.9	19.4	17.9
	浄水	最大	18.5	17.5	18.0	18.0	18.5	18.0	23.0	23.5	21.0	20.5	21.5	22.5	23.5
		最小	13.0	10.5	13.0	13.0	10.5	11.5	16.5	20.0	17.0	18.5	19.5	14.5	10.5
		平均	15.9	14.0	15.5	15.5	14.9	15.9	19.6	22.0	18.3	19.3	20.6	19.1	17.6
KMnO ₄ 消費量 (mg/l)	原水	最大	5.6	16.9	5.6	8.4	29.7	9.7	5.9	4.6	4.9	6.5	5.4	5.7	29.7
		最小	2.1	3.0	2.8	3.3	3.4	2.5	2.8	2.5	2.9	3.1	3.6	3.2	2.1
		平均	3.7	5.4	4.3	5.1	7.8	4.4	3.9	3.4	3.7	3.9	4.4	4.2	4.5
	浄水	最大	2.8	2.8	1.9	1.9	1.7	1.6	2.3	1.5	1.8	2.5	2.4	2.3	2.8
		最小	0.7	0.9	0.8	0.9	0.5	0.6	0.6	0.3	0.6	1.2	1.0	1.3	0.3
		平均	2.0	1.8	1.3	1.3	1.1	1.0	1.3	1.1	1.3	1.7	1.5	1.8	1.4
残留塩素 (mg/l)	浄水	最大	0.46	0.54	0.70	0.68	0.72	0.62	0.78	0.60	0.60	0.48	0.44	0.50	0.78
		最小	0.40	0.42	0.50	0.52	0.52	0.50	0.54	0.46	0.44	0.40	0.38	0.42	0.38
		平均	0.43	0.47	0.59	0.61	0.62	0.56	0.65	0.53	0.50	0.43	0.42	0.45	0.52

豊田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.2	25.4	27.1	31.0	33.4	28.0	27.0	18.3	13.0	7.3	8.1	17.0	33.4	
	最小	10.7	14.2	20.0	22.6	21.2	19.5	12.5	6.2	-0.2	-0.7	-0.2	4.7	-0.7	
	平均	15.6	20.5	24.2	28.1	28.1	24.1	20.0	13.0	7.3	3.2	3.3	10.9	16.5	
原水水温 (°C)	最大	13.7	17.5	19.5	23.0	23.0	21.2	20.2	15.0	10.0	5.5	5.4	9.2	23.0	
	最小	11.0	11.8	15.5	17.5	19.0	19.0	13.0	10.0	6.1	1.8	3.7	4.7	1.8	
	平均	12.0	14.3	17.9	20.0	20.7	20.1	17.5	12.7	8.1	4.6	4.4	6.4	13.2	
濁度 (度)	原水	最大	20.5	125.1	7.2	23.3	223.2	38.4	48.3	13.4	20.8	5.0	3.0	19.4	223.2
		最小	1.5	1.3	1.2	1.6	1.9	2.3	1.4	1.6	2.9	1.7	1.7	1.4	1.2
		平均	3.6	9.9	2.4	6.9	25.9	6.0	3.8	4.0	5.0	2.3	2.3	2.7	6.2
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	19.1	20.9	6.7	13.0	98.0	15.6	32.0	10.6	10.3	4.2	3.3	11.0	98.0
		最小	2.5	3.6	3.1	3.3	3.7	4.2	3.3	3.3	3.2	2.2	1.6	1.3	1.3
		平均	4.6	6.0	4.3	6.1	13.7	6.0	5.1	4.8	5.2	2.6	2.3	2.4	5.3
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.4	7.4	7.4	7.3	7.3	7.4	7.4	7.4	7.2	7.4	7.3	7.3	7.4
		最小	7.2	7.1	7.2	7.2	7.0	7.2	7.1	7.0	7.0	7.2	7.2	7.2	7.0
		平均	7.3	7.2	7.3	7.2	7.2	7.3	7.2	7.2	7.1	7.3	7.3	7.3	7.2
	浄水	最大	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.2
		平均	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3
総アルカリ度 (mg/l)	原水	最大	17.0	16.5	18.0	17.5	18.5	18.5	21.0	21.0	20.5	18.5	19.0	19.5	21.0
		最小	13.5	13.0	13.5	12.0	12.0	16.5	17.0	18.5	17.5	17.5	17.5	17.0	12.0
		平均	15.3	15.0	16.0	15.0	15.5	17.5	19.6	19.7	18.4	18.1	18.4	18.4	17.2
	浄水	最大	16.0	16.0	17.5	17.5	18.0	17.5	20.5	21.0	21.0	18.5	18.5	19.0	21.0
		最小	13.5	12.5	13.5	12.5	12.5	15.0	17.5	18.0	16.5	16.5	17.0	17.0	12.5
		平均	14.7	14.6	15.5	15.1	15.4	16.9	19.0	19.5	18.3	17.5	17.8	17.9	16.9
KMnO ₄ 消費量 (mg/l)	原水	最大	13.8	9.3	5.1	13.5	25.9	12.8	23.9	10.9	23.8	4.5	4.2	12.8	25.9
		最小	2.7	3.3	2.6	3.4	3.3	3.4	2.3	2.3	2.8	1.5	1.1	2.3	1.1
		平均	4.8	5.0	4.1	6.1	7.3	5.6	4.6	3.9	4.7	3.1	2.5	3.3	4.6
	浄水	最大	1.7	1.9	1.4	1.7	1.7	1.6	1.8	1.5	1.6	1.4	1.6	1.4	1.9
		最小	0.4	0.4	0.2	0.2	0.5	0.6	0.8	0.5	0.8	0.3	0.5	0.5	0.2
		平均	1.0	1.0	0.8	1.1	1.0	1.0	1.1	0.9	1.1	0.8	1.0	0.9	1.0
残留塩素 (mg/l)	浄水	最大	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.6	0.6	0.6	0.6	
		最小	0.4	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.4	
		平均	0.5	0.5	0.5	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	

幸田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.2	24.1	27.7	30.6	33.1	28.8	28.4	20.8	11.5	7.8	9.9	18.1	33.1	
	最小	12.2	12.6	18.2	20.7	21.9	18.5	13.7	9.0	-0.9	-1.7	0.7	5.0	-1.7	
	平均	15.4	19.1	23.4	28.4	27.8	25.4	21.3	14.2	6.7	3.3	5.1	12.0	16.8	
原水水温 (°C)	最大	15.0	19.5	22.5	26.0	28.0	25.0	21.5	15.0	10.5	6.0	6.5	12.5	28.0	
	最小	11.0	14.5	18.5	20.5	22.0	20.5	14.0	9.0	5.5	3.0	4.0	5.5	3.0	
	平均	12.4	17.1	20.7	23.3	24.5	22.0	18.6	12.5	8.2	4.5	5.1	9.2	14.8	
濁度 (度)	原水	最大	21.0	37.0	99.0	120.0	30.0	38.0	11.0	12.0	49.0	3.1	2.7	4.0	120.0
		最小	1.7	3.4	3.0	2.1	2.0	2.6	1.1	0.9	0.7	0.5	0.5	0.5	0.5
		平均	6.8	9.1	9.5	14.0	9.2	8.2	2.3	2.1	3.8	0.8	0.8	1.3	5.7
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	25.0	45.0	68.0	91.0	39.0	36.0	13.0	14.0	43.0	6.7	5.6	10.0	91.0
		最小	4.3	6.5	6.3	5.5	6.2	6.2	3.8	3.1	2.8	1.9	2.0	2.6	1.9
		平均	9.0	11.4	11.5	14.3	12.8	11.1	5.4	5.0	6.2	2.8	3.1	4.6	8.1
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.6	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.6	7.5	7.6	7.6	7.6
		最小	7.4	7.2	7.3	7.1	7.3	7.3	7.5	7.4	7.2	7.4	7.4	7.4	7.1
		平均	7.5	7.4	7.4	7.4	7.4	7.4	7.5	7.5	7.5	7.5	7.5	7.5	7.5
	浄水	最大	7.5	7.5	7.5	7.5	7.5	7.4	7.5	7.4	7.5	7.5	7.5	7.5	7.5
		最小	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
総アルカリ度 (mg/l)	原水	最大	19.5	20.5	19.5	20.0	20.0	19.0	21.0	22.0	21.0	20.5	21.0	22.5	22.5
		最小	13.0	10.0	12.5	10.0	10.5	13.5	18.5	17.0	12.5	17.5	18.5	16.0	10.0
		平均	17.4	17.0	18.1	17.1	16.3	16.6	20.1	20.8	19.2	19.8	20.1	20.5	18.6
	浄水	最大	17.5	19.0	19.0	19.0	18.5	17.5	19.5	21.0	21.0	19.5	19.5	20.0	21.0
		最小	12.0	12.0	14.0	11.0	11.5	14.0	17.5	17.0	13.0	16.5	17.5	16.0	11.0
		平均	15.8	16.1	17.1	16.2	15.3	15.5	18.5	19.4	18.5	18.7	18.8	19.2	17.4
KMnO ₄ 消費量 (mg/l)	原水	最大	14.0	27.2	18.9	26.0	20.6	21.0	9.1	12.7	21.8	5.9	4.9	7.9	27.2
		最小	3.4	4.3	4.4	3.3	4.7	4.7	3.0	2.5	2.5	1.8	2.4	2.1	1.8
		平均	6.7	8.4	8.2	9.6	9.0	8.0	4.2	4.2	4.7	2.9	3.0	3.8	6.1
	浄水	最大	1.9	1.9	1.2	1.4	1.6	1.6	1.9	2.5	2.2	1.2	2.1	1.8	2.5
		最小	0.6	0.5	0.3	0.2	0.2	0.3	0.3	0.6	0.6	0.6	0.6	0.6	0.2
		平均	1.2	1.0	0.8	0.9	1.0	1.0	0.9	1.0	1.0	0.9	1.1	1.1	1.0
残留塩素 (mg/l)	浄水	最大	0.6	0.7	0.7	0.7	0.8	0.8	0.7	0.7	0.6	0.5	0.6	0.8	
		最小	0.5	0.5	0.6	0.6	0.7	0.7	0.6	0.6	0.5	0.5	0.5	0.5	
		平均	0.5	0.6	0.7	0.7	0.7	0.7	0.7	0.6	0.6	0.5	0.5	0.6	

豊橋浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	20.4	25.7	28.6	31.3	32.5	31.0	27.6	20.0	13.8	9.5	11.1	18.1	32.5	
	最小	11.6	14.5	19.1	21.5	22.7	18.9	14.0	7.9	1.3	1.9	2.0	6.0	1.3	
	平均	16.7	21.4	24.5	28.7	28.6	25.4	21.4	14.6	8.8	5.3	6.1	12.2	17.8	
原水水温 (°C)	最大	17.0	20.0	23.1	26.5	28.5	25.5	22.6	15.6	10.7	6.0	7.0	15.1	28.5	
	最小	12.7	11.3	18.5	20.0	21.0	20.5	14.8	8.5	5.4	3.5	4.7	7.0	3.5	
	平均	15.3	17.4	21.1	23.8	24.5	22.3	19.3	12.7	8.3	4.6	5.8	10.8	15.5	
濁度 (度)	原水	最大	25.0	14.0	38.0	66.0	57.0	36.0	3.2	6.3	16.0	1.3	1.6	6.4	66.0
		最小	1.7	1.9	1.6	2.1	2.1	2.7	1.1	0.6	0.6	0.4	0.6	1.0	0.4
		平均	3.9	3.8	4.3	8.8	8.7	5.8	2.0	1.5	1.8	0.7	0.9	1.8	3.7
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	20	14	23	56	30	18	6.7	11	18	3.8	4.0	14	56
		最小	2.7	3.3	3.3	4.0	4.2	3.9	1.3	2.3	1.9	1.5	1.9	2.4	1.3
		平均	4.8	5.5	5.6	8.7	8.2	6.3	3.8	3.9	4.1	2.1	2.5	4.8	5.0
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.7	7.5	7.6	7.5	7.5	7.5	7.6	7.6	7.6	7.6	7.9	7.9	
		最小	7.2	7.0	7.1	7.2	7.1	7.2	7.3	7.4	7.3	7.4	7.6	7.2	
		平均	7.5	7.3	7.4	7.4	7.3	7.4	7.4	7.5	7.5	7.5	7.7	7.5	
	浄水	最大	7.4	7.5	7.5	7.5	7.5	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.5
		最小	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
総アルカリ度 (mg/l)	原水	最大	24.5	24.0	25.0	27.0	28.5	28.0	28.5	29.0	27.0	27.5	28.5	28.5	29.0
		最小	14.0	12.0	12.5	14.5	12.5	15.5	25.0	21.0	16.0	23.0	24.5	14.5	12.0
		平均	20.9	19.9	22.5	23.1	21.9	23.6	27.2	26.9	24.6	25.9	26.4	25.2	24.0
	浄水	最大	22.0	22.5	23.5	27.0	26.0	25.0	26.0	27.0	25.0	24.0	24.0	25.5	27.0
		最小	14.5	12.5	15.5	16.0	11.0	17.0	22.5	19.5	15.0	21.5	21.0	15.0	11.0
		平均	19.1	18.1	20.6	21.1	20.1	21.4	24.1	24.2	22.2	22.8	22.7	21.9	21.5
KMnO ₄ 消費量 (mg/l)	原水	最大	13.0	9.9	14.0	25.0	20.0	12.0	6.0	10.0	14.0	3.6	4.0	12.0	25.0
		最小	2.1	2.4	3.0	3.2	3.7	3.5	2.8	2.1	2.4	1.8	2.4	2.7	1.8
		平均	4.0	4.6	4.9	5.7	6.4	5.2	3.7	3.9	4.1	2.4	2.8	5.0	4.4
	浄水	最大	1.5	1.5	1.7	1.4	1.6	1.4	1.4	1.5	1.9	1.2	1.2	2.2	2.2
		最小	0.3	0.3	0.6	0.5	0.5	0.5	0.7	0.5	0.3	0.6	0.6	0.6	0.3
		平均	0.7	0.9	1.1	0.9	1.0	0.9	1.0	0.9	1.0	0.8	0.9	1.3	1.0
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.5	0.5	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.6
		最小	0.4	0.4	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.4
		平均	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.5

豊橋南部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	20.3	25.2	27.1	30.7	31.5	30.0	27.7	21.0	13.5	8.7	10.2	17.3	31.5	
	最小	11.1	13.9	19.3	21.1	22.2	18.4	14.2	9.6	0.9	1.5	2.3	6.6	0.9	
	平均	16.3	20.6	24.1	28.2	28.3	25.2	21.0	14.9	8.9	5.3	5.8	11.8	17.5	
原水水温 (°C)	最大	15.5	17.7	20.0	22.6	24.2	24.3	22.3	17.9	13.0	8.6	7.4	12.3	24.3	
	最小	13.0	14.7	17.5	19.5	21.0	21.8	17.5	12.1	9.0	6.0	5.9	6.4	5.9	
	平均	14.0	16.3	18.9	21.4	22.9	22.8	20.6	15.8	11.1	7.0	6.3	9.2	15.5	
濁度 (度)	原水	最大	2.3	1.7	2.4	8.6	17.4	37.8	1.5	6.4	4.5	1.3	2.3	12.2	37.8
		最小	0.8	0.6	0.8	1.3	0.8	0.6	0.8	0.8	0.7	0.8	1.0	1.2	0.6
		平均	1.1	1.0	1.2	2.5	2.3	3.0	1.2	1.3	1.2	1.0	1.5	2.3	1.6
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	4.7	5.4	5.8	12.4	8.9	21.2	4.7	7.6	8.1	4.6	4.1	11.1	21.2
		最小	3.0	3.0	2.3	2.7	3.6	3.3	3.4	3.6	3.6	3.7	3.4	3.2	2.3
		平均	3.6	3.9	4.1	4.5	5.1	4.9	4.1	4.6	4.5	3.9	3.7	4.3	4.3
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.4	7.3	7.2	7.1	7.2	7.4	7.9	7.4	7.5	7.5	7.6	7.6	7.9
		最小	7.1	7.0	7.0	6.9	6.8	7.0	7.2	7.1	7.3	7.3	7.3	7.3	6.8
		平均	7.3	7.2	7.1	7.0	7.0	7.2	7.4	7.3	7.4	7.4	7.5	7.5	7.3
	浄水	最大	7.5	7.5	7.5	7.4	7.5	7.5	7.5	7.5	7.4	7.5	7.5	7.5	7.5
		最小	7.4	7.3	7.3	7.3	7.4	7.3	7.4	7.4	7.4	7.3	7.3	7.4	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
総アルカリ度 (mg/l)	原水	最大	19.0	18.0	18.0	23.0	19.5	18.0	19.0	18.0	20.0	17.5	19.0	18.0	23.0
		最小	15.0	15.0	15.0	13.5	11.0	14.0	16.5	15.0	14.5	15.5	15.0	13.0	11.0
		平均	17.3	16.6	16.8	16.7	14.7	16.5	17.6	16.6	16.8	16.4	16.6	16.5	16.6
	浄水	最大	18.5	17.5	18.0	19.5	21.0	17.0	17.5	17.0	18.0	17.0	18.0	17.0	21.0
		最小	14.0	15.0	15.0	14.5	12.0	13.5	14.5	14.0	12.5	14.5	14.5	12.0	12.0
		平均	16.1	16.1	16.8	16.9	15.5	15.8	15.8	15.5	15.6	15.5	15.6	15.2	15.9
KMnO ₄ 消費量 (mg/l)	原水	最大	5.6	6.8	6.5	11.5	7.6	7.0	5.7	9.7	8.6	5.5	6.0	13.2	13.2
		最小	3.4	3.4	3.2	4.1	2.9	2.9	3.4	4.2	3.4	4.0	3.8	4.8	2.9
		平均	4.3	4.8	4.6	5.4	5.2	4.4	4.3	5.2	4.9	4.5	4.7	6.2	4.9
	浄水	最大	1.9	1.6	1.4	1.4	1.7	1.4	1.3	1.5	1.8	1.5	1.8	1.9	1.9
		最小	1.0	0.6	0.5	0.5	0.5	0.5	0.4	0.3	0.3	0.8	0.8	0.9	0.3
		平均	1.2	1.3	1.0	1.1	1.2	1.0	0.7	1.0	1.0	1.2	1.2	1.4	1.1
残留塩素 (mg/l)	浄水	最大	0.6	0.7	0.7	0.7	0.8	0.8	0.7	0.7	0.7	0.7	0.6	0.6	0.8
		最小	0.5	0.6	0.6	0.7	0.7	0.7	0.7	0.6	0.6	0.6	0.6	0.6	0.5
		平均	0.6	0.6	0.7	0.7	0.8	0.7	0.7	0.7	0.7	0.6	0.6	0.6	0.7

豊川浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.1	27.1	30.5	33.4	34.6	30.9	28.1	21.0	13.3	9.3	11.2	19.6	34.6	
	最小	12.4	14.6	19.7	22.0	23.3	19.3	14.3	9.7	1.3	1.5	2.6	6.8	1.3	
	平均	18.1	22.1	25.7	30.0	29.3	26.0	21.4	14.7	8.8	5.7	6.6	13.6	18.5	
原水水温 (°C)	最大	17.5	20.1	22.0	26.2	26.3	25.4	23.5	18.0	13.2	8.0	8.3	13.5	26.3	
	最小	15.3	17.2	19.5	21.5	23.5	20.0	18.0	13.0	8.5	6.5	6.9	8.0	6.5	
	平均	16.5	18.7	21.4	24.0	24.7	23.2	21.3	15.8	11.1	7.2	7.6	11.3	16.9	
濁度 (度)	原水	最大	2.8	2.5	2.0	15.0	8.0	3.4	2.7	3.5	5.2	1.6	1.8	3.5	15.0
		最小	0.8	0.6	0.6	1.3	0.7	0.7	0.8	1.1	1.5	1.1	1.1	1.2	0.6
		平均	1.6	1.4	1.2	3.7	3.5	1.9	1.6	1.9	2.6	1.3	1.5	2.1	2.0
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	6.2	7.0	6.0	14.0	13.0	8.1	5.9	6.2	7.8	4.9	4.6	6.7	14.0
		最小	3.7	3.4	3.3	2.5	4.9	3.8	3.9	4.7	4.8	4.2	3.7	3.9	2.5
		平均	4.6	4.8	4.5	7.2	7.9	5.3	4.7	5.3	5.9	4.6	4.3	4.7	5.3
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.6	7.6	7.5	7.4	7.4	7.5	7.4	7.3	7.4	7.5	7.4	7.5	7.6
		最小	7.2	7.1	7.1	6.8	6.8	7.1	7.1	7.1	7.1	7.2	7.2	7.2	6.8
		平均	7.4	7.3	7.3	7.2	7.1	7.2	7.3	7.2	7.2	7.3	7.3	7.4	7.3
	浄水	最大	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.3	7.3	7.3	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.2
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
総アルカリ度 (mg/l)	原水	最大	18.0	17.5	16.5	22.5	22.0	18.5	21.0	19.5	17.5	17.0	17.5	17.0	22.5
		最小	14.0	14.0	14.0	14.0	11.5	15.5	17.0	15.5	14.0	14.5	14.5	14.5	11.5
		平均	16.5	15.9	15.6	16.6	14.9	17.1	19.2	16.7	16.1	15.7	15.6	16.1	16.3
	浄水	最大	17.5	18.0	17.0	21.5	22.0	19.0	21.0	18.5	18.0	17.0	17.5	17.0	22.0
		最小	14.0	15.0	14.0	16.0	13.0	16.0	17.0	16.0	15.0	15.0	14.5	14.5	13.0
		平均	16.1	16.0	15.7	17.4	16.3	17.5	19.2	17.0	16.5	15.8	15.6	15.8	16.6
KMnO ₄ 消費量 (mg/l)	原水	最大	4.9	6.2	6.2	7.5	7.9	6.9	4.8	5.7	6.9	4.6	5.8	6.5	7.9
		最小	3.0	2.9	3.1	3.5	2.5	2.2	2.3	2.6	3.5	3.4	3.7	3.5	2.2
		平均	3.7	4.0	4.4	4.9	5.4	3.8	3.6	4.4	5.0	4.0	4.6	4.6	4.4
	浄水	最大	1.2	1.4	1.6	1.5	1.7	1.3	1.3	1.1	1.3	1.4	1.5	1.5	1.7
		最小	0.3	0.3	0.7	0.3	0.4	0.3	0.3	0.4	0.2	0.4	0.6	0.5	0.2
		平均	0.8	0.7	1.0	0.9	1.0	0.8	0.7	0.9	0.7	0.8	1.3	1.1	0.9
残留塩素 (mg/l)	浄水	最大	0.6	0.6	0.6	0.7	0.7	0.7	0.6	0.6	0.6	0.6	0.6	0.5	0.7
		最小	0.5	0.5	0.5	0.5	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.5
		平均	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.6

(2)工業用水毎日検査

上野浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.0	25.6	27.8	31.9	33.8	28.5	27.2	19.2	13.4	9.0	9.3	17.8	33.8	
	最小	10.4	13.8	19.4	23.3	22.9	19.5	14.1	8.6	0.2	1.2	0.9	6.5	0.2	
	平均	16.2	20.6	24.7	28.9	28.6	25.5	20.9	14.1	8.5	4.7	5.2	11.5	17.5	
原水水温 (°C)	最大	15.0	18.1	23.4	25.2	25.6	23.0	21.7	16.4	11.7	6.7	6.8	11.4	25.6	
	最小	11.8	14.5	17.5	20.9	22.1	21.1	16.6	11.3	6.9	4.4	4.5	6.2	4.4	
	平均	13.7	16.1	19.8	22.6	23.7	21.7	20.0	14.2	9.4	5.3	5.4	8.6	15.0	
濁度 (度)	原水	最大	6.3	28.9	12.1	8.5	92.4	24.5	7.9	4.1	6.2	3.0	2.5	5.4	92.4
		最小	3.1	2.9	3.6	3.3	3.9	3.1	2.6	2.3	2.5	1.7	1.6	1.8	1.6
		平均	4.9	8.9	6.0	5.6	24.8	9.5	4.5	3.1	3.7	2.2	1.9	2.8	6.5
	配水	最大	6.2	4.4	5.0	5.3	5.8	2.6	4.4	2.8	4.1	2.1	1.8	3.0	6.2
		最小	2.4	1.2	1.2	0.9	1.3	0.6	1.6	1.8	1.0	1.3	1.2	1.2	0.6
		平均	3.7	2.7	2.8	3.0	2.9	1.4	2.5	2.2	2.7	1.7	1.5	1.8	2.4
pH値	原水	最大	7.5	7.5	7.5	7.4	7.4	7.5	7.5	7.6	7.6	7.5	7.5	7.5	7.6
		最小	7.2	7.1	7.2	7.1	7.1	7.2	7.3	7.4	7.3	7.3	7.4	7.3	7.1
		平均	7.4	7.3	7.4	7.3	7.2	7.4	7.4	7.5	7.4	7.4	7.4	7.4	7.4
	配水	最大	7.4	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.3	7.4	7.3	7.4	7.4
		最小	7.3	7.0	7.0	6.8	6.9	6.9	7.2	7.2	7.1	7.2	7.2	7.2	6.8
		平均	7.3	7.2	7.3	7.1	7.1	7.1	7.3	7.3	7.3	7.3	7.3	7.3	7.2
総アルカリ度 (mg/l)	原水	最大	15.5	15.0	15.5	16.5	16.5	17.0	20.0	21.0	20.0	19.5	20.0	21.5	21.5
		最小	14.0	13.0	13.0	13.0	13.5	14.0	17.0	20.0	17.5	17.0	19.0	17.0	13.0
		平均	14.7	14.0	14.5	14.7	14.7	15.0	18.4	20.6	18.5	18.3	19.6	19.8	16.9
	配水	最大	15.0	15.0	15.5	16.0	16.0	16.5	18.5	20.0	18.5	17.5	18.5	20.0	20.0
		最小	13.5	10.5	10.5	9.5	10.0	10.0	16.0	18.0	15.5	16.0	17.0	16.0	9.5
		平均	14.2	13.1	13.9	13.1	13.1	12.3	17.2	19.1	16.6	16.7	17.9	18.2	15.5

知多浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.0	26.0	29.0	34.0	35.0	28.5	29.0	19.0	12.0	15.5	12.0	17.0	35.0	
	最小	11.0	11.0	19.5	20.0	24.0	20.0	15.0	8.0	-1.0	0.0	1.0	4.5	-1.0	
	平均	16.3	20.8	25.0	29.8	29.3	25.7	21.7	13.5	7.5	4.6	4.9	11.0	17.5	
原水水温 (°C)	最大	17.5	19.2	22.9	28.3	28.4	26.2	23.7	18.4	12.9	8.5	7.3	12.2	28.4	
	最小	14.0	16.5	19.8	23.0	25.3	23.2	18.2	12.9	8.5	5.6	6.0	7.2	5.6	
	平均	15.5	17.9	21.4	25.5	26.6	24.3	21.8	16.1	10.7	6.6	6.5	9.5	16.9	
濁度 (度)	原水	最大	4.1	5.3	3.4	3.3	21.3	4.2	4.2	4.4	2.9	2.2	2.1	3.7	21.3
		最小	1.3	1.7	1.5	1.3	1.6	2.1	1.9	2.0	1.6	1.3	1.2	1.3	1.2
		平均	2.4	2.7	2.1	2.0	6.0	3.0	2.8	2.6	2.4	1.7	1.6	2.3	2.6
	配水	最大	4.0	4.3	2.9	2.7	4.4	4.3	3.6	3.8	2.0	1.6	1.6	2.7	4.4
		最小	0.8	1.0	0.8	0.8	0.7	0.5	1.4	0.9	0.8	0.8	0.6	0.6	0.5
		平均	2.0	2.2	1.6	1.5	1.9	2.3	2.2	2.0	1.4	1.1	1.0	1.3	1.7
pH値	原水	最大	7.1	7.1	7.0	7.3	7.2	7.3	7.2	7.6	7.6	7.5	7.6	7.6	7.6
		最小	6.9	6.8	6.8	6.8	6.7	7.0	7.0	7.2	7.4	7.4	7.4	7.2	6.7
		平均	7.0	7.0	6.9	7.1	7.1	7.1	7.1	7.3	7.5	7.5	7.5	7.4	7.2
	配水	最大	7.1	7.1	7.0	7.2	7.7	7.2	7.2	7.4	7.4	7.5	7.4	7.4	7.7
		最小	6.9	6.9	6.8	6.8	6.7	7.0	7.0	7.2	7.1	7.1	7.3	7.2	6.7
		平均	7.0	7.0	6.9	7.0	7.1	7.1	7.1	7.3	7.3	7.3	7.4	7.3	7.2
アルカリ度 (mg/l)	原水	最大	19.5	17.0	16.5	18.5	19.0	25.0	21.0	21.5	21.5	19.5	21.0	21.5	25.0
		最小	16.0	14.0	14.0	14.0	14.5	14.0	16.0	19.0	18.0	17.5	18.0	18.0	14.0
		平均	17.0	15.9	15.3	15.5	15.9	15.8	18.2	20.3	19.5	18.7	19.4	20.4	17.7
	配水	最大	19.5	17.0	16.5	18.0	19.0	16.5	20.0	21.5	20.5	19.0	20.5	20.5	21.5
		最小	16.0	14.5	13.5	13.0	13.0	13.0	16.0	19.0	17.5	16.5	18.0	18.0	13.0
		平均	17.1	16.0	15.1	14.9	15.5	15.3	18.3	20.1	18.6	18.0	18.6	19.5	17.3

尾張東部浄水場(東郷)

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.5	26.5	28.4	31.7	25.3	26.9	28.4	17.6	11.0	7.6	7.4	16.1	31.7	
	最小	5.0	14.1	19.5	23.3	19.8	19.7	13.0	6.7	7.0	0.6	0.2	4.4	0.2	
	平均	16.5	20.9	24.7	28.7	22.0	23.5	19.8	12.2	8.9	3.4	3.8	10.2	16.2	
原水水温 (°C)	最大	21.8	19.0	20.6	24.9	25.5	23.5	21.7	16.5	11.6	6.6	6.0	10.5	25.5	
	最小	11.4	14.5	17.2	20.7	23.0	21.4	16.6	11.5	6.9	4.3	4.7	6.0	4.3	
	平均	16.4	16.0	19.3	22.3	24.1	22.0	20.1	14.3	9.2	5.3	5.3	8.2	25.9	
濁度 (度)	原水	最大	5.0	24.0	6.0	7.0	26.0	12.0	7.0	4.0	5.0	3.0	2.0	3.0	26.0
		最小	2.0	3.0	4.0	4.0	3.0	4.0	3.0	3.0	3.0	1.0	1.0	1.0	1.0
		平均	3.0	6.0	4.0	5.0	11.0	7.0	4.0	3.0	3.0	2.0	1.0	2.0	4.3
	配水	最大	4.0	4.0	4.0	4.0	4.0	4.0	5.0	3.0	4.0	2.1	2.1	4.0	5.0
		最小	2.0	2.0	2.0	2.0	2.0	1.0	2.0	1.0	2.0	1.6	1.6	2.0	1.0
		平均	2.0	2.0	2.0	2.0	2.0	2.0	2.0	1.0	2.0	1.9	1.0	2.0	1.8
pH値	原水	最大	7.5	7.5	7.4	7.3	7.5	7.5	7.6	7.6	7.6	7.6	7.6	7.6	7.6
		最小	7.2	7.1	7.1	7.0	7.1	7.3	7.3	7.5	7.4	7.5	7.5	7.3	7.0
		平均	7.3	7.3	7.3	7.2	7.2	7.4	7.4	7.6	7.5	7.5	7.6	7.5	7.4
	配水	最大	7.4	7.4	7.4	7.4	7.3	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.2	7.0	7.2	7.0	7.0	7.1	7.3	7.3	7.3	7.3	7.4	7.3	7.0
		平均	7.3	7.3	7.3	7.2	7.1	7.2	7.3	7.4	7.4	7.4	7.4	7.4	7.3
総アルカリ度 (mg/l)	原水	最大	16.5	16.0	16.0	16.0	16.5	16.5	20.0	22.0	20.5	19.5	20.0	21.5	22.0
		最小	13.5	12.5	13.0	13.0	13.0	13.5	16.0	19.5	17.5	17.0	18.5	18.0	12.5
		平均	14.9	14.2	14.6	14.6	14.5	14.9	18.2	20.7	18.5	18.4	19.4	19.8	16.9
	配水	最大	16.0	15.5	15.5	16.0	16.5	16.0	19.0	20.5	20.0	18.5	19.0	20.0	20.5
		最小	13.5	10.5	12.5	12.5	11.5	12.0	15.0	18.5	16.0	16.5	17.5	16.5	10.5
		平均	14.6	13.4	14.2	14.2	13.5	13.8	17.6	19.3	17.7	17.4	18.4	18.6	16.1

尾張西部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.6	26.4	28.9	32.3	35.0	29.5	28.6	23.2	14.8	10.9	10.9	18.0	35.0	
	最小	13.2	13.3	19.4	19.8	22.9	19.2	13.4	6.0	0.1	-0.2	0.8	5.0	-0.2	
	平均	17.4	20.7	25.3	28.9	28.9	25.1	21.7	14.6	8.5	4.7	5.5	11.5	17.7	
原水水温 (°C)	最大	15.5	19.0	23.0	26.7	28.5	24.0	23.2	17.0	11.3	6.6	7.7	12.2	28.5	
	最小	12.0	13.5	17.9	20.1	19.9	20.5	16.8	10.9	6.5	4.0	5.0	7.9	4.0	
	平均	14.1	16.2	20.6	23.4	23.6	21.7	20.4	14.4	9.2	5.8	6.2	9.7	15.4	
濁度 (度)	原水	最大	7.0	153.8	11.9	13.5	246.0	48.8	5.0	2.7	4.8	2.1	2.5	5.5	246.0
		最小	1.4	1.0	1.6	1.4	1.5	2.6	0.6	1.1	0.8	0.8	0.9	1.0	0.6
		平均	3.3	10.5	4.4	4.1	35.4	9.0	1.6	1.7	2.3	1.3	1.2	2.4	6.4
	配水	最大	0.4	0.4	0.4	0.4	0.3	0.3	0.3	0.3	0.4	0.4	0.3	0.4	0.4
		最小	0.1	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0
		平均	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.3	0.2	0.2	0.2	0.2
pH値	原水	最大	7.6	7.4	7.5	7.1	7.1	7.4	7.6	7.6	7.4	7.5	7.5	7.5	7.6
		最小	7.1	6.8	6.9	6.9	6.7	6.9	7.2	7.3	7.2	7.4	7.3	7.0	6.7
		平均	7.3	7.2	7.2	7.0	7.0	7.2	7.4	7.4	7.3	7.4	7.5	7.3	7.3
	配水	最大	7.4	7.3	7.3	7.3	7.4	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.1	7.1	7.1	7.0	7.1	7.1	7.2	7.2	7.1	7.2	7.3	7.1	7.0
		平均	7.2	7.2	7.2	7.1	7.2	7.2	7.3	7.3	7.3	7.3	7.4	7.3	7.3
総アルカリ度 (mg/l)	原水	最大	22.5	19.0	21.0	19.5	19.0	20.5	25.5	29.0	25.5	23.0	25.0	27.0	29.0
		最小	13.0	9.5	13.0	13.5	9.0	12.0	19.5	23.0	19.0	20.0	21.5	16.0	9.0
		平均	18.7	15.9	16.4	16.5	15.6	17.7	22.7	25.5	21.3	21.4	23.8	22.3	19.8
	配水	最大	20.0	16.0	17.0	17.0	16.5	17.5	21.0	24.5	21.0	20.0	23.0	24.0	24.5
		最小	12.5	11.0	10.0	12.0	9.5	12.5	15.0	18.5	16.0	16.0	19.5	14.0	9.5
		平均	15.7	13.2	13.4	14.5	13.8	15.2	18.7	21.3	18.5	18.3	20.7	19.8	16.9

安城浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.9	27.4	29.9	33.4	36.1	29.5	28.7	22.4	14.6	10.7	12.0	20.1	36.1	
	最小	13.4	14.5	19.6	22.3	22.9	20.0	14.8	10.2	3.5	1.0	2.2	6.8	1.0	
	平均	18.0	22.1	25.7	30.2	29.7	26.4	22.7	15.8	10.0	5.9	7.1	13.6	18.9	
原水水温 (°C)	最大	15.0	18.2	22.9	25.1	27.2	22.6	22.1	15.5	11.0	5.8	6.8	12.8	27.2	
	最小	12.6	14.0	17.7	18.4	20.6	20.7	15.5	9.7	6.2	3.6	4.5	6.7	3.6	
	平均	14.1	16.0	20.3	22.0	23.0	21.5	19.5	13.2	8.6	4.9	5.6	9.7	14.9	
濁度 (度)	原水	最大	12	27.0	12	60	215	16	16	16	28.0	5.0	4	9	215
		最小	1.0	2.0	2.0	2.0	2.0	2.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		平均	3.1	7.4	3.3	10	21.7	4.7	3.2	2.9	3.5	1.7	1.8	2.1	5.4
	配水	最大	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	2.0	1.0	2.0
		最小	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		平均	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
pH値	原水	最大	7.5	7.5	7.7	7.5	7.5	7.5	7.6	7.5	7.5	7.6	7.9	7.7	7.9
		最小	7.2	7.1	7.2	7.1	7.1	7.2	7.2	7.2	7.1	7.3	7.4	7.3	7.1
		平均	7.4	7.4	7.4	7.3	7.3	7.3	7.5	7.3	7.3	7.5	7.6	7.5	7.4
	配水	最大	7.2	7.1	7.1	7.1	7.1	7.2	7.2	7.2	7.2	7.3	7.3	7.3	7.3
		最小	6.9	6.9	6.8	6.8	6.8	6.9	7.0	6.9	6.9	7.1	7.0	7.0	6.8
		平均	7.0	7.0	7.0	7.0	7.0	7.0	7.1	7.1	7.1	7.2	7.2	7.1	7.1
総アルカリ度 (mg/l)	原水	最大	23.0	19.0	21.0	20.5	21.5	21.0	24.0	25.5	24.5	25.0	25.5	26.5	26.5
		最小	17.0	14.0	15.5	14.0	14.0	16.5	18.0	22.0	19.5	22.0	24.0	20.5	14.0
		平均	19.1	16.9	18.8	17.0	17.3	19.1	21.8	24.5	22.7	23.4	24.6	25.3	20.9
	配水	最大	17.5	15.0	16.5	17.0	17.0	17.0	19.0	21.0	20.5	20.5	21.0	23.5	23.5
		最小	13.0	11.0	12.0	11.0	11.0	12.5	14.5	16.5	16.5	18.0	19.0	16.0	11.0
		平均	15.0	13.1	14.4	12.9	13.9	14.2	16.9	19.6	18.6	19.5	20.2	21.0	16.6

豊橋南部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	20.3	25.2	27.1	30.7	31.5	30.0	27.7	21.0	13.5	8.7	10.2	17.3	31.5	
	最小	11.1	13.9	19.3	21.1	22.2	18.4	14.2	9.6	0.9	1.5	2.3	6.6	0.9	
	平均	16.3	20.6	24.1	28.2	28.3	25.2	21.0	14.9	8.9	5.3	5.8	11.8	17.5	
原水水温 (°C)	最大	15.5	17.7	20.0	22.6	24.2	24.3	22.3	17.9	13.0	8.6	7.4	12.3	24.3	
	最小	13.0	14.7	17.5	19.5	21.0	21.8	17.5	12.1	9.0	6.0	5.9	6.4	5.9	
	平均	14.0	16.3	18.9	21.4	22.9	22.8	20.6	15.8	11.1	7.0	6.3	9.2	15.5	
濁度 (度)	原水	最大	2.3	1.7	2.4	8.6	17.4	37.8	1.5	6.4	4.5	1.3	2.3	12.2	37.8
		最小	0.8	0.6	0.8	1.3	0.8	0.6	0.8	0.8	0.7	0.8	1.0	1.2	0.6
		平均	1.1	1.0	1.2	2.5	2.3	3.0	1.2	1.3	1.2	1.0	1.5	2.3	1.6
	配水	最大	0.3	0.3	0.3	0.4	0.5	0.4	0.3	0.3	0.2	0.2	0.3	0.5	0.5
		最小	0.0	0.0	0.1	0.2	0.0	0.2	0.1	0.0	0.0	0.0	0.1	0.1	0.0
		平均	0.1	0.2	0.2	0.3	0.2	0.3	0.2	0.1	0.1	0.2	0.2	0.2	0.2
pH値	原水	最大	7.4	7.3	7.2	7.1	7.2	7.4	7.9	7.4	7.5	7.5	7.6	7.6	7.9
		最小	7.1	7.0	7.0	6.9	6.8	7.0	7.2	7.1	7.3	7.3	7.3	7.3	6.8
		平均	7.3	7.2	7.1	7.0	7.0	7.2	7.4	7.3	7.4	7.4	7.5	7.5	7.3
	配水	最大	7.2	7.1	7.1	7.1	7.1	7.2	7.2	7.1	7.2	7.1	7.2	7.2	7.2
		最小	7.0	6.9	6.9	6.8	6.8	6.9	7.0	6.9	6.9	7.0	7.0	6.8	6.8
		平均	7.1	7.0	7.0	6.9	6.9	7.0	7.1	7.0	7.1	7.1	7.1	7.1	7.0
総アルカリ度 (mg/l)	原水	最大	19.0	18.0	18.0	23.0	19.5	18.0	19.0	18.0	20.0	17.5	19.0	18.0	23.0
		最小	15.0	15.0	15.0	13.5	11.0	14.0	16.5	15.0	14.5	15.5	15.0	13.0	11.0
		平均	17.3	16.6	16.8	16.7	14.7	16.5	17.6	16.6	16.8	16.4	16.6	16.5	16.6
	配水	最大	15.0	14.5	14.5	16.0	17.5	16.0	15.0	13.5	16.0	14.0	15.0	15.0	17.5
		最小	11.5	11.0	11.5	9.5	8.5	10.5	11.5	11.5	10.0	11.5	11.5	9.0	8.5
		平均	13.2	12.7	13.3	13.0	11.2	12.7	13.5	12.3	13.1	12.5	13.1	12.8	12.8

蒲郡浄水場(工水)

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.8	26.5	29.6	33.1	34.3	31.7	29.7	21.1	14.8	11.5	13.0	20.0	34.3	
	最小	14.7	15.6	20.5	22.3	24.5	21.4	15.1	10.6	3.2	3.2	4.4	8.5	3.2	
	平均	18.5	22.4	25.6	29.8	29.6	26.6	22.9	16.9	10.9	7.1	8.0	14.4	19.4	
原水水温 (°C)	最大	16.0	18.4	21.0	24.8	25.0	24.1	21.5	18.0	14.0	10.6	8.8	13.5	25.0	
	最小	13.2	15.3	18.6	20.1	21.6	20.7	17.1	13.1	10.0	7.0	7.2	8.0	7.0	
	平均	14.9	16.9	19.8	22.4	23.2	21.8	19.8	15.7	11.7	8.3	8.0	10.5	16.1	
濁度 (度)	原水	最大	1.3	1.9	2.9	13.5	4.1	2.9	3.7	1.6	4.3	1.1	1.2	8.3	13.5
		最小	0.4	0.3	0.5	0.6	0.9	0.5	0.5	0.2	0.4	0.3	0.4	0.5	0.2
		平均	0.8	0.9	1.2	2.5	2.0	1.4	1.1	0.8	1.1	0.6	0.6	1.3	1.2
	配水	最大	0.2	0.3	0.2	0.3	2.1	0.3	0.6	0.1	12.6	0.3	0.2	0.4	12.6
		最小	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
		平均	0.1	0.1	0.1	0.2	0.3	0.2	0.2	0.1	0.5	0.1	0.1	0.2	0.2
pH値	原水	最大	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.4	7.4	7.4	7.4	7.4	
		最小	7.2	7.2	7.1	7.0	7.0	7.1	6.9	7.2	7.2	7.2	7.2	7.2	
		平均	7.3	7.2	7.2	7.1	7.1	7.2	7.2	7.3	7.3	7.3	7.3	7.3	
	配水	最大	7.3	7.2	7.2	7.2	7.2	7.2	7.3	7.3	7.3	7.3	7.3	7.2	
		最小	7.1	7.0	7.0	7.0	7.0	7.1	7.0	7.1	7.1	7.1	7.1	7.1	
		平均	7.2	7.1	7.1	7.1	7.1	7.1	7.1	7.2	7.2	7.2	7.2	7.2	
総7ル初度 (mg/l)	原水	最大	22.0	25.0	21.0	25.0	24.0	24.0	25.0	22.0	23.0	23.0	20.0	20.0	
		最小	18.0	17.0	17.0	17.0	16.0	18.0	20.0	19.0	19.0	18.0	17.0	18.0	
		平均	19.9	21.0	19.2	20.3	19.9	21.3	22.7	20.7	20.1	19.3	18.6	19.2	
	配水	最大	20.0	21.0	19.0	23.0	21.0	22.0	23.0	20.0	21.0	20.0	18.0	19.0	
		最小	16.0	17.0	16.0	16.0	14.0	18.0	18.0	17.0	17.0	16.0	16.0	16.0	
		平均	18.0	18.5	17.4	18.3	18.0	19.7	20.8	18.6	18.0	17.4	17.1	17.4	