

PFOS・PFOA・PFHxS R7年度

浄水場原水 試験結果書

単位：ng/L

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
高蔵寺浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
尾張東部浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
上野浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
知多浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFOA	ng/L	< 2	< 2	2	2	< 2	< 2	< 2	< 2	2	< 2		
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
犬山浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
尾張西部浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
豊田浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
幸田浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
豊橋浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
豊橋南部浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
豊川浄水場原水	PFOS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFOA	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		
	PFHxS	ng/L	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2	< 2		

定量下限値：2ng/L

PFOS・PFOA・PFHxS R7年度

[illegible]

定量下限值：2ng/L

原水主要地点 試験結果書

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
兼山取水口	PFOS	ng/L		< 2			< 2			< 2				
	PFOA	ng/L		< 2			< 2			< 2				
	PFHxS	ng/L		< 2			< 2			< 2				
犬山共同取水口	PFOS	ng/L		< 2			< 2			< 2				
	PFOA	ng/L		< 2			< 2			< 2				
	PFHxS	ng/L		< 2			< 2			< 2				
尾西取水口	PFOS	ng/L		< 2			< 2			< 2				
	PFOA	ng/L		< 2			< 2			< 2				
	PFHxS	ng/L		< 2			< 2			< 2				
長良川取水口	PFOS	ng/L		< 2			< 2			< 2				
	PFOA	ng/L		< 2			< 2			< 2				
	PFHxS	ng/L		< 2			< 2			< 2				
岩倉取水口	PFOS	ng/L		< 2			< 2			< 2				
	PFOA	ng/L		< 2			< 2			< 2				
	PFHxS	ng/L		< 2			< 2			< 2				
細川頭首工	PFOS	ng/L		< 2			< 2			< 2				
	PFOA	ng/L		< 2			< 2			< 2				
	PFHxS	ng/L		< 2			< 2			< 2				
大野頭首工	PFOS	ng/L		< 2			< 2			< 2				
	PFOA	ng/L		< 2			< 2			< 2				
	PFHxS	ng/L		< 2			< 2			< 2				
森岡取水場	PFOS	ng/L		< 2			< 2			< 2				
	PFOA	ng/L		< 2			< 2			< 2				
	PFHxS	ng/L		< 2			< 2			< 2				

定量下限値：2ng/L