

高藏寺浄水場(上水) 汚泥濃度月報(平成11年4月～平成16年3月)

日付	平成11年												平成12年												平成13年																															
	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月																							
1	5.3			4.0		8.2	7.7	11.6	3.4		4.3	2.6		3.0	4.3							4.7	4.3		8.7	3.8		3.2	3.3		4.2		3.8	3.4																						
2	5.1		3.6	4.6	11.1	8.3		10.6	3.1		4.2	2.6		3.1				4.9		12.9	4.2			7.1	3.8	2.8	3.2		4.1	4.1		3.8	3.2																							
3			4.5		11.0	7.5			3.1		4.1	3.3	5.0				3.7	4.7		13.9	4.2													4.3																						
4			3.9		11.0		9.4	11.2		3.7	4.1		5.1				3.8	4.5	3.9	13.8		4.6	10.2																																	
5	5.3			6.7	11.6		9.0	8.7		3.5		5.1		4.1				3.9	13.0			9.8	6.3	3.6	2.7		3.1	4.1		4.0	3.7		4.3																							
6	5.2	5.1		6.4	11.6		9.5					4.2	5.0		3.9				3.9	13.3	4.3				3.7	2.7		3.0		4.1	4.1			4.2																						
7	5.1	5.0		6.5		10.0			3.7	4.2	4.3	4.9		3.8			4.0	4.5		3.6				3.6			3.3	3.0		4.1					4.1																					
8	5.1			6.1			9.9	7.3			3.9	4.3		3.2	3.7			3.5	4.2			3.6			5.3	3.4		3.5																												
9	4.8			4.6	7.5	11.7				5.5		3.8	4.4		3.2	3.5			3.5				3.0	11.1		3.4	3.0	3.5		4.6	4.0		3.6																							
10			4.8	3.8		10.9				4.9		3.8	4.5	5.0	3.1			5.1	3.5		13.6	2.9									4.3	3.9	4.3	3.3		4.2																				
11			5.3	4.5						4.5		3.6			5.1	3.2			5.1	3.4	4.2	13.8										2.9	3.6	3.1	4.5		4.4	3.2		4.3																
12	5.2	4.9					10.3	3.2		3.5			4.2	3.1	3.8	5.0					13.0										3.5	2.9		3.0	4.5		3.0		4.3																	
13	5.2	4.7					8.3	9.9			3.6		4.7	3.8		3.7	5.0			4.0	12.3	3.0									4.5	3.2	2.9		3.0	4.4		4.5																		
14	5.3	4.5	3.7				8.2	10.0					3.7	4.9					4.9	3.4	3.6		3.0																		4.2															
15	5.2		4.7	10.3				10.2	2.9			3.4			3.3	3.7			3.4				3.2		10.8	4.4	2.9		4.1											3.0																
16	5.3		4.5	10.1			8.1		2.8			2.9	4.6		3.3	3.3						12.2	3.0	10.5	4.5	2.8	2.9	4.0		4.5	4.1			3.0																						
17	4.5	4.6		11.3					2.6		3.0	3.1		3.4	3.4			5.2	3.2	6.3	12.2		4.0	10.1			2.9	4.6		4.6	3.9	4.8	3.6		4.4																					
18			4.6	4.3			10.9				2.6		3.0	3.1		3.4	3.4			5.2	3.2	6.3	12.2			10.4										3.0	4.9	3.9		4.3																
19	5.6			11.6	10.1			12.2	2.9			3.4			3.3	3.3			3.3	5.0		6.9	11.5			10.3	4.2			3.0						4.5	4.8	3.7		4.1																
20	5.4	4.4			9.9	7.7	12.0				3.1			3.2			3.0					10.7	7.3																2.8	3.8	4.6			3.8												
21		4.6	4.5	11.8		7.4	12.1			3.4	3.7	2.6	5.3	3.0		3.0			3.6	7.0			8.2																		3.6															
22	6.1		4.6	11.7		6.8				3.4		2.5	5.2		3.6	2.8			3.8	10.3			6.3	8.0	10.2			2.7																3.7	3.9											
23	5.6		4.7	12.0	10.3							2.5	5.4		3.4	2.9						9.7																																		
24		5.0	4.6		9.6	7.5			3.0	3.5	4.1	2.5	5.3	3.1				5.3	3.9		9.8																																			
25		4.1	4.7		9.1		13.8	3.1			4.1			3.1	3.4			5.3	3.6	12.2	9.5			8.1	10.1																					3.6										
26	5.3	4.9		11.7	9.8		12.7	2.8				3.1		3.5	3.2	5.4			12.8				8.1	9.3	4.2	3.0	3.0		2.9	4.9		4.2	3.1		3.6																					
27	5.3	4.5		11.7	9.3	7.8	12.7				4.0		5.3	3.0			3.1	5.3		12.2	9.3	6.7	8.0			4.5	2.9	3.1		2.9	4.8	3.6	4.2		3.7	3.5																				
28	5.3	4.9	4.4	12.0		7.7	12.7				4.0	2.5		3.2				5.3																																						

尾張東部浄水場(上水) 汚泥濃度月報(平成11年4月～平成16年3月)

日付	平成11年												平成12年												平成13年																					
	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月													
1			2.9	4.4			6.0		5.2			3.9		2.6	3.4		4.0	4.6				5.6		5.9	3.4			3.1			3.4		1.7													
2	2.4		3.3	4.3	7.3			6.5	4.6		4.5	3.6		2.6	3.4		4.3		10.2	11.9				5.5	3.2	2.2			2.0	3.5		1.8	2.5													
3			3.5		7.3				4.1		3.6	3.8	4.8				4.1		11.4									3.3	3.2	2.6	1.8															
4			3.5				6.1			2.8		4.2			2.4		4.8			4.8	14.7					1.9		2.9	3.9		2.7															
5			4.4				6.1	5.9		4.5				4.1		3.3	2.2		4.9	12.0			4.4	14.5	5.3	3.0	2.7		2.8	3.2		2.7			1.7											
6			4.4				6.1			4.7				4.2		3.4	2.3		5.0				3.8		5.1	2.8	3.4		2.8	3.4		3.3	2.8													
7	2.5		3.4	4.6			6.2		3.9	4.3	2.6	4.3			3.7		3.7	5.0		14.7	3.5		6.8	2.6				2.7		3.2	2.6			1.7												
8			3.5	4.7		7.8	6.4		3.7		2.5	4.0						4.2	5.0		11.5	6.6		5.1	2.5		1.6	2.9		3.2			2.8													
9	2.7		3.6	4.8			7.9		5.2	3.5		2.2	3.9		2.8			4.2						14.6	4.9	2.6	3.4			3.7	3.0			2.9												
10			3.6		7.3	8.0			4.3	3.4		2.7	3.0	4.2	2.8				10.8	10.6		14.5					3.4	2.0			3.2	3.4	1.9	1.9	1.9		1.7									
11	2.8	3.7		7.2				3.7		4.4				4.4	2.4		2.2		5.1			9.4	14.1				3.3	2.0	2.5				2.2	2.1												
12	2.6		4.9	7.0				4.1						4.0	2.7	3.6	2.5		5.1			14.0			2.3	3.1		2.7	1.8		2.5	2.1	2.8	1.6												
13	2.6		5.0	6.8	7.7	6.7				4.1		2.8	3.7		3.8	2.5		5.2		8.5	12.5		4.8	2.3	3.2		2.5	2.8	4.9			2.8														
14	2.5		5.5		7.3	6.9			4.0	3.4	5.2	2.7	3.5		4.0			5.2			13.0		4.2	2.2		1.9	2.6		4.7	2.2		2.6														
15			3.8	5.3				5.3		4.6		5.4	2.7		2.6	3.9		3.9			12.8	13.7	3.1	2.3		2.3	2.5		3.9			2.6														
16			5.4	7.0	7.1				5.4	5.0		5.3	2.6		2.7	3.6		4.1			13.0	2.2	2.3	3.1			3.6	3.0			2.5															
17			4.0			6.8			4.6	4.9	2.7	5.7	2.4	3.4	2.8		2.2	4.1		8.4	9.4							3.0		4.0	2.6	2.3	2.2	1.5												
18	2.7	4.1				6.6				3.3	5.1		3.3	2.7		2.9		4.9			11.9			3.0	2.3	2.5	4.0																			
19	2.7		5.4	7.1				4.0					3.1	2.6	3.5	3.0			14.1				1.6	2.3	2.9		2.9	3.8		1.9			2.3	1.6												
20	2.6			7.0				6.7		4.9				2.9		3.2			13.6				2.8			3.1			2.3	1.9		2.3														
21	2.9		5.5		6.4	7.6				4.9		4.3	2.2	2.8		3.0		4.0			13.9		4.3	2.0		2.3	3.0		2.2	1.8		2.2	1.6													
22	2.6	4.2	5.7		6.1	5.8				4.9		5.1	3.1		2.5	3.1		4.1	5.2		8.4	13.6	8.6	4.4			2.6	2.8		1.9			2.2													
23		4.3	5.8	6.6							6.5	4.6		2.5	2.8		4.2		13.4			8.7	4.1	1.3	2.8			3.7	2.3																	
24	3.7			6.4	5.9					4.4		6.3	4.7	2.7	2.5			2.9			13.9	8.6		7.4					2.2		2.4															
25	3.8	4.3		6.2				1.8				5.4		2.7	2.7			3.3	8.4	12.0		14.1			2.2	2.4	2.5	2.9			1.5				1.5											
26	3.8		5.9			7.5	3.0						2.8			3.4		10.0			14.5	6.5	3.9	1.2			3.1	3.1		1.8																
27	2.7	3.3	6.5	6.0			7.4			4.5			5.0	2.7		2.4	3.7		10.6		8.5	14.6		3.7	1.7	2.0			3.4	3.3	2.4	1.8		2.0	1.5											
28	2.4		7.3			6.0							5.0	5.0	2.6		2.1	3.7	3.5	10.9		6.8	14.7		3.7	2.0		2.5		2.9		2.4														
29			7.4			6.0	6.8						4.5	4.9		2.6	1.7		4.1			6.5					2.1		2.4			2.4			1.8											
30			4.5		7.1					4.8				5.0																																

尾張東部浄水場(工水) 汚泥濃度月報(平成11年4月～平成16年3月)

日付	平成11年												平成12年												平成13年																									
	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月																	
1														10.0	7.3		10.0	10.7	12.9	11.3	7.6																										13.4			
2														9.2	8.6		10.7	8.1		10.2		12.6	10.2																											
3														8.6				9.4			12.5	10.3																												
4														8.4				9.2	9.9		11.6	10.5	7.9																										14.8	
5	10.4														7.6	9.2				10.4	10.5	8.6	13.3	13.7	13.6																					14.5				
6		10.2		11.0	9.4									8.6			8.1	9.4			11.5	10.2	8.3		13.0	13.5																			14.3					
7		10.4		12.4										7.8	8.8	9.5		8.4	9.1	10.1		10.0	10.5	8.2		12.8	13.9																	13.4						
8				12.8										7.6	9.2		9.8	8.1		11.2	10.2	11.0	8.0			14.2																								
9					8.8									8.2	9.3		10.0	8.4			10.4	10.8		13.9	13.3	13.9		15.7																	12.0					
10					9.2									9.3	9.9				9.3	10.7		9.9	10.4		13.6																					12.9				
11															10.2	10.1		9.4	11.1	11.9	10.0	10.3	8.1	13.6																										
12	10.3				9.0										10.0	10.0	8.2	9.3		12.2	10.1	11.0	13.5		13.9																			13.2						
13			12.4											14.9		10.1		8.6	9.4		11.9	10.1	10.4	13.1		13.8	14.0																	13.2						
14			11.8											16.1		9.1		8.6	9.3	10.8		10.2	10.2	13.8		14.2	14.1																12.6							
15	10.3		11.4												9.3		9.7	9.1		10.9	10.3	10.4	14.1	13.3	13.9																			14.9						
16	10.1		10.8												9.4		9.7	9.0		10.6		10.3	10.4		13.8	14.1	13.3	14.5	16.5														15.4							
17			9.8											16.1		9.6	9.9		9.1	10.4		10.5		13.0																						12.5				
18														11.5	8.0		9.7	9.5		9.8	10.7	12.0	10.3	10.8	13.4		12.7																13.5							
19	10.0													8.6		9.7	9.5	8.8	9.6		12.3	10.3	10.4	13.3	12.8	13.1	13.5															14.5								
20	10.2													6.7				9.5		12.5	10.2	10.4	13.0		13.5																					12.3				
21			10.0											6.5		9.1	9.6		9.6	9.5	10.7	12.1	10.1	10.3		13.8																	12.4							
22			9.3												6.8			8.8	9.3		11.0	12.3	9.3	10.1		13.6	13.6																	14.2						
23	10.1		8.7												7.3	9.2		8.8	9.2		10.8		10.1		13.0	14.5	13.5		16.5															13.8						
24														7.1	8.1	9.2		8.8		9.4	10.3		10.1	10.0		12.9																		14.3						
25														7.3	8.8		9.5	8.5		9.7		12.6	10.1	9.8	14.4	13.5																	13.5							
26														7.5		9.9	8.3	9.2	9.6		13.4	9.5	10.1	14.4	13.5	14.8																	12.3							
27			9.1											7.5		9.0	10.2		9.2	9.6		13.4	9.9	9.3	13.6		14.2																13.3							
28			10.5	9.2										7.0	8.6	9.3			9.2		13.4	9.0	9.1	13.4		14.2	14.0																15.9							
29																		7.5		10.5	13.7	11.0	8.5		14.0																						13.6			
30																		8.0	9.2		13.2		8.1		14.0																								15.9	
31																		9.2			13.0		8.1		14.0																									13.6
最大	10.4	10.4	10.5	12.8	9.8									16.1	9.2	9.4	10.2	10.7	9.6	9.8	11.1	13.7	12.9	11.3	14.4	14.0	14.8	14.2	15.8	16.6	16.3	15.8	12.8	14.8	15.9	15.9	15.6													
最小	10.0	10.2	10.5	8.7	8.8									6.5	6.8	8.6	9.5	7.5	7.3	9.1	9.9	10.7	9.0	8.1	7.6	12.7	12.8	13.3	14.1	15.6	14.6	11.0	11.7	12.6	13.3	13.4	12.3													
平均	10.2	10.3	10.5	10.6	9.2									9.7	8.1	9.1	9.8	9.3	8.7	9.4	10.5	12.4	10.5	10.2	11.3	13.4	13.8	13.8	15.0	16.1	15.5	13.8	12.3	14.1	14.6	13.3														

日付	平成14年												平成15年												平成16年																
	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月														
1		12.8	11.6		14.7		15.0	9.2									2.1		9.7	3.0	6.5	10.5					15.6														
2				13.7	14.4		15.5	9.5				6.3					2.5	7.4	10.1		6.5	6.2					15.3														
3				12.8		15.6	15.7							6.6				7.5				6.6				7.4															
4		12.3	11.4			14.6	15.4							7.6				7.6	9.8	2.6						6.0		5.8	12.4												
5		13.6	11.2			13.8	15.2	5.8	7.6		3.5			8.5	4.0			7.9							6.2	5.3	10.5														
6		12.2	11.1			15.8								4.8	6.7	7.8										6.4	12.4														
7	12.7	11.9	11.1		14.8	16.0									6.1					10.0				4.3				5.1													
8	13.4	12.3	11.2		15.1			4.3						7.8		4.6			3.4	9.8				6.8		5.8															
9	13.8			14.1	14.7		14.6	7.0	4.6					4.0				2.8	4.4	9.0		7.2	9.3		3.9		12.6														
10	12.9			14.5	14.7	13.0	14.3							3.4		3.9			7.7				7.5	9.2		7.6		13.3													
11			11.0			14.2	12.3										2.1			8.4				7.8					5.2												
12		12.0	10.9			14.5		5.3						11.4		4.3			4.9				8.0							2.1											
13		13.0	11.1		15.1	13.9								13.3					5.3			4.6						5.5													
14		13.9	11.2			13.1								12.6				2.9	5.3	7.7	5.2						6.6														
15	13.7	13.5	11.1		15.4		12.4							10.3		3.3			5.5								9.7	6.6		4.5											
16	13.2			14.7	15.3		6.8							9.9		6.5			5.7	6.3		8.2					10.0				4.3										
17			14.6											11.9		8.4	3.9										6.9		14.1	8.2											
18	13.4	12.4		14.0			7.1							13.6							7.7		8.7						15.8	10.6											
19		11.8	11.4					5.1							4.2				5.9		3.7	9.3					5.8		16.3	11.0											
20		13.0	6.1		15.2									4.0		5.9	7.3			6.1		5.5						5.7	16.0												
21		12.8			14.8	13.8										8.7			6.1		6.2																				
22	13.2	12.9		14.1	15.2														6.4	5.3								5.8	5.2		11.0										
23	13.6			14.3			6.7										7.4			6.4	3.1									15.4											
24	14.1				14.7	14.3	8.2									8.1	4.9	2.3											15.6												
25	13.2	12.2	11.3	14.3		14.5	8.6											4.4		2.0	8.4		6.2	10.7				5.5					11.7								
26		12.3	10.9			14.6	8.6									11.0				6.4	9.2	6.4	11.1							6.6	15.3										
27		12.3			15.3												4.1													5.4	14.8										
28		12.3	10.9		15.0											10.0			2.3	6.6		6.4																			
29	13.0		10.9		14.9		8.4																						5.1												
30	13.0			14.3										6.2																						11.7					
31	13.0						8.5										6.0																								
最大	14.1	13.9	11.6	14.7	15.4	16.0	15.7	9.5	7.6	13.6	13.3	11.0	8.7	8.5	4.0	2.9	6.6	9.2	10.1	6.8	11.1	10.5			10.0	6.6	16.3	15.6	16.6	~	2.9	-									
最小	12.7	11.8	6.1	12.8	14.4	13.0	6.7	4.3	4.0	9.9	3.5	3.4	3.3	3.9	2.1	2.0	2.1	7.4	2.8	2.6	6.5	4.3			3.9	5.1	5.8	2.1	15.6	~	2.0	-									
平均	13.3	12.6	10.8	14.1	15.0	14.4	11.4	6.6	5.4	11.8	9.8	6.2	6.0	5.9	2.7	2.6	5.3	8.0	7.6	5.1	8.4	7.7			6.7	5.8	13.7	9.5	16.1	~	2.6	10.6									

上野浄水場(1号) 汚泥濃度月報(平成11年4月～平成16年3月)

日付	平成11年												平成12年												平成13年																					
	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月	
1	5.8									3.1	3.4									8.8	3.2			6.10		1.8	2.3																			3.8
2	4.2		3.6			2.2			3.2		3.3	3.6			5.3				8.3	5.8			3.1		3.0																		4.0			
3		2.9		4.6						3.1	3.6								9.1																									2.7		
4		5.2	3.2		5.0	2.3			2.7		2.9				4.1			6.2	8.9		2.8				3.8	3.0																2.7				
5	5.3		4.1	2.7		5.3												6.9	8.2			3.3	2.9		3.9	6.4															4.3					
6	5.8		4.2	2.4				2.8		2.6					2.3		4.8		5.8	3.4			4.9	4.6		2.7	2.8													2.1						
7	5.9		6.8	6.3			4.3			1.9	2.1	2.8	2.8		2.6	3.6	4.4		5.2			2.9	3.50		1.9													3.4								
8		5.9	5.3			4.9	2.6	2.3		2.3	3.1			3.1				4.1		4.9	3.9		4.10			3.4																				
9		4.1	5.3			2.2				2.2	2.9			2.5							4.7			3.3	3.0	2.2															2.1					
10		6.4		2.3			2.3	2.1		2.9	5.1				2.3	4.2		7.8			4.0																			3.1						
11		3.8							2.4			4.4		2.9	3.8	4.4	7.0			3.9				2.3	2.0	2.3																				
12	6.3	3.0		5.2	2.4			1.8			5.3		6.8		3.9			7.2			4.1		3.80																	3.9						
13	2.9		5.2	2.8			5.5		2.0	3.4				6.5			4.3	8.8	3.3	4.2		3.5	4.90	2.5															2.6							
14	5.8					4.9			3.8	4.0	3.5			5.6	3.1	4.2			5.2		6.7	5.30		2.3	2.6														2.4							
15	5.9	3.0				4.3				2.8		4.8			3.9						4.8		4.20																		2.7					
16	4.6					5.2		2.0			2.5	2.8	3.8		3.6	2.5		3.9			7.0			4.3	3.53	2.1	2.0											3.8								
17									2.5					3.6							9.2			2.8	3.32	4.1															2.9					
18		3.1		2.3			2.1				3.7	3.3		3.2			2.7	6.7	7.3		4.2	5.1		2.14	2.0	3.5												3.5								
19	5.8		5.3				5.0						3.2		3.9	2.4					5.5	3.6	5.4	3.1	2.47														2.9							
20	6.0						3.5													7.5		4.0			3.76	3.4		2.9																		
21		6.2			3.4			3.8	3.1	2.6										6.5				3.6	3.43		2.3	3.4											3.0							
22	8.1			7.3	3.4	2.3				3.8		4.2	2.9									3.1	4.1		3.42														4.1							
23	4.1	8.2																																												
24	4.1		2.4				2.0			4.1	2.8				3.3						3.1				3.5																					
25											3.5	3.8		3.9																														1.8		
26	3.0		4.2	2.2		3.6				4.2	3.0				4.6						3.7	7.4			5.1	3.1	3.53													1.9						
27	4.2		4.8								3.2	3.4					2.9						8.3		4.0			2.90	2.7													2.3				
28		3.3				2.6				4.4	3.3							4.2	6.9					4.3	3.32																					
29		1.7	3.4								3.5	3.3		3.1								7.1			3.8		5.4																3.5			
30						2.6					2.9		4.0			3.1					2.8																									

上野浄水場(2号) 汚泥濃度月報(平成11年4月～平成16年3月)

日付	平成11年												平成12年												平成13年															
	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月							
1	5.8		3.4		2.4	4.2	2.4			3.1	3.4		6.4	4.3		3.4	6.4		8.8	3.2						1.8	2.3											3.8		
2	4.2		3.6	3.8	4.0					3.3			6.6			3.2		8.3	5.8				3.1	5.90	3.0												4.0			
3			2.9							3.1		2.7				3.7	4.1		9.1																	5.1		2.7		2.7
4					3.2		2.3			2.7							4.2	6.2	8.9		2.8													3.0	5.3		3.4	3.3		
5	5.3			4.1		5.3							3.3		4.1			6.9	8.2					2.9	4.10	3.9											4.3			
6	5.8	6.3		4.2	2.4	1.9	6.2		2.8					3.8	2.3		4.8	7.8	5.8	3.4					4.9		4.6	3.3									2.1			
7	5.9	6.7	6.8	6.3						1.9	2.1	2.8	2.8			3.6	2.8		5.2	3.9		2.9				1.9	4.4										3.4			
8	6.3			5.3			2.6					3.1		3.9	3.1		4.3	4.1		4.9				4.10				3.4												
9	5.9		4.1	5.3	2.8						2.2	2.9		5.0			4.5			4.7			3.8	3.3		3.0	2.2										2.1	2.8		
10		2.8					2.3	2.1				5.1	2.8	3.8		2.3			7.8	4.0		4.0																3.1		
11		2.5	3.8								3.5	3.1	4.4			2.9		4.4	7.0		3.9					2.3	2.0	2.3	4.5								7.1	3.2		
12	6.3			5.2	2.4	4.4			2.7			5.3	3.6	6.8	5.2	3.9			7.2				4.1		3.80											5.2	3.8	3.9	2.4	2.6
13	2.9	2.3		5.2		6.7		2.0			5.6	3.8		6.5	3.0			8.8	3.3	4.2			3.5	4.89	2.5											2.7		4.3		
14	5.8	2.1	5.5	5.6		7.3	4.9		3.8	4.0	3.5	3.1			3.1		6.8		5.2		6.7	5.30		2.3	2.6										4.1		2.6	2.4		
15	5.9			5.4		4.3					4.9		4.8	2.9		3.9			2.8	4.4				4.19												2.8		2.4		2.7
16			5.5	2.0	5.2			2.0		2.7	3.9		3.6	2.5		3.9		7.0				4.3	3.54	2.1	2.0										3.1	3.4			3.8	
17		3.9	4.5		2.0	5.3			2.5		3.8	2.8	3.6		3.3			9.2	3.0		2.8		3.32		4.1											2.8	2.5		2.9	
18		4.5				4.8	2.1			3.7	3.3		3.2		3.3			7.3		4.2			2.14	2.0	3.5	2.8	2.8											3.5		
19	5.5	5.8		2.1		5.0					3.2	2.5	3.9		4.0			5.5			5.4	3.1	2.46												2.9		2.9	2.8		
20	6.0	3.3				5.5		1.9			2.8	3.8					7.0	7.5	4.5	4.0			3.74	3.4		2.9														
21	7.6	2.7	3.1	6.2		8.8	3.4			3.8	3.1	2.6	3.7			3.2	3.7							3.6	3.44		2.3	3.4								2.7			3.4	
22	8.1			6.3		7.3		2.3				3.7		4.2						3.9	3.1	4.1		3.43													4.1			
23	4.1			5.0						2.9	3.3		4.6			2.5		8.7				3.4	3.31	2.3	2.6											2.8		4.2		
24		4.1	9.1		3.1			1.9	4.1		4.1	3.0			3.4			6.8			3.6		3.96												3.8	6.8				
25		4.4	9.6		2.9							3.8	3.2	3.9		3.0			6.5		6.3	3.6		4.08	2.9	2.2	2.1									1.8	5.1			
26	3.8			4.2		3.6	1.9		4.2	3.5	3.5	2.5		2.8	4.4			7.4				3.1	3.54																1.9	
27		2.2		4.8			2.4			4.4	3.3	3.3	4.6		2.6	4.1		6.9				4.3	3.33		2.4											3.0				
28	4.9	4.4				2.4																												2.4	3.1		2.8			
29				3.4								3.3		3.1			4.3	7.1		3.8		5.4												4.9			3.5			
30				4.3	3.0							3.9		2.9																							2.4			
31		4.2										4.0				3.1		7.2			4.4																3.6	2.8		
最大	8.1	6.7	9.6	6.3	4.0	8.8	6.2	2.6	2.8	4.4	4.0	5.6	11.8	6.8	6.5	4.4	4.5	7.1	9.2	8.8	6.3	5.4	6.7	5.90	4.9	4.1	6.4	5.3	6.8	7.1	5.1	4.3	3.4							
最小	2.9	2.1	2.9	3.4	2.0	1.9	3.4	1.9	1.9	2.1	2.6	2.5	2.9	2.5	2.3	2.5	4.1	5.5	2.8	2.8	2.8	2.9	2.14	2.0	1.8	2.1	2.8	2.4	1.8	2.1	1.9	1.9	2.1							
平均	5.6	3.9	5.1	5.0	2.7	5.1	4.6	2.3	2.1	3.4	3.1	3.7	3.7	4.4	3.7	3.3	3.7	6.0	7.7	4.6	4.0	4.1	3.7	3.8	2.9	2.4	3.4	3.8	3.3	3.6	3.4	3.1	2.7							

上野浄水場(3号) 汚泥濃度月報(平成11年4月～平成16年3月)

日付	平成14年												平成15年												平成16年							
	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月					
1				3.0				4.5		5.4	2.8									3.0							4.0					
2					2.4				3.3	4.9									1.9	1.6	4.3					3.7						
3				3.2		2.8	3.9		2.9	8.8				2.6	2.1										2.2			2.0	4.8			
4		2.1	1.9			3.9			5.5		3.2					1.8		2.4	3.8	2.4	2.7			4.4			2.1	7.8				
5				2.5		2.7		4.1	3.8		3.0		2.5											3.9								
6			3.2					4.4					4.9	1.5		1.8	2.9						2.5	3.5								
7	2.0	2.1			3.7	2.0		4.2		4.0	2.1					1.7			3.2	2.1												
8			2.6	3.0		2.5			3.6											3.2	3.0					9.0						
9				2.4		3.0		3.6	5.3		2.8	2.6				1.8			2.8									1.8	8.5			
10	1.9			3.0	4.2	1.8			3.7				2.3	1.9			4.2								1.9							
11		2.4				4.3		3.0	4.6		2.2					1.8		5.5	2.5	3.1	5.5							4.6				
12		2.0		2.7		3.8	3.9	3.0	4.3					1.6		2.3			3.8	2.6		2.6				2.3	4.8					
13		2.0		3.8			3.3	4.0		2.3	2.5		2.2				2.8															
14			2.1	2.8			3.0					2.2			1.6	1.6	2.4		2.9					2.5								
15	1.8		2.2	2.4			2.6			6.5	2.5														2.1	11.9		2.4				
16				2.4		3.9	2.6		4.4		2.3					1.7	2.5	2.4	2.7		8.0	2.1				2.5	5.1					
17			2.8	3.7	3.7	3.7		3.7	5.8			2.9	2.3	1.6			5.6			8.2	4.6	2.4				5.3						
18	2.0	1.8	2.3	4.4		3.5		4.0	4.1	2.4	2.5				1.6		2.6	2.8	6.7							4.7						
19			3.5		2.1		3.4	4.0		3.0			2.4	1.5		2.2	3.2			3.4		2.1	2.8		2.2	4.5						
20			2.6		3.7			3.5		2.3	2.5					10.7	5.0		2.7		2.9											
21	1.9						4.8		5.2	3.2			2.4			2.8	5.1						2.5		10.3							
22		2.2	2.1		1.6		4.9		3.6			2.9						3.0		3.6						2.4						
23			2.1	3.6		3.5					4.7				2.4	1.8	2.5									2.5						
24	1.9				1.9			4.5	2.5		1.7		2.3	1.7	3.6			2.5		4.7	2.4		5.9			2.5						
25			2.8	1.8		4.3			3.8	2.9	3.1						1.9			3.7					3.4							
26					2.4	3.1	3.4						2.1	1.8		3.3			3.7			2.2			2.3							
27			2.9		2.7	4.2			3.8			3.3					1.7		2.8		2.1				1.7							
28	2.2				4.1				2.2				2.3			2.2		2.4								1.7						
29			2.5		2.2							3.4					4.2			3.2						2.4						
30			2.6		3.3		3.4	3.2							1.8		5.5															
31	1.8				3.6							3.0		1.7			2.6			2.4												
																										変動幅		平均				
最大	2.2	2.2	3.2	4.4	4.2	4.3	4.3	4.9	4.5	8.8	3.2	3.2	4.7	4.9	2.1	3.6	10.7	5.6	3.8	3.8	8.2	4.6	4.4	5.9	11.9	3.4	8.5	12.3	~	2.1	-	
最小	1.8	1.8	1.9	1.8	1.6	1.8	2.4	2.6	2.9	2.2	2.1	1.7	2.2	2.1	1.5	1.6	1.6	1.7	2.4	2.1	2.6	2.1	1.9	2.1	1.7	1.8	2.3	5.5	~	1.5	-	1,2,3号の平均
平均	1.9	2.0	2.5	2.8	3.0	3.0	3.4	3.8	3.7	4.5	2.7	2.5	3.1	2.6	1.7	2.0	3.3	3.6	2.8	3.0	4.5	2.7	2.7	3.6	8.2	2.4	4.4	8.2	~	1.7	3.7	2.4